Linear LED to light underside of vent canopy. L5/17 Continuous run of linear LED luminaires mounted within tube entrance cladded soffit. NOTE: slot size on vent facade cladding dictated by dimensions of D1 luminaires. Luminaires to Square profile LED downlights mounted within cladding detail. have Its own L1/10 L1/10 L1/10 L1/10 integral lighting - by others L1/10 L1/10 L1/10 L1/10 L1/10 NOTE: L4 - a channel to be provided within the rotunda cladding to house the L4 luminaires. Refer to SF drawing 3011-05-005. 1/10 NOTE:L4 LUMINARIES MOUNTED WITHIN RECESS ON TOP OF LUL STAIRS STRUCTURE ON ALL SIDES SOUTHERN ELEVATION

NORTHERN ELEVATION

B1 - IP65 25W P/M LINEAR LED LUMINAIRE, TO BE INTEGRATED INTO BENCH.

LUMINAIRE KEY

- C1 18M HIGH FEATURE LIGHTING COLUMN WITH MULTIPLE HEAD LED PROJECTORS: ESTIMATED WATTAGE PER 1.2KW
- C2 6M HIGH LED LIGHTING COLUMNS WITH MULTIPLE HEAD LED PROJECTORS. ESTIMATED WATTAGE 300W.
- D2 IP65 22W RECESSED LED DOWNLIGHT.
- D3 IP65 30W LED DOWNLIGHT
- L1 IP54 50W LINEAR LED LUMINAIRE.
- L2 IP65 40W LINEAR LED LUMINAIRE.
- L3 JP54 15W P/M LINEAR LED LUMINAIRE.
- L4 IP65 36W P/M LINEAR LED LUMINAIRE.
- L5 IP65 25W P/M LINEAR LED MODULES COMPLETE WITH WIDE BEAM DISTRIBUTION.
- L6 IP65 30W P/M LINEAR LED LUMINAIRE
- L7 IP65 40W SURFACE MOUNTED LINEAR LED LUMINAIRE.
- L8 IP65 36W SURFACE MOUNTED LINEAR LED LUMINAIRE.
- L8A IP65 12W SURFACE MOUNTED LINEAR LED LUMINAIRE.
- L10 IP65 70W LINEAR LED LUMINAIRE. L11 - IP65 36W LINEAR LED LUMINAIRE.
- P2 IP65 30W LED PROJECTORS.
- T1 IP65 30W IN-GROUND LED UPLIGHTER.
- U1 IP68 36W IN GROUND, LINEAR, ADJUSTABLE LED UPLIGHTER.
- U2 IP68 24W IN GROUND, LINEAR, ADJUSTABLE LED UPLIGHTER.
- U3 IP68 12W IN GROUND, LINEAR, ADJUSTABLE LED UPLIGHTER.

01 29-07-11 BH CS	CS

Issue Date By Chkd Appd

Client
Cubitt House
1 Battle Bridge Road
London NIC 4AH
Phone +44 (0)20 7147 6011
Email
KingsCrossRedevelopmentProje
Gnetworkrali.co.uk

Network Rail



studio FRACTAL

Job Title

King's Cross Station Redevelopment Programme Package 7

Kings Cross Square TTH Stair, Rotunda Linking Canopy and Rotunda Lighting Plan This drawing has been produced by Stanton Williams under an instruction by Network Rail on behalf of London Underground Ltd for submission under the Channel tunnel Rail Link Act 1996 - Schedule 6, Plans and Specification, for the following structures - The Cladding and retail extension to the Blue Egg Ventilation Shaft, the Tube Ticket Hall Main Staircase and the Euston Road Canopies.

Scale at A1 1:50

NOT FOR CONSTRUCTION

Document Reference No ENG-DWG-SWA-SSQ-SFR-3011-05-004

Planning/Grip4

SF Job No Drawing No 3011 05-004

02