

NOT FOR CONSTRUCTION

LUMINAIRE KEY

B1 - IP65 25W P/M LINEAR LED LUMINAIRE, TO BE INTEGRATED INTO BENCH.

C1 - 18M HIGH FEATURE LIGHTING COLUMN WITH MULTIPLE HEAD LED PROJECTORS. ESTIMATED WATTAGE PER 1.2KW

C2 - 6M HIGH LED LIGHTING COLUMNS WITH MULTIPLE HEAD LED PROJECTORS. ESTIMATED WATTAGE 300W.

D2 - IP65 22W RECESSED LED DOWNLIGHT.

D3 - IP65 30W LED DOWNLIGHT

L2 - IP65 40W LINEAR LED LUMINAIRE.

L3 - JP54 15W P/M LINEAR LED LUMINAIRE. L4 - IP65 36W P/M LINEAR LED LUMINAIRE.

L5 - IP65 25W P/M LINEAR LED MODULES COMPLETE WITH WIDE BEAM DISTRIBUTION.

L7 - IP65 40W SURFACE MOUNTED LINEAR LED LUMINAIRE.

L8 - IP65 36W SURFACE MOUNTED LINEAR LED LUMINAIRE.

L8A - IP65 12W SURFACE MOUNTED LINEAR LED LUMINAIRE.

L10 - IP65 70W LINEAR LED LUMINAIRE.

L11 - IP65 36W LINEAR LED LUMINAIRE.

P2 - IP65 30W LED PROJECTORS.

T1 - IP65 30W IN-GROUND LED UPLIGHTER.

U1 - IP68 36W IN - GROUND, LINEAR, ADJUSTABLE LED UPLIGHTER.

U2 - IP68 24W IN - GROUND, LINEAR, ADJUSTABLE LED UPLIGHTER.

U3 - IP68 12W IN - GROUND, LINEAR, ADJUSTABLE LED UPLIGHTER.

01 29-07-11 BH CS CS

Issue Date By Chkd Appd

Client
Cubit House
1 bittle Bridge Road
London NIC 4AH
Phone +44 (0) 7147 6011
Email
KingsCrossRedevelopmentProje
Gnetworkrail.co.uk

Network Rail



studio FRACTAL

Job Title

King's Cross Station Redevelopment Programme Package 7

Kings Cross Square Push Pull Ventilation Shaft Lighting Plan

Scale at A1
1:50
Decument Reference No
ENG-DWG-SWA-SSQ-SFR-3011-05-008
Drawing Status
GRIPStage4

SF Job No Drawing No 3011 05-008

01