



NOTE: L11 LUMINAIRES SURFACE MOUNTED TO CANOPY STRUCTURE.

- LUMINAIRE KEY**
- B1 - IP65 25W PIM LINEAR LED LUMINAIRE, TO BE INTEGRATED INTO BENCH.
 - C1 - 18M HIGH FEATURE LIGHTING COLUMN WITH MULTIPLE HEAD LED PROJECTORS. ESTIMATED WATTAGE PER 1.2KW
 - C2 - 6M HIGH LED LIGHTING COLUMNS WITH MULTIPLE HEAD LED PROJECTORS. ESTIMATED WATTAGE 300W.
 - D1 - IP65 10W SURFACE MOUNTED LED PROJECTOR.
 - D2 - IP65 22W RECESSED LED DOWNLIGHT.
 - D3 - IP65 30W LED DOWNLIGHT
 - L1 - IP54 50W LINEAR LED LUMINAIRE.
 - L2 - IP65 40W LINEAR LED LUMINAIRE.
 - L3 - IP54 15W PIM LINEAR LED LUMINAIRE.
 - L4 - IP65 36W PIM LINEAR LED LUMINAIRE.
 - L5 - IP65 25W PIM LINEAR LED MODULES COMPLETE WITH WIDE BEAM DISTRIBUTION.
 - L6 - IP65 30W PIM LINEAR LED LUMINAIRE.
 - L7 - IP65 40W SURFACE MOUNTED LINEAR LED LUMINAIRE.
 - L8 - IP65 36W SURFACE MOUNTED LINEAR LED LUMINAIRE.
 - L8A - IP65 12W SURFACE MOUNTED LINEAR LED LUMINAIRE.
 - L10 - IP65 70W LINEAR LED LUMINAIRE.
 - L11 - IP65 40W LINEAR LED LUMINAIRE.
 - L12 - IP65 40W LINEAR LED LUMINAIRE
 - P2 - IP65 30W LED PROJECTORS.
 - T1 - IP65 30W IN-GROUND LED UPLIGHTER.
 - U1 - IP68 36W IN - GROUND, LINEAR, ADJUSTABLE LED UPLIGHTER.
 - U2 - IP68 24W IN - GROUND, LINEAR, ADJUSTABLE LED UPLIGHTER.
 - U3 - IP68 12W IN - GROUND, LINEAR, ADJUSTABLE LED UPLIGHTER.

02	09-09-11	BH	CS	CS
01	05-08-11	BH	CS	CS

Issue	Date	By	Chkd	Appd
-------	------	----	------	------

ARUP
 13, JILTZBOY STREET
 LONDON, W1T 4BQ
 TEL: +44(0)207361531 FAX: +44(0)2075803924
 WWW.ARUP.COM

John McAslan + Partners
 49 Pinner Place London W11 4DA
 Tel: +44 (0)20 7721 2803
 Fax: +44 (0)20 7721 8835
 www.mcaslan.co.uk

Architect
 Landscape Architect

studio | FRACTAL
 Suite 113, The Beehive, City Place,
 Gatwick, East Sussex, RH6 0PA,
 Tel: 01293 804792, Email: info@studiofractal.co.uk



Job Title
**Kings Cross Station
 Redevelopment Programme
 Package 7**

Drawing Title
 Kings Cross Square
 Southern Facade Canopy
 Lighting Plan

Scale of A1
 1:100

Document Reference No
 ENG-DWG-OAP-SFC-CEL-0019

Drawing Status
 APPROVAL IN PRINCIPLE/ PLANNING

OAP Job No	Drawing No	Rev.
3011	05-019	02

NOT FOR CONSTRUCTION