

2-4 BUCKNALL STREET, LONDON

NOISE IMPACT ASSESSMENT

Report 5091.NIA.01

Prepared on 19 April 2011

For:

Oak Wood Builders

10 Johnsons Way

Park Royal

London

NW10 7PF

CONTENTS

1.0	INTRODUCTION	1
2.0	ENVIRONMENTAL NOISE SURVEY	1
2.1	Procedure	1
2.2	Equipment	1
3.0	RESULTS	1
4.0	NOISE CRITERIA	2
5.0	DISCUSSION	2
6.0	CONCLUSION	4

List of Attachments

5091.SP1	Indicative Site Plan
5091.TH1	Environmental Noise Time History
Appendix A	Glossary of Acoustic Terminology
Appendix B	Acoustic Calculations

1.0 INTRODUCTION

Practical Acoustics has been commissioned by Oak Wood Builders, 10 Johnsons Way, Park Royal, London, NW10 7PF to measure existing background noise levels at 2-4 Bucknall Street, London, WC2H 8LA. The measured noise levels will be used to determine noise emission criteria for the proposed plant units in agreement with the planning requirements of the London Borough of Camden.

This report presents the results of the environmental survey followed by noise impact calculations and outlines any necessary mitigation measures.

2.0 ENVIRONMENTAL NOISE SURVEY

2.1 Procedure

Measurements were taken at the position shown in Site Plan 5091.SP1. The choice of this position was based both on accessibility and on collecting representative noise data in relation to the nearest noise sensitive receivers.

Continuous automated monitoring was undertaken for the duration of the survey between 09:30 on 29 March and 09:30 on 30 March 2011.

Weather conditions were dry with light winds, therefore suitable for the measurement of environmental noise.

The measurement procedure generally complied with BS7445:1991. *Description and measurement of environmental noise, Part 2- Acquisition of data pertinent to land use.*

2.2 Equipment

The equipment calibration was verified before and after use and no abnormalities were observed.

The equipment used was as follows.

- Svantek Type 957 Class 1 Sound Level Meter
- Norsonic Type 1251 Class 1 Calibrator

3.0 RESULTS

The $L_{Aeq: 15min}$, $L_{Amax: 15min}$, $L_{A10: 15min}$ and $L_{A90: 15min}$ acoustic parameters were measured and are shown as a time history in Figure 5091.TH1.

Background noise levels were dominated by traffic noise from Bucknall Street and surrounding roads.

Minimum measured background levels are shown in Table 3.1.

	Minimum Background Noise L _{A90} : 15min dB(A)
Daytime (07:00-23:00)	52
Night-time (23:00-07:00)	50

Table 3.1: Minimum background noise levels

4.0 NOISE CRITERIA

The London Borough of Camden’s criteria for noise emissions of new plant installations are as follows:

“Design measures should be taken to ensure that specific plant noise levels at a point 1 metre external to sensitive façades are at least 5dB(A) less than the existing background measurement (L_{A90}) when the equipment is in operation. Where it is anticipated that equipment will have a noise that has distinguishable, discrete continuous note[…], special attention should be given to reducing the noise at any sensitive façade by at least 10dB(A) below the L_{A90} level.”

In order to provide a more robust assessment, it is proposed that criteria are set at 10dB below the existing minimum background noise levels, as shown in Table 4.1.

	Daytime	Night-time
Noise criterion at nearest residential receiver (10dB below minimum L _{A90})	42 dB(A)	40 dB(A)

Table 4.1: Proposed Noise Emissions Criteria

As the units are only expected to be used during typical office hours, the worst case scenario of a full daytime criterion of 42dB(A) will be used in this assessment.

5.0 DISCUSSION

The proposed plant to be installed comprises seven air conditioning units, selected as follows:

- 7 no. Daikin Air Conditioning Unit type REYQ8P9

The selected unit has a manufacturer’s sound pressure level at 1m as shown in Table 5.1. Loudest modes of operation have been used, as they provide a worst case scenario.

Unit	Sound Pressure Level at 1m (dB) in each Frequency Band								dB(A)
	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz	
Daikin Unit type REYQ8P9	60	62	61	56	52	45	43	37	58

Table 5.1 Manufacturer spectral sound pressure level at 1m for proposed unit

The proposed units will be installed on a rear wall of the north eastern corner of the flat roof of 2-4 Bucknall Street. The closest residential window is a residential flat located at the fifth floor of a building located on the corner of Bucknall Street and Earnshaw Street, approximately 55m from the proposed plant location as shown in indicative site plan 5091.SP1.

Taking into account all necessary acoustic corrections including distance corrections, the resulting noise level at the window of the nearest noise sensitive receiver would be as shown in Table 5.3. Detailed calculations are shown in Appendix B.

Receiver	Operating Hours Criterion	Level at Receiver (due to proposed plant)
Nearest Residential Window	42 dB(A)	31 dB(A)

Table 5.3: Noise levels and criteria at nearest noise sensitive receivers

As shown in Table 5.3 and Appendix B, the predicted plant noise emissions would meet the requirements set out by the London Borough of Camden.

In addition to the above assessment, further calculations will aim to assess whether the noise emissions from the proposed plant unit would be expected to meet recognised British Standard recommendations, in order to further ensure the amenity of nearby noise sensitive receivers.

British Standard 8233:1999 ‘*Sound insulation and noise reduction for buildings – Code of Practice*’ gives recommendations for acceptable internal noise levels in residential properties. Assuming worst case conditions, of the closest window being for a bedroom, BS8233:1999 recommends 30dB(A) as being ‘Good’ internal resting/sleeping conditions.

With external levels of 31dB(A), the window itself would only need to provide 1dB attenuation to achieve ‘Good’ conditions. However, according to BS8233:1999, even a partially open window offers a minimum of 10dB attenuation.

It can therefore be predicted that noise emissions from the proposed plant would be expected to comfortably meet the recommendations of the relevant British Standard, even with neighbouring windows partially open. Predicted levels are shown in Table 5.4, with detailed calculations shown in Appendix B.

Receiver	'Reasonable' Conditions Design Range – For <i>resting/sleeping conditions in a bedroom, in BS8233:1999</i>	Noise Level at Receiver (due to plant installation)
Inside Nearest Residential Space	35 dB(A)	21 dB(A)

Table 5.4: Noise levels and criteria inside nearest residential space

6.0 CONCLUSION

An environmental noise survey has been undertaken at 2-4 Bucknall Street, London, WC2H 8LA. The results of the survey have enabled criteria to be set for noise emissions from the proposed plant in accordance with the London Borough of Camden's planning conditions.

A noise impact assessment has then been undertaken using manufacturer noise data to predict noise levels at the nearby noise sensitive receivers due to the current proposals.


Calculations have shown that the noise emissions of the proposed installation will be within the requirements of the London Borough of Camden for the nearest noise sensitive receivers.

Report by

Duncan Martin AMIOA

Checked by

Kyriakos Papanagiotou MIOA



Date: 19 April 2011

FIGURE 5091.SP1

Title:
 Indicative site plan showing proposed plant locations, noise monitoring position and nearest noise sensitive receiver

2-4 BUCKNALL STREET, LONDON

Environmental Noise Time History
29 March to 30 March 2011




Figure 5091.TH1

APPENDIX A

GLOSSARY OF ACOUSTIC TERMINOLOGY

dB(A)

The human ear is less sensitive to low (below 125Hz) and high (above 16kHz) frequency sounds. A sound level meter duplicates the ear's variable sensitivity to sound of different frequencies. This is achieved by building a filter into the instrument with a similar frequency response to that of the ear. This is called an A-weighting filter. Measurements of sound made with this filter are called A-weighted sound level measurements and the unit is dB(A).

L_{eq}

The sound from noise sources often fluctuates widely during a given period of time. An average value can be measured, the equivalent sound pressure level L_{eq} . The L_{eq} is the equivalent sound level which would deliver the same sound energy as the actual fluctuating sound measured in the same time period.

L_{10}

This is the level exceeded for not more than 10% of the time. This parameter is often used as a "not to exceed" criterion for noise

L_{90}

This is the level exceeded for not more than 90% of the time. This parameter is often used as a descriptor of "background noise" for environmental impact studies.

L_{max}

This is the maximum sound pressure level that has been measured over a period.

Octave Bands

In order to completely determine the composition of a sound it is necessary to determine the sound level at each frequency individually. Usually, values are stated in octave bands. The audible frequency region is divided into 10 such octave bands whose centre frequencies are defined in accordance with international standards.

Addition of noise from several sources

Noise from different sound sources combines to produce a sound level higher than that from any individual source. Two equally intense sound sources operating together produce a sound level which is 3dB higher than one alone and 10 sources produce a 10dB higher sound level.

Attenuation by distance

Sound which propagates from a point source in free air attenuates by 6dB for each doubling of distance from the noise source. Sound energy from line sources (e.g. stream of cars) drops off by 3dB for each doubling of distance.

Subjective impression of noise

Sound intensity is not perceived directly at the ear; rather it is transferred by the complex hearing mechanism to the brain where acoustic sensations can be interpreted as loudness. This makes hearing perception highly individualised. Sensitivity to noise also depends on frequency content, time of occurrence, duration of sound and psychological factors such as emotion and expectations. The following table is a reasonable guide to help explain increases or decreases in sound levels for many acoustic scenarios.

Change in sound level (dB)	Change in perceived loudness
1	Imperceptible
3	Just barely perceptible
6	Clearly noticeable
10	About twice as loud
20	About 4 times as loud

Barriers

Outdoor barriers can be used to reduce environmental noises, such as traffic noise. The effectiveness of barriers is dependent on factors such as its distance from the noise source and the receiver, its height and its construction.

Reverberation control

When sound falls on the surfaces of a room, part of its energy is absorbed and part is reflected back into the room. The amount of reflected sound defines the reverberation of a room, a characteristic that is critical for spaces of different uses as it can affect the quality of audio signals such as speech or music. Excess reverberation in a room can be controlled by the effective use of sound-absorbing treatment on the surfaces, such as fibrous ceiling boards, curtains and carpets.

APPENDIX B

2-4 BUCKNALL STREET, LONDON

EXTERNAL PLANT NOISE EMISSIONS CALCULATION

Source: Daikin A/C Unit

	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
Manufacturer's sound pressure level at 1m Daikin A/C Unit Type - REYQ8P9	60	62	61	56	52	45	43	37	58
Correction for number of units, (7 No.)	8	8	8	8	8	8	8	8	
Distance correction to receiver, dB (55m)	-35	-35	-35	-35	-35	-35	-35	-35	
Sound Pressure Level at Receiver due to Daikin A/C Unit	33	35	34	29	25	18	16	10	31

Day Time Criterion	42
---------------------------	-----------

BS 8233 ASSESSMENT CALCULATION

Receiver: Inside Nearest Residential Window

Daikin A/C Unit Type - RZQ250C

	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
Sound pressure level outside window	33	35	34	29	25	18	16	10	31
Minimum attenuation from partially open window, dB	-10	-10	-10	-10	-10	-10	-10	-10	
Sound pressure level inside nearest noise sensitive window	23	25	24	19	15	8	6	0	21

Design Range	30-35
---------------------	--------------