

Wellcome Trust

**Bentley House, 200 Euston Road, London
Plant Noise Assessment Report**

| Issue | Date |
|-------|-----------------|
| 1.0 | 01 October 2010 |

**HILSON MORAN
ONE DISCOVERY PLACE
COLUMBUS DRIVE
FARNBOROUGH
HAMPSHIRE GU14 0NZ**

engineering the future
for the built environment

Bentley House, 200 Euston Road, London

Plant Noise Assessment Report

| | |
|----------|-----------------|
| Project: | 9552.02.01 |
| Issue: | 1.0 |
| Status: | Final |
| Date: | 01 October 2010 |

| | |
|-------------|---|
| Originator: | Mark Brightwell Principal Acoustic Consultant |
| Approved: | Nicholas Jones Head of Acoustics |
| Copies to: | Faithful and Gould TP Bennett DP9 Wellcome Trust hmp104 – Acoustics |

Contents

| | | |
|-----|--|----|
| 1 | EXECUTIVE SUMMARY | 3 |
| 2 | INTRODUCTION | 4 |
| 3 | SITE DESCRIPTION | 5 |
| 4 | SURVEY METHODOLOGY | 6 |
| 5 | SURVEY RESULTS & OBSERVATIONS | 8 |
| 5.1 | Results | 8 |
| 5.2 | Observations | 8 |
| 6 | EXTERNAL PLANT NOISE LIMITS | 9 |
| 6.1 | Local Authority Guidance | 9 |
| 7 | PLANT NOISE ASSESSMENT | 10 |
| 7.1 | Proposed Plant Locations and Nearest Noise Sensitive Windows | 10 |
| 7.2 | Manufacturer's Plant Noise Data | 11 |
| 7.3 | Proposed Plant Operating Hours | 13 |
| 7.4 | Plant Noise Prediction Calculations | 14 |
| | APPENDIX A: ACOUSTIC TERMINOLOGY | 15 |
| | APPENDIX B: UNMANNED NOISE MONITORING RESULTS | 16 |
| B1. | Time History Graph of Noise Levels at Measurement Position A (Facing Euston Road) | 16 |
| B2. | Time History Graph of Noise Levels at Measurement Position B (Facing Stephenson Way) | 17 |
| | APPENDIX C: FULL ATMOSPHERIC PLANT NOISE LEVELS CALCULATIONS | 18 |
| C1. | CHP Unit Atmospheric Noise Levels | 18 |
| C2. | AHU Atmospheric Noise Levels | 19 |
| C3. | AHU Packaged Plant Room Atmospheric Noise Levels | 21 |
| | DOCUMENT CONTROL & REFERENCES | 24 |
| | Change History | 24 |
| | Changes Forecast | 24 |
| | Document References | 24 |

1 EXECUTIVE SUMMARY

A planning application for a new development, comprising a student Hall of Residence and associated amenity areas, is proposed at Bentley House, 200 Euston Road, London. The proposed development will include external building services plant.

Hilson Moran therefore undertook an environmental noise survey at the proposed development site, in order to determine prevailing noise levels affecting the site and its surroundings and inform the planning process.

The results of the survey and the requirements of Camden Council have been used to establish plant noise limits for the external plant units, not to be exceeded when measured at the nearest noise sensitive properties.

The plant manufacturer's noise emission data was used to predict noise levels from the proposed units at the nearest noise sensitive properties, which were then compared with the proposed plant noise limits.

Noise levels due to the proposed plant were predicted to fall significantly below the proposed noise limits; hence the proposed plant is predicted to comply with the acoustic requirements of Camden Council.

2 INTRODUCTION

A planning application for a new development, comprising a student Hall of Residence and associated amenity areas, is proposed at Bentley House, 200 Euston Road, London. The proposed development will include external building services plant.

The purpose of the assessment is to determine the prevailing background noise levels at a position representative of the nearest noise sensitive properties to the proposed plant, in order to determine external plant noise limits in accordance with Local Authority requirements.

Following this introductory section, a description of the site is given in Section 3. A description of the survey methodology is given in Section 4 with results presented in Section 5 and Appendix B. Plant noise limits are proposed in Section 6 and noise from the proposed plant assessed in Section 7.

Appendix A presents an explanation of the acoustic terminology used in this report.


3 SITE DESCRIPTION

The proposed development site is located at 200 Euston Road in London. The site is currently occupied by Bentley House, a vacant 4-storey storage/archive building. Bentley House is bounded by Euston Road to the South, Stephenson Way to the North and office buildings to the East and West.

Whilst on site it was noted that the surrounding properties mainly consist of offices, as well as a hotel and café on the corner of Euston Road and North Gower Street. University College Hospital is located to the South-West of the site.

Figure 3.1 below shows the existing site and its surroundings.

Figure 3.1 Location of Proposed Development Site and Surrounding Land Use



4 SURVEY METHODOLOGY

An unmanned environmental noise survey was undertaken between approximately 14:00 hours on Friday 16 April 2010 and 14:00 hours on Tuesday 20 April 2010.

A-weighted (dBA) L_{max} , L_{eq} and L_{90} noise levels were measured throughout the environmental noise survey over contiguous 100 millisecond intervals. Octave band noise levels (from 63Hz to 8kHz) were also recorded so as to provide a more detailed description of the noise climate throughout the survey period.

The measurement positions are shown on Figure 4.1 and described in Table 4.1.

Figure 4.1 Site Plan Indicating Approximate Measurement Positions




Table 4.1 Description of Noise Measurement Positions

| Measurement Position | Description |
|----------------------|---|
| A | At the Southern boundary of the proposed development site, protruding by approximately 0.5m from a first floor window of the existing building (200 Euston Road), at a height of approximately 5m above ground level, overlooking Euston Road |
| B | At the Northern boundary of the proposed development site, protruding by approximately 1m from a first floor window of the existing building (200 Euston Road) at a height of approximately 5m above ground level, overlooking Stephenson Way |

Measurement position A was considered representative of typical noise levels at the noisiest façade of the site, in order to allow an assessment of the acoustic requirements of the proposed development façades to be undertaken.

Measurement position B was considered representative of typical noise levels at the quietest area of the site, to be used to determine suitable plant noise emission limits. Position B was also selected so that noise levels incident on the rear of proposed development site, due to road traffic along Stephenson Way, could be assessed.

The equipment used for the noise survey is summarised in Table 4.2.

Table 4.2 Description of Equipment used for Noise Survey

| Measurement Position | Equipment | Description | Quantity | Serial Number |
|----------------------|--------------|--|----------|---------------|
| A | 01 dB Solo | Type 1 automated logging sound level meter | 1 | 60461 |
| | 01 dB PRE 21 | Type 1 ½" microphone and pre-amplifier | 1 | 13429 |
| | 01 dB BAP 21 | Outdoor microphone casing | 1 | 10936 |
| B | 01 dB Solo | Type 1 automated logging sound level meter | 1 | 60447 |
| | 01 dB PRE 21 | Type 1 ½" microphone and pre-amplifier | 1 | 13259 |
| | 01 dB BAP 21 | Outdoor microphone casing | 1 | 10935 |
| All | 01 dB CAL 21 | Calibrator | 1 | 50441990 |

The weather conditions at the start and end of the survey periods were considered appropriate for undertaking environmental noise measurements i.e. there was little or no rainfall, the sky was fairly clear of cloud and there was only light wind. Hilson Moran understands these weather conditions were representative of the full survey period.

The noise monitoring equipment used was calibrated before and after the noise survey periods. No significant change was found.

5 SURVEY RESULTS & OBSERVATIONS

5.1 Results

Appendix B presents time history graphs showing the A-weighted (dBA) L_{max} , L_{eq} and L_{90} noise levels measured throughout the noise survey at each position (note that levels measured at position A have been corrected for nearby surface reflections in accordance with advice from BS8233: 1999¹). We would consider the noise levels measured to be representative of the typical noise climate at the site, considering the location of the measurement positions and the dominant nearby noise sources.

The lowest measured 10-minute background L_{A90} noise levels during weekday/weekend daytime, evening and night-time periods at each position are summarised in Table 5.1 below.

Table 5.1 Lowest Measured Daytime, Evening and Night-time Background L_{90} Noise Levels

| Measurement Position | Lowest Measured L_{90} Background Noise Level (dBA) | | | | | |
|----------------------|---|---------|----------------------------------|---------|-------------------------------------|---------|
| | Daytime/Typical Office Hours (07:00 – 19:00 hours) | | Evening (19:00 – 23:00 hours) | | Night-time (23:00 – 07:00 hours) | |
| | Weekday | Weekend | Weekday | Weekend | Weekday | Weekend |
| A | 66 | 63 | 64 | 63 | 56 | 57 |
| B | 55 | 52 | 52 | 52 | 51 | 51 |

From the measured noise levels, we have derived the logarithmically-averaged daytime, *evening* and night-time free-field ambient noise levels at each measurement position shown in Table 5.2.

Table 5.2 Overall Measured Daytime, Evening and Night-time Ambient Noise Levels

| | Period, T | $L_{Aeq,T}$ (dB) | |
|---|---------------|------------------|------------|
| | | Position A | Position B |
| Daytime Logarithmic Average (12 hour) | 07:00 – 19:00 | 72 | 61 |
| Evening Logarithmic Average (4 hour) | 19:00 – 23:00 | 73 | 58 |
| Night-time logarithmic Average (8 hour) | 23:00 – 07:00 | 72 | 56 |

5.2 Observations

Due to the nature of the survey (unmanned) we are unable to comment on the exact noise climate throughout the entire survey period. However, at the beginning and end of the survey the daytime noise climate at position A was noted to be dominated by noise from traffic movements along Euston Road. Night-time noise levels at position A were assumed to be affected by general ambient background noise (road traffic, etc.)

At position B, the daytime noise climate was noted to be dominated by noise from road traffic and occasional loading activities on Stephenson Way. Noise from traffic movements on Euston Road was clearly audible and noise from building services plant on surrounding buildings was also audible at this position. Night-time noise levels at position B were assumed to be affected by general ambient background noise (road traffic, etc.) as well as noise from building services plant.

6 EXTERNAL PLANT NOISE LIMITS

6.1 Local Authority Guidance

The proposed development site lies within the jurisdiction of London Borough of Camden (Camden Council). We understand Camden Council's typical standards relating to plant noise are as follows²

"The Council will only grant planning permission for plant or machinery, including ventilation or air handling equipment, if it can be operated without causing a loss to local amenity and does not exceed the thresholds..."

Thresholds for noise levels from plant and machinery at which planning permission will not be granted by Camden Council are shown in Table 6.1 below

Table 6.1 Noise Levels from Plant and Machinery at Which Planning Permission will not be Granted

| Noise Description and location of measurement | Period | Time | Noise Level |
|---|------------------------|---------------|-----------------------------|
| Noise at 1 metre external to a sensitive façade | Day, Evening and Night | 00:00 – 24:00 | 5dB(A) less than L_{A90} |
| Noise that has a distinguishable discrete continuous note (whine, hiss, screech, hum) at 1 metre external to a sensitive façade | Day, Evening and Night | 00:00 – 24:00 | 10dB(A) less than L_{A90} |
| Noise that has distinct impulses (bangs, clicks, clatters, thumps) at 1 metre external to a sensitive façade | Day, Evening and Night | 00:00 – 24:00 | 10dB(A) less than L_{A90} |
| Noise at 1 metre external to a sensitive façade where $L_{A90} > 60$ dB | Day, Evening and Night | 00:00 – 24:00 | 55dB L_{Aeq} |

Based on typical Camden Council standards and the lowest measured 10-minute background L_{A90} noise levels during daytime, evening and night-time periods at each position during the environmental noise survey, we would propose the plant noise limits shown in Table 6.2. The plant noise limits are to be achieved during the relevant plant operating period, when measured 1m external to the nearest noise sensitive façade to the site.

Table 6.2 Proposed External Plant Noise Limits – Noise Sensitive Properties

| Measurement Position | External Plant Noise Limit during plant operating period (dBA) | | | | | |
|----------------------|--|---------|----------------------------------|---------|-------------------------------------|---------|
| | Daytime/Typical Office Hours (07:00 – 19:00 hours) | | Evening (19:00 – 23:00 hours) | | Night-time (23:00 – 07:00 hours) | |
| | Weekday | Weekend | Weekday | Weekend | Weekday | Weekend |
| A | 55* | 55* | 55* | 55* | 49 | 52 |
| B | 50 | 47 | 47 | 47 | 46 | 46 |

The above external plant noise limits are subject to approval by Camden Council. In accordance with the requirements of Camden Council, if noise from the proposed plant has a distinguishable discrete continuous note or distinct impulses then the above plant noise limits should be reduced by 5 dBA (except those marked *, where the lowest measured L_{A90} exceeds 60 dB so the plant noise limit remains at 55 dBA).

7 PLANT NOISE ASSESSMENT


7.1 Proposed Plant Locations and Nearest Noise Sensitive Windows

We understand the proposed new items of plant are as follows:

- 1No CHP 120kWh (Plant Location 1)
- 1No. packaged boiler room (Plant Location 2), containing: 1No. supply and extract air handling unit, 2No condensing boilers, 4No pumps and 1No pressurisation set.

The sketch plan in Figure 7.1 indicates the approximate proposed locations of the new plant items on the roof of 200 Euston Road. The approximate locations of the nearest noise-sensitive (residential and hotel) properties are also shown.

Figure 7.1 Approximate Proposed Plant Locations and Nearest Noise Sensitive Properties



The nearest noise-sensitive properties to the proposed plant locations are noted to be the hotels and residential property on Euston Street, the hotel on the junction of Stephenson Way and North Gower Street, and the residential properties on North Gower Street.

7.2 Manufacturer's Plant Noise Data

Details of the proposed plant items are given in the following sections.

7.2.1 CHP Unit

Manufacturer: Ener-G
Model: Ener-G 100 CHP Unit
Approximate Dimensions: 3.7m (L) x 1.0m (W) x 2.5m (H)
Quantity: 1

Note: the CHP is to be housed inside an acoustic enclosure, supplied by Ener-G.

Noise emission data for the CHP Unit, taking account the acoustic enclosure, is given in Table 7.1.

Table 7.1 Sound Pressure Level at 1m from CHP Unit

| Sound Pressure Level (dB) at 1m @ Octave Band Centre Frequency | | | | | | | | dBA @ 1m |
|--|-----|-----|-----|----|----|----|----|----------|
| 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| 87 | 83 | 73 | 63 | 55 | 55 | 53 | 49 | 70 |

7.2.2 Packaged Plant Room

The items of plant proposed within the packaged plant room are described in the following sections.

7.2.2.1 Supply and Extract AHU

Manufacturer: Daikin
Model: VAWL17000AAW1 Heat Recovery AHU
Approximate Dimensions: 2.9m (L) x 1.4m (W) x 2.1m (H)
Quantity: 1

Note: the AHU would be located within the packaged plant room, with ducted supply and extract outlet to fresh air. In-duct fan sound power levels for this AHU are given in Table 7.2.

Table 7.2 In-duct Fan Sound Power Levels for Supply and Extract AHU

| Fan | In-duct Fan Sound Power Level (dB) @ Octave Band Centre Frequency | | | | | | | |
|---------|---|-----|-----|-----|----|----|----|----|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k |
| Supply | 86 | 84 | 81 | 79 | 77 | 74 | 71 | 68 |
| Extract | 93 | 89 | 82 | 77 | 76 | 73 | 70 | 65 |

The air handling unit will include in-duct attenuators on both the supply intake and the extract exhaust ducts, providing the following minimum insertion losses presented in Table 7.3 below.

Table 7.3 In-duct Attenuator Insertion Losses for Supply and Extract AHU

| Fan | Minimum Attenuator Insertion Loss (dB) @ Octave Band Centre Frequency | | | | | | | |
|---------|---|-----|-----|-----|-----|-----|-----|-----|
| | 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k |
| Supply | -4 | -7 | -13 | -19 | -23 | -23 | -16 | -13 |
| Extract | -4 | -7 | -13 | -19 | -23 | -23 | -16 | -13 |

We understand the AHU casing panels will be constructed so as to achieve the casing losses shown in Table 7.4.

Table 7.4 Casing Losses for AHU

| Casing Loss (dB) @ Octave Band Centre Frequency | | | | | | | |
|---|-----|-----|-----|----|----|----|----|
| 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k |
| 18 | 20 | 25 | 34 | 41 | 43 | 46 | 46 |

7.2.2.2 Condensing Boilers

Manufacturer: Viessman Ltd
Model: VitoCrossal 300 314kw Condensing Boilers
Approximate Dimensions 1.8m (L) x 1.0m (D) x 2.0m (H)
Quantity: 2

Noise emission data for each boiler unit is given in Table 7.5

Table 7.5 Sound Pressure Levels at 1m from 1No. Boiler Unit

| Sound Pressure Level (dB) at 1m @ Octave Band Centre Frequency | | | | | | | | dBA @ 1m |
|--|-----|-----|-----|----|----|----|----|----------|
| 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| 58 | 58 | 55 | 52 | 49 | 46 | 43 | 40 | 55 |

7.2.2.3 Pumps

Manufacturer: Wilo
Model: Wilo IL65-210-2.2/4 2.2kW
Approximate Dimensions 0.8m (L) x 0.4m (D) x 0.4m (H)
Quantity: 2 (1No run 1No standby)

Noise emission data for each pump is given in Table 7.6.

Table 7.6 Sound Pressure Levels at 1m from Each Pump

| Sound Pressure Level (dB) at 1m @ Octave Band Centre Frequency | | | | | | | | dBA @ 1m |
|--|-----|-----|-----|----|----|----|----|----------|
| 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| 48 | 51 | 55 | 55 | 51 | 48 | 45 | 40 | 57 |

7.2.2.4 Pumps

Manufacturer: Wilo
Model: Wilo DL125/320 18.5kW
Approximate Dimensions 0.8m (L) x 0.7m (D) 0.7m (H)
Quantity: 2 (1No run 1No standby)

Noise emission data for each pump is given in Table 7.7.

Table 7.7 Sound Pressure Levels at 1m from Each Pump

| Sound Pressure Level (dB) at 1m @ Octave Band Centre Frequency | | | | | | | | dBA @ 1m |
|--|-----|-----|-----|----|----|----|----|----------|
| 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| 58 | 61 | 65 | 65 | 61 | 58 | 55 | 50 | 67 |

7.2.2.5 Pressurisation Set

Manufacturer: Wilo
Model: Wilo Comfort 225 18.5kW
Approximate Dimensions 0.8m (L) x 0.7m (D) 0.7m (H)
Quantity: 1No

Noise emission data for the pressurisation set is given in Table 7.8.

Table 7.8 Sound Pressure Levels at 1m from Pressurisation Set

| Sound Pressure Level (dB) at 1m @ Octave Band Centre Frequency | | | | | | | | dBA @ 1m |
|--|-----|-----|-----|----|----|----|----|----------|
| 63 | 125 | 250 | 500 | 1k | 2k | 4k | 8k | |
| 58 | 61 | 65 | 65 | 61 | 58 | 55 | 50 | 67 |

7.3 Proposed Plant Operating Hours

Hilson Moran understands each item of plant may operate continuously.

7.4 Plant Noise Prediction Calculations

We have undertaken calculations to predict the total noise level due to the proposed plant, at a position 1 metre outside the nearest noise-sensitive windows to the plant, for comparison with the external plant noise limits proposed in Section 6.

Our calculations have considered reflections from the roof. As all of the nearest noise-sensitive windows are facing away from the plant locations and do not have line of sight to the plant locations our calculations have also considered acoustic screening due to intervening buildings. Appendix C presents full details of our calculations. Table 7.9 summarises the predicted noise levels due to each item of plant, as well as the total cumulative level due to all plant items.

Table 7.9 Summary of Plant Noise Prediction Calculations

| Plant | Predicted Noise Level at 1m Outside Nearest Noise Sensitive Property (dBA) | | |
|------------------------------------|--|--|--|
| | 1m From Hotels and Residential Property on Euston Street | 1m From Hotel on junction of Stephenson Way and North Gower Street | 1m From Nearest Residential Property on North Gower Street |
| CHP Unit | 35 | 34 | 33 |
| AHU Supply Louvre | 11 | 10 | 9 |
| AHU Extract Louvre | 14 | 13 | 12 |
| Packaged Plant Room Break-Out | 17 | 16 | 15 |
| Total Predicted Noise Level | 35 | 34 | 33 |
| External Plant Noise Limit | 46 * | | |

** Plant may operate at any time, thus this worst case plant noise limit assumes operation during night-time periods on weekends*


It can therefore be seen that the total predicted plant noise levels 1m outside the nearest noise-sensitive properties should fall significantly below the external plant noise limit, hence the proposed plant items should comply with Camden Council's acoustic requirements.

APPENDIX A: ACOUSTIC TERMINOLOGY


| Parameter | Description |
|----------------------------|---|
| Decibel (dB) | A logarithmic scale representing the sound pressure or power level relative to the threshold of hearing (20×10^{-6} Pascals). |
| Sound Pressure Level (SPL) | The sound pressure level is the sound pressure fluctuation caused by vibrating objects relative to the threshold of hearing. |
| Sound Power Level | The sound power of a noise source relative to the sound power at the threshold of hearing. Sound power is the total amount of sound inherent in a particular sound source, independent of its acoustic environment. |
| A-weighting, L_A (dBA) | The sound level in dB with a filter applied to increase certain frequencies and decrease others to correspond with the average human response to sound. |
| $L_{Aeq,T}$ | The equivalent continuous noise level over the time period T. This is the sound level that is equivalent to the average energy of noise recorded over a given period. |
| $L_{n,T}$ | The noise level exceeded for n% of the time over a given period T. e.g. L_{90} , the noise level exceeded for 90% of the time (background noise level). |
| L_{max} | The maximum noise level measured. |

APPENDIX B: UNMANNED NOISE MONITORING RESULTS

B1. Time History Graph of Noise Levels at Measurement Position A (Facing Euston Road)



B2. Time History Graph of Noise Levels at Measurement Position B (Facing Stephenson Way)



APPENDIX C: FULL ATMOSPHERIC PLANT NOISE CALCULATIONS

C1. CHP Unit Atmospheric Noise Levels

Calculations of Predicted Noise Level at 1m Outside Nearest Window of Hotels and Residential Property on Euston Street:

| CHP Unit | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|-----------|-----------|-----------|-----------|-----------|-----------|----------|----------|-----------|
| Lp at 1m | 87 | 83 | 73 | 63 | 55 | 55 | 53 | 49 | 70 |
| Correction Lp to Lw ¹ | +19 | +19 | +19 | +19 | +19 | +19 | +19 | +19 | |
| Distance attenuation (65m) ¹ | -37 | -37 | -37 | -37 | -37 | -37 | -37 | -37 | |
| Hemi-spherical radiation | -8 | -8 | -8 | -8 | -8 | -8 | -8 | -8 | |
| Screening Loss ² | -7.0 | -8.0 | -10.0 | -12.0 | -15.0 | -18.0 | -21.0 | -23.0 | |
| Resultant Lp at receiver | 54 | 49 | 37 | 25 | 14 | 11 | 6 | 0 | 35 |

Calculations of Predicted Noise Level at 1m Outside Nearest Window of Hotel on Junction of Stephenson Way and North Gower Street:

| CHP Unit | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|-----------|-----------|-----------|-----------|-----------|-----------|----------|----------|-----------|
| Lp at 1m | 87 | 83 | 73 | 63 | 55 | 55 | 53 | 49 | 70 |
| Correction Lp to Lw ¹ | +19 | +19 | +19 | +19 | +19 | +19 | +19 | +19 | |
| Distance attenuation (75m) ¹ | -38 | -38 | -38 | -38 | -38 | -38 | -38 | -38 | |
| Hemi-spherical radiation | -8 | -8 | -8 | -8 | -8 | -8 | -8 | -8 | |
| Screening Loss ² | -7.0 | -8.0 | -10.0 | -12.0 | -15.0 | -18.0 | -21.0 | -23.0 | |
| Resultant Lp at receiver | 53 | 48 | 36 | 24 | 13 | 10 | 5 | 0 | 34 |

Calculations of Predicted Noise Level at 1m Outside Nearest Windows of Residential Properties on North Gower Street:

| CHP Unit | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|-----------|-----------|-----------|-----------|-----------|----------|----------|----------|-----------|
| Lp at 1m | 87 | 83 | 73 | 63 | 55 | 55 | 53 | 49 | 70 |
| Correction Lp to Lw ¹ | +19 | +19 | +19 | +19 | +19 | +19 | +19 | +19 | |
| Distance attenuation (85m) ¹ | -39 | -39 | -39 | -39 | -39 | -39 | -39 | -39 | |
| Hemi-spherical radiation | -8 | -8 | -8 | -8 | -8 | -8 | -8 | -8 | |
| Screening Loss ² | -7.0 | -8.0 | -10.0 | -12.0 | -15.0 | -18.0 | -21.0 | -23.0 | |
| Resultant Lp at receiver | 52 | 47 | 35 | 23 | 12 | 9 | 4 | 0 | 33 |

C2. AHU Atmospheric Noise Levels

Calculations of Predicted Noise Level at 1m Outside Nearest Window of Student Accommodation on Stephenson Way:

| AHU Supply Fan | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|-----------|-----------|-----------|----------|----------|----------|----------|----------|-----------|
| In-duct Lw | 86 | 84 | 81 | 79 | 77 | 74 | 71 | 68 | 82 |
| Attenuator Insertion Loss | -4 | -7 | -13 | -19 | -23 | -23 | -16 | -13 | |
| Grille End Reflection Loss ³ | -4 | -1 | 0 | 0 | 0 | 0 | 0 | 0 | |
| Distance attenuation (65m) ¹ | -38 | -38 | -38 | -38 | -38 | -38 | -38 | -38 | |
| Hemi-spherical radiation | -8 | -8 | -8 | -8 | -8 | -8 | -8 | -8 | |
| Screening Loss ² | -7.0 | -8.0 | -10.0 | -12.0 | -15.0 | -18.0 | -21.0 | -23.0 | |
| Resultant Lp at receiver | 25 | 22 | 12 | 2 | 0 | 0 | 0 | 0 | 11 |

| AHU Extract Fan | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|-----------|-----------|-----------|----------|----------|----------|----------|----------|-----------|
| In-duct Lw | 93 | 89 | 82 | 77 | 76 | 73 | 70 | 65 | 82 |
| Attenuator Insertion Loss | -4 | -7 | -13 | -19 | -23 | -23 | -16 | -13 | |
| Grille End Reflection Loss ³ | -4 | -1 | 0 | 0 | 0 | 0 | 0 | 0 | |
| Distance attenuation (65m) ¹ | -38 | -38 | -38 | -38 | -38 | -38 | -38 | -38 | |
| Hemi-spherical radiation | -8 | -8 | -8 | -8 | -8 | -8 | -8 | -8 | |
| Screening Loss ² | -7.0 | -8.0 | -10.0 | -12.0 | -15.0 | -18.0 | -21.0 | -23.0 | |
| Resultant Lp at receiver | 32 | 27 | 13 | 0 | 0 | 0 | 0 | 0 | 14 |

Calculations of Predicted Noise Level at 1m Outside Nearest Window of Hotels on Euston Street:

| AHU Supply Fan | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|-----------|-----------|-----------|----------|----------|----------|----------|----------|-----------|
| In-duct Lw | 86 | 84 | 81 | 79 | 77 | 74 | 71 | 68 | 82 |
| Attenuator Insertion Loss | -4 | -7 | -13 | -19 | -23 | -23 | -16 | -13 | |
| Grille End Reflection Loss ³ | -4 | -1 | 0 | 0 | 0 | 0 | 0 | 0 | |
| Distance attenuation (75m) ¹ | -39 | -39 | -39 | -39 | -39 | -39 | -39 | -39 | |
| Hemi-spherical radiation | -8 | -8 | -8 | -8 | -8 | -8 | -8 | -8 | |
| Screening Loss ² | -7.0 | -8.0 | -10.0 | -12.0 | -15.0 | -18.0 | -21.0 | -23.0 | |
| Resultant Lp at receiver | 24 | 21 | 11 | 1 | 0 | 0 | 0 | 0 | 10 |

| AHU Extract Fan | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|-----------|-----------|-----------|----------|----------|----------|----------|----------|-----------|
| In-duct Lw | 93 | 89 | 82 | 77 | 76 | 73 | 70 | 65 | 82 |
| Attenuator Insertion Loss | -4 | -7 | -13 | -19 | -23 | -23 | -16 | -13 | |
| Grille End Reflection Loss ³ | -4 | -1 | 0 | 0 | 0 | 0 | 0 | 0 | |
| Distance attenuation (75m) ¹ | -39 | -39 | -39 | -39 | -39 | -39 | -39 | -39 | |
| Hemi-spherical radiation | -8 | -8 | -8 | -8 | -8 | -8 | -8 | -8 | |
| Screening Loss ² | -7.0 | -8.0 | -10.0 | -12.0 | -15.0 | -18.0 | -21.0 | -23.0 | |
| Resultant Lp at receiver | 31 | 26 | 12 | 0 | 0 | 0 | 0 | 0 | 13 |

Calculations of Predicted Noise Level at 1m Outside Nearest Window of Hotel on Junction of Stephenson Way and North Gower Street:

| AHU Supply Fan | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|-----------|-----------|-----------|----------|----------|----------|----------|----------|----------|
| In-duct Lw | 86 | 84 | 81 | 79 | 77 | 74 | 71 | 68 | 82 |
| Attenuator Insertion Loss | -4 | -7 | -13 | -19 | -23 | -23 | -16 | -13 | |
| Grille End Reflection Loss ³ | -4 | -1 | 0 | 0 | 0 | 0 | 0 | 0 | |
| Distance attenuation (85m) ¹ | -40 | -40 | -40 | -40 | -40 | -40 | -40 | -40 | |
| Hemi-spherical radiation | -8 | -8 | -8 | -8 | -8 | -8 | -8 | -8 | |
| Screening Loss ² | -7.0 | -8.0 | -10.0 | -12.0 | -15.0 | -18.0 | -21.0 | -23.0 | |
| Resultant Lp at receiver | 23 | 20 | 10 | 0 | 0 | 0 | 0 | 0 | 9 |

| AHU Extract Fan | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|-----------|-----------|-----------|----------|----------|----------|----------|----------|-----------|
| In-duct Lw | 93 | 89 | 82 | 77 | 76 | 73 | 70 | 65 | 82 |
| Attenuator Insertion Loss | -4 | -7 | -13 | -19 | -23 | -23 | -16 | -13 | |
| Grille End Reflection Loss ³ | -4 | -1 | 0 | 0 | 0 | 0 | 0 | 0 | |
| Distance attenuation (85m) ¹ | -40 | -40 | -40 | -40 | -40 | -40 | -40 | -40 | |
| Hemi-spherical radiation | -8 | -8 | -8 | -8 | -8 | -8 | -8 | -8 | |
| Screening Loss ² | -7.0 | -8.0 | -10.0 | -12.0 | -15.0 | -18.0 | -21.0 | -23.0 | |
| Resultant Lp at receiver | 30 | 25 | 11 | 0 | 0 | 0 | 0 | 0 | 12 |

C3. AHU Packaged Plant Room Atmospheric Noise Levels

The packaged plant room is to be constructed from insulated steel panels, making up the walls, floor and roof. Acoustic louvres (approx 2.0m x 1.0m) shall be incorporated into the North West façade of the plant room construction. These louvres are likely to be the dominant source of noise break-out from the completed plant room. In determining the sound pressure level (Lp) radiated from the packaged plant room, first the total reverberant sound pressure level (Rev Lp) within the plant room must be calculated:

$$\text{Rev Lp} = \text{Lw} + 10 \cdot \log(4/R_c) \quad \text{where } R_c = \text{Room Constant} = (S\alpha)/(1-\alpha)$$

Calculation of Room Constant of Packaged Plant room

| Description | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz |
|--|------|-------|-------|-------|------|------|------|------|
| Mean sound absorption co-efficient of plant room, α | 0.08 | 0.12 | 0.08 | 0.07 | 0.05 | 0.05 | 0.05 | 0.05 |
| Surface Area of Plantroom, m ² | 144 | 144 | 144 | 144 | 144 | 144 | 144 | 144 |
| Room constant, R_c | 12.5 | 19.2 | 12.5 | 10.0 | 6.8 | 6.8 | 6.8 | 6.8 |

Determination of Total Plant Sound Power Level (Lw)

| Description | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|------|-------|-------|-------|------|------|------|------|------|
| AHU Casing Radiated | | | | | | | | | |
| Combined Supply and Extract Fan Lw | 94 | 90 | 85 | 81 | 80 | 77 | 74 | 70 | 85 |
| AHU Casing Loss | -18 | -20 | -25 | -34 | -41 | -43 | -46 | -46 | |
| Radiated Lw | 76 | 70 | 60 | 47 | 39 | 34 | 28 | 24 | 57 |
| 2No VitoCrossal 300 314kw Condensing Boilers | | | | | | | | | |
| Lp at 1m | 58 | 58 | 55 | 52 | 49 | 46 | 43 | 40 | 55 |
| Correction Lp to Lw ¹ | 17 | 17 | 17 | 17 | 17 | 17 | 17 | 17 | |
| 2No. Units | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 3 | |
| Resultant Lw | 78 | 78 | 75 | 72 | 69 | 66 | 63 | 60 | 75 |
| 1No Wilo IL65-210-2.2/4 2.2kW Pump (run/standby) | | | | | | | | | |
| Lp at 1m | 48 | 51 | 55 | 55 | 51 | 48 | 45 | 40 | 56.6 |
| Correction Lp to Lw ¹ | 11 | 11 | 11 | 11 | 11 | 11 | 11 | 11 | |
| Resultant Lw | 59 | 62 | 66 | 66 | 62 | 59 | 56 | 51 | 67.6 |
| 1No Wilo DL125/320 18.5kW Pump (run/standby) | | | | | | | | | |
| Lp at 1m | 58 | 61 | 65 | 65 | 61 | 58 | 55 | 50 | 66.6 |
| Correction Lp to Lw ¹ | 14 | 14 | 14 | 14 | 14 | 14 | 14 | 14 | |
| Resultant Lw | 72 | 75 | 79 | 79 | 75 | 72 | 69 | 64 | 80.6 |
| 1No Wilo Comfort 225 18.5kW Pressurisation Set | | | | | | | | | |
| Lp at 1m | 58 | 61 | 65 | 65 | 61 | 58 | 55 | 50 | 66.6 |
| Correction Lp to Lw ¹ | 14 | 14 | 14 | 14 | 14 | 14 | 14 | 14 | |

| | | | | | | | | | |
|--------------------------|----|----|----|----|----|----|----|----|------|
| Resultant Lw | 72 | 75 | 79 | 79 | 75 | 72 | 69 | 64 | 80.6 |
| Total Resultant Plant Lw | 81 | 81 | 83 | 83 | 79 | 76 | 73 | 68 | 84 |
| Total Plantroom Rev Lp | 76 | 75 | 78 | 79 | 76 | 73 | 70 | 66 | 81 |

Calculation of Radiated Lw from Packaged Plantroom Louvre

| Description | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|--|------|-------|-------|-------|------|------|------|------|-----|
| Total Plantroom Rev Lp | 76 | 75 | 78 | 79 | 76 | 73 | 70 | 66 | 81 |
| Area of Louvre, m ² | 2 | 2 | 2 | 2 | 2 | 2 | 2 | 2 | |
| Acoustic Louvre Insertion Losses (dB) (300mm deep) | -3 | -5 | -7 | -11 | -16 | -20 | -15 | -14 | |
| Radiated Lw of Louvre | 76 | 73 | 74 | 71 | 63 | 56 | 58 | 55 | 71 |

Calculations of Predicted Noise Level at 1m outside nearest window of student accommodation on Stephenson Way:

| | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|------|-------|-------|-------|-------|-------|-------|-------|-----|
| Radiated Lw | 76 | 73 | 74 | 71 | 63 | 56 | 58 | 55 | 71 |
| Distance attenuation (65m) ¹ | -35 | -35 | -35 | -35 | -35 | -35 | -35 | -35 | |
| Hemi-spherical radiation | -8 | -8 | -8 | -8 | -8 | -8 | -8 | -8 | |
| Screening Loss ² | -7.0 | -8.0 | -10.0 | -12.0 | -15.0 | -18.0 | -21.0 | -23.0 | |
| Resultant Lp at receiver | 26 | 22 | 21 | 16 | 5 | 0 | 0 | 0 | 17 |

Calculations of Predicted Noise Level at 1m outside nearest window of Hotels on Euston Street:

| | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|------|-------|-------|-------|-------|-------|-------|-------|-----|
| Radiated Lw | 76 | 73 | 74 | 71 | 63 | 56 | 58 | 55 | 71 |
| Distance attenuation (75m) ¹ | -36 | -36 | -36 | -36 | -36 | -36 | -36 | -36 | |
| Hemi-spherical radiation | -8 | -8 | -8 | -8 | -8 | -8 | -8 | -8 | |
| Screening Loss ² | -7.0 | -8.0 | -10.0 | -12.0 | -15.0 | -18.0 | -21.0 | -23.0 | |
| Resultant Lp at receiver | 25 | 21 | 20 | 15 | 4 | 0 | 0 | 0 | 16 |

Calculations of Predicted Noise Level at 1m outside nearest of Hotel on junction of Stephenson Way and North Gower Street:

| | 63Hz | 125Hz | 250Hz | 500Hz | 1kHz | 2kHz | 4kHz | 8kHz | dBA |
|---|------|-------|-------|-------|-------|-------|-------|-------|-----|
| Radiated Lw | 76 | 73 | 74 | 71 | 63 | 56 | 58 | 55 | 71 |
| Distance attenuation (75m) ¹ | -37 | -37 | -37 | -37 | -37 | -37 | -37 | -37 | |
| Hemi-spherical radiation | -8 | -8 | -8 | -8 | -8 | -8 | -8 | -8 | |
| Screening Loss ² | -7.0 | -8.0 | -10.0 | -12.0 | -15.0 | -18.0 | -21.0 | -23.0 | |
| Resultant Lp at receiver | 24 | 20 | 19 | 14 | 3 | 0 | 0 | 0 | 15 |

Calculation Notes and References:

1. Correction from Sound Pressure Level (L_p) to Sound Power Level (L_w) has been calculated based on BS 3746: 1996 *“Acoustics – Determination of sound power levels of noise sources using sound pressure - Survey Method using an enveloping measurement surface over a reflecting plane”*
2. Correction for screening calculated in accordance with Maekawa Method. Note each receptor screened by edge of 200 Euston Road and intervening buildings.
3. Grille end losses based on CIBSE Guide B5 *‘Noise and Vibration Control for HVAC’*

DOCUMENT CONTROL & REFERENCES

Hilson Moran Partnership Limited, One Discovery Place, Columbus Drive, Southwood West, Farnborough, Hants.GU14 0NZ Copyright © Hilson Moran Partnership Limited 2010. All rights reserved.

Change History

| | | |
|-----------|-------------------|--|
| Issue 0.1 | 29 September 2010 | Document produced by Mark Brightwell and forwarded to Nicholas Jones for review. |
| Issue 0.2 | 29 September 2010 | Document reviewed by Nicholas Jones and returned to Mark Brightwell for issue. |
| Issue 0.3 | 29 September 2010 | Draft document issued to design team for review. |
| Issue 1.0 | 01 October 2010 | Final document issued. |

Changes Forecast

None

Document References

1. BS 8233 British Standard (BS) 8233: 1999 “Sound insulation and noise reduction for buildings – Code of practice”
2. London Borough of Camden Replacement Unitary Development Plan, Adopted June 2006