

REFERENCES

References

- Ref. 01 Greater London Authority, (2010), The London Plan: Spatial Development Strategy for Greater London Consolidated with Alterations since 2004.
- Ref. 02 UK Government, (2010), Approved Document L2A: Conservation of Fuel and Power.
- Ref. 03 UK Government, (2006), Approved Document L2A: Conservation of Fuel and Power.
- Ref. 04 European Union, (2002), COM 2002/91/EC: Directive on the Energy Performance of Buildings.
- Ref. 05 UK Government, (2004), Housing Act.
- Ref. 06 UK Government, (2003), Energy White Paper: Our Energy Future, Creating a Low Carbon Economy.
- Ref. 07 Office of the Deputy Prime Minister, (2004), Planning Policy Statement 22: Renewable Energy.
- Ref. 08 UK Government, (2004), Sustainable and Secure Buildings Act.
- Ref. 09 Office of the Deputy Prime Minister, (2005), Planning Policy Statement 1: Delivering Sustainable Development.
- Ref. 10 UK Government, (2006), Climate Change and Sustainable Energy Act.
- Ref. 11 Department for Communities and Local Government (2006), Building a Greener Future: Towards Zero Carbon Development - Consultation.
- Ref. 12 The Department of Trade and Industry, (2007), White Paper: Meeting the Energy Challenge.
- Ref. 13 Department for Communities and Local Government, (2007), Planning Policy Statement: Planning and Climate Change – Supplement to PPS1.
- Ref. 14 UK Government, (2008), Climate Change Act.
- Ref. 15 UK Government, (2008), Energy Act.
- Ref. 16 UK Government, (2008) Planning and Energy Act.
- Ref. 17 Greater London Authority, (2009), The London Plan: Spatial Development Strategy For Greater London, Consultation Draft Replacement Plan.
- Ref. 18 Greater London Authority, (2004), Green Light to Clean Power: the Mayor's Energy Strategy.
- Ref. 19 London Energy Partnership, (2005), Integrating Renewables into New Developments: Toolkit for Planners, Developers and Consultants.
- Ref. 20 Greater London Authority, (2009), GLA Energy Team Guidance on Planning Energy Assessments, Version 1.
- Ref. 21 Greater London Authority, (2010), The Draft Climate Change Adaptation Strategy for London, Public Consultation Draft.
- Ref. 22 Greater London Authority, (2010), Delivering London's Energy Future: the Mayor's Draft Climate Change Mitigation and Energy Strategy for Consultation with the London Assembly and Functional Bodies.
- Ref. 23 London Borough of Camden, (2006), Replacement Unitary Development Plan.
- Ref. 24 London Borough of Camden, (2006), Camden Planning Guidance.
- Ref. 25 UK Government, (2004), Planning and Compulsory Purchase Act.
- Ref. 26 Department for Communities and Local Government, (2008), National Calculation Methodology (NCM) Modelling Guide (For Buildings other than Dwellings in England and Wales).
- Ref. 27 Greater London Authority, (2006), Supplementary Planning Guidance on Sustainable Design and Construction.
- Ref. 28 Health and Safety Executive's, (2003), Approved Code of Practice and Guidance L8 – Legionnaires' Disease: The Control of Legionella Bacteria in Water Systems.

GLOSSARY

Glossary

ADL2A	Building Regulations Approved Document L2A	UKCMRI	UK Centre for Medical Research and Innovation
BER	Building CO ₂ Emission Rate	UPS	Uninterruptible Power Supply
BMS	Building Management System	VE	Virtual Environment
BREEAM	Building Research Establishment Environmental Assessment Methodology	VSD	Variable Speed Drive
BRF	Biological Research Facility		
BRUKL	Building Regulations United Kingdom Part L		
CCHP	Combined Cooling Heat and Power		
CHP	Combined Heat and Power		
CHPQI	Combined Heat and Power Quality Index		
CHPQA	Combined Heat and Power Quality Assurance		
CIBSE	Chartered Institution of Building Services Engineers		
CL	Containment Level		
CRAC	Computer Room Air Conditioning		
DHW	Domestic Hot Water		
ECA	Enhanced Capital Allowance		
EDFE	EDF Energy		
EPC	Energy Performance Certificate		
ETPL	Energy Technology Product List		
EU	European Union		
GLA	Greater London Authority		
IES	Integrated Environmental Solutions		
IT	Information Technology		
LBC	London Borough of Camden		
LDA	London Development Agency		
LED	Light-Emitting Diode		
LHTW	Low Temperature Hot Water		
LZC	Low and Zero Carbon		
M&E	Mechanical and Electrical		
MRC	Medical Research Council		
NCM	National Calculation Methodology		
NMR	Nuclear Magnetic Regulator		
PPS	Planning Policy Statement		
PV	Photovoltaic		
RO	Reverse Osmosis		
RUDP	Replacement Unitary Development Plan		
SPG	Supplementary Planning Guidance		
TER	Target CO ₂ Emission Rate		
TRY	Test Reference Year		
UCL	University College London		

APPENDICES

Appendix

APPENDIX A

IES Input


Appendix

Glazed construction data

The glazed areas of the building have been modelled based on SunGard Super Neutral SN62 glass which has been used on all areas of the building.

The SN62 glass consists of a double glazed unit with a Net U Value (including frame) of 1.6W/m2K and a G value (BS EN 410) of 0.34. Due to the high proportion of glass in the building it is extremely important that these values are taken as a minimum and are inclusive of the frame and that any fins that may form part of the frame do not detract from these values.

Although the majority of the double glazed unit is clear glass, a certain percentage of fritting has been applied to the inner pane of the glass along external corridors to the lab areas on levels 2 to 5 in the location shown below.



This has been modelled as 5 strips each 1m high consisting of the following percentage of clear and fritted glass.


Glass type SN62 – 75% fritting
Glass type SN62 – 50% fritting
Glass type SN62 – 25% fritting
Glass type SN62 – 0% fritting
Glass type SN62 – 50% fritting

The following Net U Value (including frame) and the G value (BS EN 410) have been taken for the fritted glass, based on correspondence between HOK & SunGard.


SN62 GLASS % OF FRITTING	NET U VALUE (INCLUDING FRAME)	G VALUE (BS EN 410)
0% (CLEAR GLASS)	1.6W/M2K	0.34
25%	1.6W/M2K	0.33
50%	1.6W/M2K	0.31
75%	1.6W/M2K	0.29

200mm deep external horizontal fins at 1m centres have been included in front of the glass on the external corridors. We understand this will be further refined during detail design.

The glazing on NW, SW, NE and SE end facades on levels 2-5 has recessed 150mm into the terracotta wall in the location shown below.



The roof lights have also been modelled in the location shown below which are based on SunGard Super Neutral SN62 glass. The SN62 glass consists of a double glazed unit with a Net U Value (including frame) of 2.2W/m2K and a G value (BS EN 410) of 0.34.



Appendix

Thermal Templates

The following building templates have been defined and assigned to the various rooms in the model. An NCM activity and a system characteristics including renewable have been defined for each of the different thermal templates.

Thermal Template	NCM Activity	System Characteristics
Atrium	NCM Indus: Circulation Area	General CV system - Atrium, Writeup, Tertiary Area
Atrium High level	NCM Indus: Circulation Area	General CV system - Atrium, Writeup, Tertiary Area
Circulation Area	NCM Indus: Circulation Area	General CV system - Atrium, Writeup, Tertiary Area
Auditorium	NCM Court: Lecture Theatre/Assembly area	Lecture Theatre - CV System
Restaurant /Seating Area	NCM Indus: Eating/Drinking Area	General FCU system - Offices, Meeting Rooms, Restaurant, SER
BRF	NCM Indus: Laboratory	BRF CV system
BRF Tertiary	NCM Laund: Laundry	BRF Tertiary CV system
CL3	NCM Indus: Laboratory	CL3 CV System
CL3+	NCM Indus: Laboratory	CL3+ CV System
Data Centre	NCM Misc24Hr: Data Centre	Data Centre - FCU system
Imaging	NCM Indus: Laboratory	Imaging CV System
Kitchen	NCM Indus: Food Preparation Area	Kitchen CV system
Loading Bay	NCM Indus: Warehouse storage	Loading Bay Mech System
Meeting Room	NCM Indus: Meeting Room	General FCU system - Offices, Meeting Rooms, Restaurant, SER
Office	NCM Indus: Open plan office	General FCU system - Offices, Meeting Rooms, Restaurant, SER
Plantroom Untreated Space	NCM Unheated Space	None
Plantroom Mech Vent	NCM Indus: Plantroom	Plantroom Mech System
Primary Labs	NCM Indus: Laboratory	Primary/Secondary Lab-single duct VAV
Primary Write-up	NCM Indus: Open plan office	General FCU system - Offices, Meeting Rooms, Restaurant, SER

Secondary Labs	NCM Indus: Laboratory	Primary/Secondary Lab-single duct VAV
Tertiary area	NCM Indus: Laboratory	General CV system - Atrium, Writeup, Tertiary Area
SER	NCM Misc24Hr:IT	General FCU system - Offices, Meeting Rooms, Restaurant, SER
Riser	NCM Unheated Space	None
Toilets	NCM Indus: Toilet	None
Workshop	NCM Indus: Workshop-small scale	General CV system - Atrium, Writeup, Tertiary Area

Appendix

System Characteristics

The following Systems characteristics have been set up and assigned to the building templates. The main system inputs have been defined for each system

General CV System: Atrium, Write-up, Tertiary areas

UK NCM System Type: Constant volume system (variable fresh air rate)

Heating System : LTHW Boiler, CHP, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 6.8, Generator Nominal EER – 7.2, SSEER: 5.5

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power 2.5W//s

Ventilation: Heat Recovery- Run around coil, Ratio 0.5.

Renewables: CHP & PV

BRF CV System

UK NCM System Type: Constant volume system (variable fresh air rate)

Heating System : LTHW Boiler, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 6.8, Generator Nominal EER – 7.2, SSEER: 5.5

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power-2.5W//s

Ventilation: Heat Recovery- Run around coil, Ratio 0.5.

Renewables: CHP & PV

BRF Tertiary CV System

UK NCM System Type: Constant volume system (variable fresh air rate)

Heating System: LTHW Boiler, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 6.8, Generator Nominal EER – 7.2, SSEER: 5.5

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power -2.5W//s

Ventilation: Heat Recovery- Run around coil, Ratio 0.5.

Renewables: CHP & PV

CL3 CV System

UK NCM System Type: Constant volume system (variable fresh air rate)

Heating System: LTHW Boiler, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 6.8, Generator Nominal EER – 7.2, SSEER: 5.5

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power 2.5W//s

Ventilation: Heat Recovery- Run around coil, Ratio 0.5

Renewables: CHP & PV

CL3+ CV System

UK NCM System Type: Constant volume system (variable fresh air rate)

Heating System: LTHW Boiler, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 6.8, Generator Nominal EER – 7.2, SSEER: 5.5

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power 2.5W//s

Ventilation: Heat Recovery- Run around coil, Ratio 0.5.

Renewables: CHP & PV

Data Centre - FCU system

UK NCM System Type: Fan coil systems

Heating System: LTHW Boiler, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 20, Generator Nominal EER – 20, SSEER: 20.7

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power- 2W//s

Ventilation: No Heat Recovery

Renewables: CHP & PV

General FCU system - Offices, Meeting Rooms, Restaurant, SER

UK NCM System Type: Fan coil systems

Heating System: LTHW Boiler, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 6.8, Generator Nominal EER – 7.2, SSEER: 5.5

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power - 2W//s

Ventilation: No Heat Recovery

Renewables: CHP & PV

Imaging CV system

UK NCM System Type: Constant volume system (variable fresh air rate)

Heating System : LTHW Boiler, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 6.8, Generator Nominal EER – 7.2, SSEER: 5.5

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power 2.5W//s

Ventilation: Heat Recovery- Run around coil, Ratio 0.5.

Renewables: CHP & PV

Appendix

Kitchen CV system

UK NCM System Type: Constant volume system (variable fresh air rate)

Heating System: LTHW Boiler, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 6.8, Generator Nominal EER – 7.2, SSEER: 5.5

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power 2W/l/s

Ventilation: No Heat Recovery

Renewables: CHP & PV

Lecture theatre CV system

UK NCM System Type: Constant volume system (variable fresh air rate)

Heating System: LTHW Boiler, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 6.8, Generator Nominal EER – 7.2, SSEER: 5.5

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power 2.5W/l/s

Ventilation: Heat Recovery- Run around coil, Ratio 0.5.

Renewables: CHP & PV

Primary/Secondary Lab Single Duct VAV

UK NCM System Type: Single-duct VAV

Heating System: LTHW Boiler, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 6.8, Generator Nominal EER – 7.2, SSEER: 5.5

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power 2.3W/l/s

Ventilation: Heat Recovery- Run around coil, Ratio 0.5.

Renewables: CHP & PV

Loading Bay Mech System

UK NCM System Type: Single-duct VAV

Heating System: LTHW Boiler, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 6.8, Generator Nominal EER – 7.2, SSEER: 5.5

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power 2W/l/s

Ventilation: No Heat Recovery

Renewables: CHP & PV

Plantroom Mech System

Heating System : LTHW Boiler, Generator Fuel – Nat Gas, Generator Seasonal Efficiency – 0.85, SCOP – 0.8KW/KW.

Cooling System: Air Cooled Chiller, Chiller Fuel- Electricity, Generator Seasonal EER – 6.8, Generator Nominal EER – 7.2, SSEER: 5.5

Ductwork & AHU system: Duct CEN Leakage- Class B, AHU CEN leakage – Class L1, Specific Fan Power 2W/l/s

Ventilation: No Heat Recovery

Renewables: CHP & PV

APPENDIX B
IES BRUKL Output

BRUKL Output Document



Compliance with England and Wales Building Regulations Part L

Project name

UKCMRI

Baseline Scheme

As designed

Date: Thu Jul 29 16:41:21 2010

Administrative information

Building Details

Address: London, NW1

Owner Details

Name: Owner

Telephone number: Phone

Address: , Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 6.0.6

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 6.0.6

BRUKL compliance check version: v3.5.a.0

Certifier details

Name: URS

Telephone number: Phone

Address: Street Address, City, Postcode

Criterion 1: Predicted CO2 emission from proposed building does not exceed the target

1.1	Calculated CO2 emission rate from notional building	54.2 KgCO2/m2.annum
1.2	Improvement factor	0.2
1.3	LZC benchmark	0.1
1.4	Target CO2 Emission Rate (TER)	39.1 KgCO2/m2.annum
1.5	Building CO2 Emission Rate (BER)	38.9 KgCO2/m2.annum
1.6	Are emissions from building less than or equal to the target?	BER =< TER
1.7	Are as built details the same as used in BER calculations?	Separate submission

Criterion 2: The performance of the building fabric and the building services systems should be no worse than the design limits

2.1 Are the U-values better than the design limits? **Better than design limits**

Element	U _a -Limit	U _a -Calc	U _i -Limit	U _i -Calc	Surface where this maximum value occurs*
Wall**	0.35	0.22	0.7	0.59	B2ML0006:Surf[4]
Floor	0.25	0.2	0.7	0.25	B2ML0009:Surf[0]
Roof	0.25	0.25	0.35	0.25	B1CR0004:Surf[0]
Windows***, roof windows, and rooflights	2.2	2	3.3	2.1	L0CR0026:Surf[3]
Personnel doors	2.2	0	3	0	No Personnel doors in building
Vehicle access & similar large doors	1.5	0	4	0	No Vehicle access doors in building
High usage entrance doors	6	0	6	0	No High usage entrance doors in building

U_a-Limit = Limiting area-weighted average U-values [W/(m2K)]

U_i-Limit = Limiting individual element U-values [W/(m2K)]

U_a-Calc = Calculated area-weighted average U-values [W/(m2K)]

U_i-Calc = Calculated individual element U-values [W/(m2K)]

* There might be more than one surface exceeding the limiting standards.

** Automatic U-value check by the tool does not apply to curtain walls whose limiting standards are similar to those for windows.

*** Display windows and similar glazing are not required to meet the standard given in this table.

2.2 Is air permeability no greater than the worst acceptable standard? **No greater than worst acceptable standard**

Air Permeability	Worst acceptable standard	This building (Design value)
m3/(h.m2) at 50 Pa	10	10

2.3 Are all building services standards acceptable?

2.3a-1 BRF CV system

HVAC system standard is acceptable

Efficiency check	Limiting heat source seasonal efficiency	This building
Heat source efficiency	0.84	0.84
0.84 is the overall limiting efficiency for a single or a multiple boiler system. For a multiple boiler system the limiting efficiency for any individual boiler is 0.80.		
Efficiency check	Limiting Cooling Nominal efficiency	This building
Cooling efficiency	2.25	4.4
Efficiency check	Limiting Specific Fan Power	This building
SFP	2.5	2.5

2.3a-2 CL3+ CV System

HVAC system standard is acceptable

Efficiency check	Limiting heat source seasonal efficiency	This building
Heat source efficiency	0.84	0.84
0.84 is the overall limiting efficiency for a single or a multiple boiler system. For a multiple boiler system the limiting efficiency for any individual boiler is 0.80.		
Efficiency check	Limiting Cooling Nominal efficiency	This building
Cooling efficiency	2.25	4.4
Efficiency check	Limiting Specific Fan Power	This building
SFP	2.5	2.5

2.3a-3 General CV system - Atrium, Writeup, Tertiary Area

HVAC system standard is acceptable

Efficiency check	Limiting heat source seasonal efficiency	This building
Heat source efficiency	0.84	0.84
0.84 is the overall limiting efficiency for a single or a multiple boiler system. For a multiple boiler system the limiting efficiency for any individual boiler is 0.80.		
Efficiency check	Limiting Cooling Nominal efficiency	This building
Cooling efficiency	2.25	4.4
Efficiency check	Limiting Specific Fan Power	This building
SFP	2.5	2.5

2.3a-4 Plantroom Mech System

HVAC system standard is acceptable

Efficiency check	Limiting heat source seasonal efficiency	This building
Heat source efficiency	0.84	0.84
0.84 is the overall limiting efficiency for a single or a multiple boiler system. For a multiple boiler system the limiting efficiency for any individual boiler is 0.80.		
Efficiency check	Limiting Cooling Nominal efficiency	This building
Cooling efficiency	2.25	4.4
Efficiency check	Limiting Specific Fan Power	This building
SFP	2	2

2.3a-5 Primary/Secondary Lab- single duct VAV

HVAC system standard is acceptable

Efficiency check	Limiting heat source seasonal efficiency	This building
Heat source efficiency	0.84	0.84
0.84 is the overall limiting efficiency for a single or a multiple boiler system. For a multiple boiler system the limiting efficiency for any individual boiler is 0.80.		
Efficiency check	Limiting Cooling Nominal efficiency	This building
Cooling efficiency	2.25	4.4
Efficiency check	Limiting Specific Fan Power	This building
SFP	2.5	2.3

2.3a-6 BRF Tertiary CV system

HVAC system standard is acceptable

Efficiency check	Limiting heat source seasonal efficiency	This building
Heat source efficiency	0.84	0.84
0.84 is the overall limiting efficiency for a single or a multiple boiler system. For a multiple boiler system the limiting efficiency for any individual boiler is 0.80.		
Efficiency check	Limiting Cooling Nominal efficiency	This building
Cooling efficiency	2.25	4.4
Efficiency check	Limiting Specific Fan Power	This building
SFP	2.5	2.5

2.3a-7 General FCU system - Offices, Meeting Rooms, Restaurant, SER

HVAC system standard is acceptable

Efficiency check	Limiting heat source seasonal efficiency	This building
Heat source efficiency	0.84	0.84
0.84 is the overall limiting efficiency for a single or a multiple boiler system. For a multiple boiler system the limiting efficiency for any individual boiler is 0.80.		
Efficiency check	Limiting Cooling Nominal efficiency	This building
Cooling efficiency	2.25	4.4
Efficiency check	Limiting Specific Fan Power	This building
SFP	2	2

2.3a-8 Imaging CV System

HVAC system standard is acceptable

Efficiency check	Limiting heat source seasonal efficiency	This building
Heat source efficiency	0.84	0.84
0.84 is the overall limiting efficiency for a single or a multiple boiler system. For a multiple boiler system the limiting efficiency for any individual boiler is 0.80.		
Efficiency check	Limiting Cooling Nominal efficiency	This building
Cooling efficiency	2.25	4.4
Efficiency check	Limiting Specific Fan Power	This building
SFP	2.5	2.5

2.3a-9 Lecture Theatre - CV System

HVAC system standard is acceptable

Efficiency check	Limiting heat source seasonal efficiency	This building
Heat source efficiency	0.84	0.84
0.84 is the overall limiting efficiency for a single or a multiple boiler system. For a multiple boiler system the limiting efficiency for any individual boiler is 0.80.		
Efficiency check	Limiting Cooling Nominal efficiency	This building
Cooling efficiency	2.25	4.4
Efficiency check	Limiting Specific Fan Power	This building
SFP	2.5	2.5

2.3a-10 Kitchen CV system

HVAC system standard is acceptable

Efficiency check	Limiting heat source seasonal efficiency	This building
Heat source efficiency	0.84	0.84
0.84 is the overall limiting efficiency for a single or a multiple boiler system. For a multiple boiler system the limiting efficiency for any individual boiler is 0.80.		
Efficiency check	Limiting Cooling Nominal efficiency	This building
Cooling efficiency	2.25	4.4
Efficiency check	Limiting Specific Fan Power	This building
SFP	2	2

2.3a-11 Loading Bay Mech System

HVAC system standard is acceptable

Efficiency check	Limiting heat source seasonal efficiency	This building
Heat source efficiency	0.84	0.84
0.84 is the overall limiting efficiency for a single or a multiple boiler system. For a multiple boiler system the limiting efficiency for any individual boiler is 0.80.		
Efficiency check	Limiting Cooling Nominal efficiency	This building
Cooling efficiency	2.25	4.4
Efficiency check	Limiting Specific Fan Power	This building
SFP	2	2

2.3a-12 CL3 CV System

HVAC system standard is acceptable

Efficiency check	Limiting heat source seasonal efficiency	This building
Heat source efficiency	0.84	0.84
0.84 is the overall limiting efficiency for a single or a multiple boiler system. For a multiple boiler system the limiting efficiency for any individual boiler is 0.80.		
Efficiency check	Limiting Cooling Nominal efficiency	This building
Cooling efficiency	2.25	4.4
Efficiency check	Limiting Specific Fan Power	This building
SFP	2.5	2.5