



NEW KITCHEN RISER FROM BELOW (1200x600)

NEW KITCHEN RISER TO ROOF (1200x600)

SYSTEM 2 (YORK SUITE) & SYSTEM 5 (DORRY SUITE) VRY CONDENSERS (REPLACEMENT OF 5 EXISTING UNITS)

EXISTING KITCHEN EXTRACT FAN REF. E1 REPLACED. WT=500kg. FAN LOCATED IN EXISTING BRICK ENCLOSURE. 1410Lx1450Wx1855H. 480kg.

NOTE: ROOF ACCESS ROUTE ALONG THIS ROOF BLOCKED BY NEW DUCTWORK. ACCESS VIA OPPOSITE ROOF.

28mm LPHW T/B.

AHU 2 GROUND FLOOR MEETING ROOM AND GYM. (LOCATED ON TANK BASE) 4400Lx2000Wx1300H

400x600 SUPPLY & EXTRACT DUCTS FROM GROUND FLOOR MEETING ROOMS & BASKETBALL GYM/B.O.H. RISE UP EXTERNALLY AFTER SETTING OVER AT L/L ROOF.

133mm BOOSTED CWS RISE FROM BELOW TO CONNECT TO EXISTING CWS DROPPERS. (SEE M14 & 15)

EXISTING PLANT HOUSINGS DEMOLISHED

HIGH VELOCITY DISCHARGE

S31 (DISCHARGE)

5 EXISTING VRY UNITS TO REMAIN

250x450 SUPPLY & EXTRACT DUCT RISERS EXTERNAL TO BUILDING TO H/L ROOF.

AHU 8 BAR AND LOUNGE WT=800kg 3600Lx1450Wx710H.

AHU 3 RESTAURANT & LOBBY WT=1702kg 4175Lx2000Wx1200H.

700x300 DUCTS RISE EXTERNALLY TO ROOF

EXISTING PLANT HOUSINGS DEMOLISHED

NEW DX CONDENSERS FOR AHU 3 & 8.

REV. B BY: TH CFI: 00 DATE: 28.07.10

Drawing scale amended to 1:50@A0

REV. A BY: ALP CFI: 00 DATE: 30.04.10

TRIPLEX AND GENERAL SPECIFICATION NOTES ADDED. REFER ALSO TO DRAWINGS M0204 & 304



MORRISON DESIGN
CHARTERED ARCHITECTS

St Alkmunds House, 103 Belper Road, Derby DE1 3ES
T: 01332 363355 F: 01332 291441 E: architect@morrisondesign.co.uk

Job Title
PARK INN HOTEL
92 Southampton Row
London WC1B 4BH

Drawing Title
High Level Roofs
As proposed indicating new plant

File Ref:
Project Ref:

Scale: 1:50@A0 Drawn: CFI Date: April 10

Job No.	Drawing No.	Revision
3829	212	B

CONSTRUCTION