

From: Giusti, Celeste [mailto:Celeste.Giusti@camden.gov.uk]
Sent: 05 August 2010 10:42
To: Malcolm, Adrian
Cc: Emma Rodley
Subject: FW: NEQ - Water Supply Infrastructure

hi Adrian

This information is fine to discharge the condition, although it would be helpful to have a drawing showing where the storage and boosted supplies will be located.

I understand Thames Water requested the condition. Thames Water has carried out a flow and pressure feasibility investigation which concluded that there is adequate capacity in the existing infrastructure to provide the required water supplies to the NEQ development. Therefore no new infrastructure is required to service the development.

It should be noted that this investigation was based on the development including storage and boosted supplies. The plans should identify space for the storage tanks/pipes and plant.

Celeste Giusti
Senior Planning Officer

Telephone: 020 7974 2085