

001-231755-LTR-000011.doc

Ms Victoria Fowles
Development Control Planning Services
London Borough of Camden
Town Hall
Argyle Street
London WC1H 8ND

3 Colegate
Norwich
Norfolk
NR3 1BN
T. +44(0)1603 674444
F. +44(0)1603 674445
www.pmt.co.uk

10 August 2009

Dear Victoria

**North West Development - Electrical Sub-Station Project -
Sample Brickwork Panel, Planning Condition**

Thank you for attending the morning site visit held on Monday 10 August 2009. I confirm that the following points were discussed and approved to satisfy Condition 2 of the Planning Approval. This required a sample panel of all facing brickwork to demonstrate the brick type, bond, pointing and mortar prior to construction:

- The brickwork type is to be Terca / Baggeridge - Smeed Dean London Stock.
- The pointing is to have a weather struck joint which is to have a very small shadow at the top and no shadow at the bottom. This is to be achieved using a vertical trowel and keeping the pointing tight to the top edge.
- The mortar colour was considered satisfactory to meet planning requirements.

Yours sincerely

Joanne Hatwell
for Purcell Miller Tritton LLP

Principals
Andrew Clark
Brian Anderson
Chris Betts
Christopher Cotton
David Bissonnet
David Pendery
Ian Alderton
James Coath
James Montgomery
James Sanderson
Jane Kennedy
Jeremy Blake
John Burton
Mark Goldspink
Mark Hammond
Martin Stancilffe
Michael Morrison
Nigel Sunter
Richard Ellis
Richard Putnam

Associates
Alasdair Travers
Beulah Dutton
Dante Vanoli
David Sherriff
Denis Butler
Gary Dalton
Gary Sparrow
Jane Roylance
Joanne Merry
John Rutherford
Jonathan Gotelee
Kate Bultitude
Kelley Christ
Kenny Brown
Martin Dunseath
Nigel Young
Paul Prentice
Peter Gooderham
Richard George
Robert Chambers
Ruth Brennan
Simon Marks
Stephen Elliott
Suzi Armstrong