


7 Sound data

7 - 1 Sound pressure spectrum

7

RXYSQ6PV - Cooling

4D052716B



NOTES

- 1 Over all (dB):

Scale A	53.0
Scale C	64.5

(B.G.N. is already rectified)

- 2 Measuring place: Anechoic chamber

- 3 Operating conditions:

- Power source: 220-240V 50Hz, 220V 60Hz
- Cooling: Return air temperature: 27°C DB, 19.0°C WB; Outdoor temperature: 35°C DB, 24°C WB


- 4 Location of microphone



- 5 The operating sound is measured in anechoic chamber, if it is measured under the actual installation conditions, it is normally over the set value due to environmental noise and sound reflection.

RXYSQ6PV - Heating

4D052717B



NOTES

- 1 Over all (dB):

Scale A	55.0
Scale C	67.0

(B.G.N. is already rectified)

- 2 Measuring place: Anechoic chamber

- 3 Operating conditions:

- Power source: 220-240V 50Hz, 220V 60Hz
- Heating: Return air temperature: 20°C DB; Outdoor temperature: 7°C DB, 6°C WB

- 4 Location of microphone



- 5 The operating sound is measured in anechoic chamber, if it is measured under the actual installation conditions, it is normally over the set value due to environmental noise and sound reflection.