

Mr Richard Howard
The Interiors Group
Park House
Windmill Business Park
Sunbury- On-Thames
TW16 7DY

Application Ref: **2010/1888/P**
Please ask for: **Hannah Parker**
Telephone: 020 7974 **6805**

15 June 2010

Dear Sir/Madam

DECISION

Town and Country Planning Acts 1990 (as amended)
Town and Country Planning (General Development Procedure) Order 1995
Town and Country Planning (Applications) Regulations 1988

Full Planning Permission Granted

Address:
101 Bayham Street
London
NW1 0AG

Proposal:
Extension to existing plant area at roof level of office building (Class B1a) to accommodate a new air conditioning condenser plant.

Drawing Nos: Site location plan; Conabeare Acoustics ref:CS 6780 17th March 2010; Q10025.M.01revA; 3136 01; Proposed mechanical with plant visuals.

The Council has considered your application and decided to grant permission subject to the following conditions:

Conditions and Reasons:

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).



- 2 The development hereby permitted shall be carried out in accordance with the following approved plans Site location plan; Conabeare Acoustics ref:CS 6780 17th March 2010; Q10025.M.01revA; 3136 01; Proposed mechanical with plant visuals.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment are in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies SD6, SD7B, SD8 and Appendix 1 of the London Borough of Camden Replacement Unitary Development Plan 2006.

- 4 Automatic time clocks shall be fitted to the plant hereby approved, prior to commencement of the use of the units, to ensure that the plant does not operate between 19 00 hrs and 07 00hrs. The timer equipment shall be properly maintained and retained permanently thereafter.

Reason:- To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies SD6, SD7B, SD8, Appendix 1 of the London Borough of Camden Replacement Unitary Development Plan 2006.

Informatives:

- 1 Reasons for granting permission.

The proposed development is in general accordance with the policy requirements of the London Borough of Camden Replacement Unitary Development Plan 2006, with particular regard to policies B1- General Design, B7- Conservation area, SD6 - Amenity for occupiers and neighbours, SD7 - Noise and vibration pollution, Appendix A - Noise and vibration thresholds. For a more detailed understanding of the reasons for the granting of this planning permission, please refer to the officers report.

- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Planning and Public Protection Division (Compliance and Enforcement Team), Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 5613 or by email ppp@camden.gov.uk or on the

website www.camden.gov.uk/pollution) or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

- 3 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 2363).

Disclaimer

This is an internet copy for information purposes. If you require a copy of the signed original please contact the Culture and Environment Department on (020) 7974 5613