

This design submission has been carried out by an Authorised SAP Assessor. It has been prepared from plans and specifications and may not reflect the property as constructed.

Assessor name	MRS JOANNE CHURCHILL	Assessor number	1591
Client		Last modified	27/04/2010
Address	Unit 3 Makepeace Mansions Unit 3(LB), Holly Lodge Estate, Camden, Greater London, NW1		

### 1. Overall dwelling dimensions

	Area (m <sup>2</sup> )		Average storey height		Volume (m <sup>3</sup> )
Lowest occupied	<input type="text" value="42.24"/> (1a)	x	<input type="text" value="2.63"/>	=	<input type="text" value="111.09"/> (1)
Total floor area	(1a) + (2a) + (3a) + (4a) = <input type="text" value="42.24"/> (5)				
Dwelling volume	(1) + (2) + (3) + (4) = <input type="text" value="111.09"/> (6)				

### 2. Ventilation rate

			m <sup>3</sup> per hour		
Number of chimneys	<input type="text" value="0"/>	x 40 =	<input type="text" value="0"/>	(7)	
Number of open flues	<input type="text" value="0"/>	x 20 =	<input type="text" value="0"/>	(8)	
Number of intermittent fans or passive vents	<input type="text" value="0"/>	x 10 =	<input type="text" value="0"/>	(9)	
Number of flueless gas fires	<input type="text" value="0"/>	x 40 =	<input type="text" value="0"/>	(9a)	
					Air changes per hour
Infiltration due to chimneys, flues and fans	(7) + (8) + (9) + (9a) =	<input type="text" value="0"/>	÷ (6) =	<input type="text" value="0.00"/>	(10)
If a pressurisation test has been carried out, proceed to box (19)					
Number of storeys in the dwelling		<input type="text" value="N/A"/>	(11)		
Additional infiltration			[(11) - 1] x 0.1 =	<input type="text" value="N/A"/>	(12)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction				<input type="text" value="N/A"/>	(13)
If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0				<input type="text" value="N/A"/>	(14)
If no draught lobby, enter 0.05, else enter 0				<input type="text" value="N/A"/>	(15)
Percentage of windows and doors draught stripped		<input type="text" value="N/A"/>	(16)		
Window infiltration			0.25 - [0.2 x (16) ÷ 100] =	<input type="text" value="N/A"/>	(17)
Infiltration rate			(10) + (12) + (13) + (14) + (15) + (17) =	<input type="text" value="N/A"/>	(18)
If based on air permeability value, then [q50 ÷ 20] + (10) in (19), otherwise (19) = (18)				<input type="text" value="0.50"/>	(19)
Air permeability value applies if a pressurisation test has been done, or a design or specified air permeability is being used					
Number of sides on which sheltered				<input type="text" value="2"/>	(20)
Shelter factor			1 - [0.075 x (20)] =	<input type="text" value="0.85"/>	(21)
Adjusted infiltration rate			(19) x (21) =	<input type="text" value="0.42"/>	(22)
Calculate effective air change rate for the applicable case:					
If balanced whole house mechanical ventilation			air throughput (in ach, see 2.6.6) =	<input type="text" value="0.30"/>	(22a)
If balanced with heat recovery			efficiency in % allowing for in-use factor =	<input type="text" value="79.05"/>	(22b)
a) If balanced mechanical ventilation with heat recovery			(22) + (22a) x [1 - (22b) ÷ 100] =	<input type="text" value="0.49"/>	(23)
b) If balanced mechanical ventilation without heat recovery			(22) + (22a) =	<input type="text" value="N/A"/>	(23a)
c) If whole house extract ventilation or positive input ventilation from outside if (22) < 0.25, then (23b) = 0.5; otherwise (23b) = 0.25 + (22)				<input type="text" value="N/A"/>	(23b)
d) If natural ventilation or whole house positive input ventilation from loft					

if (22) >= 1, then (24) = (22); otherwise (24) = 0.5 + [(22)<sup>2</sup> x 0.5]

N/A (24)

Effective air change rate - enter (23) or (23a) or (23b) or (24) in (25)

0.49 (25)

### 3. Heat losses and heat loss perimeter

	Net area (m <sup>2</sup> )		U-value		AxU (W/K)	
Windows*	10.16	x	1.77	=	17.94	(27)
Ground floor	42.24	x	0.22	=	9.12	(28)
Walls	31.40	x	0.31	=	9.83	(29)
Walls	20.77	x	0.25	=	5.19	(29)
Total area of elements	104.57	(32)				

\*for windows and rooflights, use effective window U-value calculated as given in paragraph 3.2

Fabric heat loss (26) + (27) + (28) + (29) + (30) = 42.09 (33)

Thermal bridges - calculated using Appendix K

15.69 (34)

if details of thermal bridging are not known calculate y x (32) [see Appendix K] and enter in (34)

Total fabric heat loss (33) + (34) = 57.77 (35)

Ventilation heat loss (25) x 0.33 x (6) = 17.88 (36)

Heat loss coefficient (35) + (36) = 75.66 (37)

Heat loss parameter (HLP), W/m<sup>2</sup>K (37) ÷ (5) = 1.79 (38)

### 4. Water heating energy requirements

Energy content of hot water used from Table 1 column (b) kWh/year 1325.73 (39)

Distribution loss from Table 1 column (c)

233.95 (40)

if instantaneous water heating at point of use, enter '0' in (40) to (45)

for community heating use Table 1 (c) whether or not hot water tank is present

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day)

N/A (41)

Temperature factor from Table 2b

N/A (41a)

Energy lost from water storage, kWh/year

(41) x (41a) = N/A (42)

b) If manufacturer's declared cylinder loss factor is not known:

Cylinder volume (litres) including any solar storage within same

0.00 (43)

if community heating and no tank in dwelling, enter 110 litres in (43)

otherwise if no stored hot water (this includes instantaneous combi boilers) enter 0 in (43)

Hot water storage loss factor from Table 2, kWh/litre/day

0.00 (44)

if community heating and no tank in dwelling, use cylinder loss from Table 2 for 50mm factory insulation

Volume factor from Table 2a

0.00 (44a)

Temperature factor from Table 2b

0.00 (44b)

Energy lost from water storage, kWh/year

0.00 (45)

Enter (42) or (45) in (46)

0.00 (46)

If dedicated solar storage is within cylinder, (47) = (46) x [(43) - (H11)] ÷ (43), else

0.00 (47)

Primary circuit loss from Table 3

0.00 (48)

Combi loss from Table 3a (enter 0 if not a combi)

439.59 (49)

Solar DHW input calculated using Appendix H (enter 0 if no solar collector)

0.00 (50)

Output from water heater

(39) + (40) + (47) + (48) + (49) - (50) = 1999.28 (51)

Heat gains from water heating

0.25 x [(39) + (49)] + 0.8 x [(40) + (47) + (48)] = 628.49 (52)

include (47) in the calculation of (52) only if a cylinder is in the dwelling or hot water is from community heating

### 5. Internal gains

Lights, appliances, cooking and metabolic from Table 5 Watts 292.86 (53)

Reduction of internal gains due to low energy lighting using Appendix L	28.28	(53a)
Additional gains from Table 5a	0.00	(53b)
Water heating	71.75	(54)
Total internal gains	336.32	(55)

## 6. Solar gains

	Access factor Table 6d		Area (m <sup>2</sup> )		Flux Table 6a		gL Table 6b		FF Table 6c		Gains (W)	
East	0.77	x	1.58	x	48.00	x 0.9 x	0.72	x	0.70	=	26.42	(58)
South	0.77	x	8.58	x	72.00	x 0.9 x	0.72	x	0.70	=	215.87	(60)
Total solar gains	(56) + (57) + (58) + (59) + (60) + (61) + (62) + (63) + (64) =										242.29	(65)
Total gains	(55) + (65) =										578.61	(66)
Gain/loss ratio (GLR)	(66) ÷ (37) =										7.65	(67)
Utilisation factor from Table 7, using GLR in (67)											0.90	(68)
Useful gains	(66) x (68) =										523.63	(69)

## 7. Mean internal temperature

	°C	
Mean internal temperature of the living area from Table 8	18.86	(70)
Temperature adjustment from Table 4e, where appropriate	0.00	(71)
Adjustment for gains R is obtained from the 'responsiveness' column of Table 4a or Table 4d	{[(69) ÷ (37)] - 4} x 0.2 x R =	0.58 (72)
Adjusted living room temperature	(70) + (71) + (72) =	19.45 (73)
Temperature difference between zones from Table 9		0.71 (74)
Living area fraction (0 to 1.0)	living room area ÷ (5) =	0.54 (75)
Rest-of-house fraction	1 - (75) =	0.46 (76)
Mean internal temperature	(73) - [(74) x (76)] =	19.12 (77)

## 8. Degree days

Temperature rise from gains	(69) ÷ (37) =	6.92 (78)
Base temperature	(77) - (78) =	12.20 (79)
Degree days, use (79) and Table 10		1387.01 (80)

## 9. Space heating requirement

	kWh/year	
Space heating requirement (useful)	0.024 x (80) x (37) =	2518.43 (81)

### 9a. Energy requirements - individual heating systems

Space heating		
Fraction of heat from secondary/supplementary system using value from Table 11, Appendix F or Appendix N		0.00 (82)
Efficiency of main heating system, % SEDBUK or from Table 4a or 4b, adjusted where appropriate by the amount shown in the 'efficiency adjustment' column of Table 4c		85.20 (83)
Efficiency of secondary/supplementary system, % use value from Table 4a or Appendix E		0.00 (84)
Main fuel requirement, kWh/year	[(1 - (82)) - (81) x 100 ÷ (83) =	2955.91 (85)
Secondary fuel requirement, kWh/year	(82) x (81) x 100 ÷ (84) =	0.00 (85a)
Water heating		
Efficiency of water heater, % SEDBUK or from Table 4a or 4b, adjusted where appropriate by the amount shown in the 'efficiency adjustment' column of Table 4c		85.20 (86)
Energy required for water heating, kWh/year	(51) x 100 ÷ (86) =	2346.57 (86a)

				kWh/year	
Electricity for pumps and fans					
Each central heating pump from Table 4f				130.00	(87a)
Each boiler with a fan-assisted flue from Table 4f				45.00	(87b)
Warm air heating system fans from Table 4f				0.00	(87c)
Mechanical ventilation - balanced, extract or positive input from outside from Table 4f				54.65	(87d)
Maintaining keep-hot facility for gas combi boiler from Table 4f				0.00	(87e)
Pump for solar water heating from Table 4f				0.00	(87f)
Total electricity for the above equipment	(87a) + (87b) + (87c) + (87d) + (87e) + (87f) =			229.65	(87)

#### 10a. Fuel costs - individual heating systems

	Fuel required kWh/year		Fuel price Table 12		Fuel cost £/year	
Main space heating	(85)	x	1.63	x 0.01 =	48.18	(88)
Secondary space heating	(85a)	x	N/A	x 0.01 =	0.00	(89)
Water heating (electric off-peak tariff)						
On-peak fraction, from Table 13 or Appendix F for electric CPSUs				0.00		(90)
Off-peak fraction			1 - (90) =	1.00		(90a)
On-peak cost	(86a) x (90)	x	0.00	x 0.01 =	0.00	(91)
Off-peak cost	(86a) x (90a)	x	0.00	x 0.01 =	0.00	(91a)
Water heating (other fuel)	(86a)	x	1.63	x 0.01 =	38.25	(91b)
Pump and fan energy	(87)	x	7.12	x 0.01 =	16.35	(92)
Energy for lighting, calculated in Appendix L	188.56	x	7.12	x 0.01 =	13.43	(93)
Additional standing charges from Table 12					34.00	(94)
Renewable and energy-saving technologies (Appendices M, N and Q)						
Energy produced or saved	0.00	x	N/A	x 0.01 =	0.00	(95)
Energy consumed	0.00	x	N/A	x 0.01 =	0.00	(96)
Total energy cost	(88) + (89) + (91) + (91a) + (91b) + (92) + (93) + (94) - (95) + (96) =				150.21	(97)

#### 11a. SAP rating - individual heating system

Energy cost deflator	0.91	(98)
Energy cost factor (ECF)	1.22	(99)
SAP rating from Table 14	83	(100)
SAP band	B	

#### 12a. CO emissions - individual heating systems and community heating without CHP

	Energy kWh/year		Emission factor kg CO /kWh		Emissions kg CO /year	
Individual heating system						
Main space heating	(85)	x	0.194	=	573.45	(101)
Secondary space heating	(85a)	x	N/A	=	0.00	(102)
Water heating	(86a)	x	0.194	=	455.23	(103)
Space and water heating if negative, enter '0' in (107)				(101) + (102) + (103) =	1028.68	(107)
Electricity from pumps and fans from (87) or (88*)	229.65	x	0.422	=	96.91	(108)
Energy for lighting from Appendix L	188.56	x	0.422	=	79.57	(109)
Renewable and energy-saving technologies (Appendices M, N and Q)						
Energy produced or saved	0.00	x	N/A	=	0.00	(110)
Energy consumed	0.00	x	N/A	=	0.00	(111)
Total CO	(107) + (108) + (109) - (110) + (111) =				1205.16	(112)

Dwelling CO <sub>2</sub> emission rate	(112) ÷ (5) =	28.53	{113}
EI rating		81	
EI band		B	

### 13a. Primary energy - individual heating systems and community heating without CHP

	Energy kWh/year		Primary energy factor		Primary energy kWh/year	
Individual heating system						
Main space heating	(85)	x	1.150	=	3399.29	{101}
Secondary space heating	(85a)	x	N/A	=	0.00	{102}
Water heating	(86a)	x	1.150	=	2698.56	{103}
Space and water heating if negative, enter '0' in {107}			{101} + {102} + {103} =		6097.85	{107}
Electricity from pumps and fans from (87) or (88*)	229.65	x	2.800	=	643.01	{108}
Energy for lighting from Appendix L	188.56	x	2.800	=	527.97	{109}
Renewable and energy-saving technologies (Appendices M, N and Q)						
Energy produced or saved	0.00	x	N/A	=	0.00	{110}
Energy consumed	0.00	x	N/A	=	0.00	{111}
Primary energy			{107} + {108} + {109} - {110} + {111} =		7268.82	{112}
Primary energy, kWh/m <sup>2</sup> /year			{112} ÷ (5) =		172.08	{113}