

This Design submission has been carried out by an Authorised SAP Assessor. It has been prepared from plans and specifications and may not reflect the property as constructed.

Assessor Name MRS JOANNE CHURCHILL

Assessor Number 1591

Client

Date Last Modified 27/04/2010

Address Unit 9 Makepeace Mansions Unit 9(LB) Holly Lodge Estate, Camden, Greater London, NW1

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

1. Overall dwelling dimensions

	Area (m ²)	Average storey height (m)	Volume (m ³)
Ground Floor	<input type="text" value="42.24"/> (1a)	<input type="text" value="2.60"/>	<input type="text" value="109.82"/> (1)
Total floor area (1a)+(2a)+(3a)+(4a)+(4b)+(4d)+(4f)+(4h) =	<input type="text" value="42.24"/> (5)		
Dwelling volume		(1)+(2)+(3)+(4)+(4c)+(4e)+(4g)+(4i) =	<input type="text" value="109.82"/> (6)

2. Ventilation rate

	m ³ per hour	Air changes per hour
Number of chimneys	<input type="text" value="0"/> × 40 = <input type="text" value="0"/> (7)	
Number of open flues	<input type="text" value="0"/> × 20 = <input type="text" value="0"/> (8)	
Number of intermittent fans or passive vents	<input type="text" value="0"/> × 10 = <input type="text" value="0"/> (9)	
Number of flueless gas fires	<input type="text" value="0"/> × 40 = <input type="text" value="0"/> (9a)	
Infiltration due to chimneys, flues and fans = (7)+(8)+(9)+(9a) =	<input type="text" value="0"/>	÷ box (6) = <input type="text" value="0.00"/> (10)
<i>If a pressurisation test has been carried out, proceed to box (19)</i>		
Number of storeys in the dwelling	<input type="text" value="1"/> (11)	
Additional infiltration		[(11) - 1] × 0.1 = <input type="text" value="N/A"/> (12)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction		<input type="text" value="N/A"/> (13)
If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0		<input type="text" value="N/A"/> (14)
If no draught lobby, enter 0.05, else enter 0		<input type="text" value="N/A"/> (15)
Percentage of windows and doors draught stripped	<input type="text" value="N/A"/> (16)	
<i>Enter 100 in box (16) for new dwellings which are to comply with Building Regulations</i>		
Window infiltration	0.25 - [0.2 × (16) ÷ 100] =	<input type="text" value="N/A"/> (17)
Infiltration rate	(10)+(12)+(13)+(14)+(15)+(17) =	<input type="text" value="N/A"/> (18)
If based on air permeability value, then [q ₅₀ ÷ 20] + (10) in box (19), otherwise (19) = (18)		<input type="text" value="0.50"/> (19)
<i>Air permeability value applies if a pressurisation test has been done or the design air permeability is being used</i>		

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

Number of sides on which sheltered (Enter 2 in box (20) for new dwellings where location is not shown)		<div>2</div>	(20)
Shelter factor	$1 - [0.075 \times (20)] =$	<div>0.85</div>	(21)
Adjusted infiltration rate	$(19) \times (21) =$	<div>0.38</div>	(22)
Calculate effective air change rate for the applicable case			
If balanced whole house mechanical ventilation system	air throughput (ach) =	<div>0.30</div>	(22a)
If balanced with heat recovery	efficiency in % allowing for in-use factor =	<div>79.05</div>	(22b)
a) If balanced whole house mechanical ventilation with heat recovery	$(22) + (22a) \times [1 - (22b) / 100] =$	<div>0.45</div>	(23)
b) If balanced whole house mechanical ventilation without heat recovery	$(22) + (22a) =$	<div>N/A</div>	(23a)
c) If whole house extract ventilation or positive input ventilation from outside if $(22) < 0.25$, then $(23b) = 0.5$; otherwise $(23b) = 0.25 + (22)$		<div>N/A</div>	(23b)
d) If natural ventilation or whole house positive input ventilation from loft if $(22) \geq 1$, then $(24) = (22)$; otherwise $(24) = 0.5 + [(22)^2 \times 0.5]$		<div>N/A</div>	(24)
Effective air change rate - enter (23) or (23a) or (23b) or (24) in box (25)		<div>0.45</div>	(25)

3. Heat losses and heat loss parameter

ELEMENT	Area (m ²)	U - value	AXU (W/K)
Windows *	<div>10.93</div>	<div>1.77</div>	<div>19.30</div> (27)
Walls	<div>29.92</div>	<div>0.31</div>	<div>9.36</div> (29)
Walls	<div>20.77</div>	<div>0.25</div>	<div>5.19</div> (29)
Total area of elements ΣA , m ²	<div>61.62</div> (32)		

* for windows and rooflights use effective window U-value calculated as given in paragraph 3.2

Fabric heat loss, W/K	$(26)+(27)+(27a)+(27b)+(28)+(29)+(29a)+(30)+(30a)+(31) =$	<div>33.86</div>	(33)
Thermal bridges - $\Sigma (l \times \Psi)$ calculated using Appendix K if details of thermal bridging are not known calculate $y \times (32)$ [see Appendix K] and enter in box (34)		<div>9.24</div>	(34)
Total fabric heat loss	$(33)+(34) =$	<div>43.10</div>	(35)
Ventilation heat loss	$(25) \times 0.33 \times (6) =$	<div>16.14</div>	(36)
Heat loss coefficient, W/K	$(35)+(36) =$	<div>59.24</div>	(37)
Heat loss parameter (HLP), W/m ² K	$(37) \div (5) =$	<div>1.40</div>	(38)

4. Water heating energy requirement

Energy content of hot water used from Table 1 column (b)	<div>1325.73</div>	(39)
Distribution loss from Table 1 column (c) If instantaneous water heating at point of use, enter "0" in boxes (40) to (45) For community heating use Table 1 (c) whether or not hot water tank is present	<div>233.95</div>	(40)
Water storage loss:		

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

a) If manufacturer's declared loss factor is known (kWh/day):

	<input type="text" value="N/A"/>	(41)
Temperature factor from Table 2b	<input type="text" value="N/A"/>	(41a)
Energy lost from water storage, kWh/year	$(41) \times (41a) \times 365 =$	<input type="text" value="N/A"/> (42)

b) If manufacturer's declared cylinder loss factor is not known:

Cylinder volume (litres) including any solar storage within same cylinder	<input type="text" value="N/A"/>	(43)
<i>If community heating and no tank in dwelling, enter 110 litres in box (43)</i>		
<i>Otherwise, if no stored hot water (this includes instantaneous combi boilers), enter '0' in box (43)</i>		
Hot water storage loss factor from Table 2 (kWh/litre/day)	<input type="text" value="0.00"/>	(44)
<i>If community heating and no tank in dwelling, use cylinder loss from Table 2 for 50 mm factory insulation in box (44)</i>		
Volume factor from Table 2a	<input type="text" value="0.00"/>	(44a)
Temperature factor from Table 2b	<input type="text" value="0.00"/>	(44b)
Energy lost from water storage, kWh/year	$(43) \times (44) \times (44a) \times (44b) \times 365 =$	<input type="text" value="0.00"/> (45)
Enter (42) or (45) in box (46)	<input type="text" value="0.00"/>	(46)
If cylinder contains dedicated solar storage, box (47) = $(46) \times [(43) - (H11)] / (43)$, else (47) = (46)	<input type="text" value="0.00"/>	(47)
Primary circuit loss from Table 3	<input type="text" value="0.00"/>	(48)
Combi loss from Table 3a (enter "0" if no combi boiler)	<input type="text" value="439.59"/>	(49)
Solar DHW input calculated using Appendix H (enter "0" if no solar collector)	<input type="text" value="0.00"/>	(50)
Output from water heater, kWh/year	$(39) + (40) + (47) + (48) + (49) - (50) =$	<input type="text" value="1999.28"/> (51)
Heat gains from water heating	$0.25 \times [(39) + (49)] + 0.8 \times [(40) + (47) + (48)] =$	<input type="text" value="628.49"/> (52)
<i>include (47) in calculation of (52) only if cylinder is in the dwelling or hot water is from community heating</i>		

5. Internal gains

	Watts	
Lights, appliances, cooking and metabolic (Table 5)	<input type="text" value="388.80"/>	(53)
Reduction of internal gains due to low energy lighting (calculated in Appendix L)	<input type="text" value="30.13"/>	(53a)
Additional gains from Table 5a	<input type="text" value="0.00"/>	(53b)
Water heating	$(52) \div 8.76 =$	<input type="text" value="71.75"/> (54)
Total internal gains	$(53) + (53b) + (54) - (53a) =$	<input type="text" value="430.42"/> (55)

6. Solar gains

	Access factor Table 6d	Area m ²	Flux Table 6a	g Table 6b	FF Table 6c	Gains (W)	
East	<input type="text" value="0.77"/>	<input type="text" value="1.56"/>	<input type="text" value="48.48"/>	<input type="text" value="0.9"/>	<input type="text" value="0.72"/>	<input type="text" value="26.42"/>	(59)
South	<input type="text" value="0.77"/>	<input type="text" value="9.37"/>	<input type="text" value="72.72"/>	<input type="text" value="0.9"/>	<input type="text" value="0.72"/>	<input type="text" value="238.02"/>	(62)

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

Total solar gains: [(56) + + (64)] = 264.43 (65)

Note: for new dwellings where overshadowing is not known, the solar access factor is '0.77'

Total gains, W (55) + (65) = 694.85 (66)

Gain/loss ratio (GLR) (66) ÷ (37) = 11.73 (67)

Utilisation factor (Table 7, using GLR in box (67)) 0.78 (68)

Useful gains, W (66) × (68) = 545.09 (69)

Gains Zone 1, G1 327.05 (NHER)

Gains Zone 2, G2 218.04 (NHER)

7. Mean internal temperature

° C

Living area fraction (0 to 1.0) living room area ÷ (5) = 0.54 (75)

Interzone heat coefficient 98.58 (NHER)

Mean external temperature 2.41 (NHER)

	Zone1	Zone2	
Specific loss	32.10	27.14	(NHER)
Demand temperature	21.00	20.35	(NHER)
Mean internal temperature	19.33	18.80	(NHER)

8. Degree days

	Zone1	Zone2	
Base temperature	10.00	8.83	(NHER)
Degree-days	585.21	466.28	(NHER)

9. Space heating requirements

	Zone1	Zone2	
Space heating requirement (useful), kWh/year	749.78	65.56	(NHER)
Total space heating requirement (useful), kWh/year		815.34	(81)

For range cooker boilers where efficiency is obtained from the Boiler Efficiency Database or manufacturer's declared value, multiply the result in box (81) by (1 - Φ_{case}/Φ_{water}) where Φ_{case} is the heat emission from the case of the range cooker at fullload (in kW); and Φ_{water} is the heat transferred to water at full load (in kW). Φ_{case} and Φ_{water} are obtained from the database record for the range cooker boiler or manufacturer's declared value.

9a. Energy requirements - individual heating systems, including micro-CHP

Note: when space and water heating is provided by community heating use the alternative worksheet 9b

Space heating:

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

Fraction of heat from secondary/supplementary system (use value from Table 11, Table 12a or Appendix F)	<input type="text" value="0.00"/>	(82)
Efficiency of main heating system, %	<input type="text" value="85.20"/>	(83)
(SEDBUK or from Table 4a or 4b, adjusted where appropriate by the amount shown in the 'efficiency adjustment' column of Table 4c)		
Efficiency of secondary/supplementary heating system, % (use value from Table 4a or Appendix E)	<input type="text" value="0.00"/>	(84)
Space heating fuel (main) requirement, kWh/year	$[1 - (82)] \times (81) \times 100 \div (83) =$	<input type="text" value="956.97"/> (85)
Space heating fuel (secondary), kWh/year	$(82) \times (81) \times 100 \div (84) =$	<input type="text" value="N/A"/> (85a)

Water heating:

Efficiency of water heater, %	<input type="text" value="85.20"/>	(86)
(SEDBUK or from Table 4a or 4b, adjusted where appropriate by the amount shown in the 'efficiency adjustment' column of Table 4c)		
Energy required for water heating, kWh/year	$(51) \times 100 \div (86) =$	<input type="text" value="2346.57"/> (86a)

Electricity for pumps and fans:

	kWh/year	
each central heating pump, (Table 4f)	<input type="text" value="130.00"/>	(87a)
each boiler with a fan-assisted flue (Table 4f)	<input type="text" value="45.00"/>	(87b)
warm air heating system fans (Table 4f)	<input type="text" value="0.00"/>	(87c)
mechanical ventilation -balanced, extract or positive input from outside (Table 4f)	<input type="text" value="54.02"/>	(87d)
maintaining keep-hot facility for gas combi boiler (Table 4f)	<input type="text" value="0.00"/>	(87e)
pump for solar water heating (Table 4f)	<input type="text" value="0.00"/>	(87f)
Total electricity for the above equipment, kWh/year	<input type="text" value="229.02"/>	(87)
Electricity for pumps,fans lights and appliances:	<input type="text" value="2021.08"/>	(NHER)

Cooking:

Cooking fuel requirement (Electricity), kWh/year	<input type="text" value="302.30"/>	(NHER)
Cooking fuel requirement (Other fuel), kWh/year	<input type="text" value="531.08"/>	(NHER)

10a. Fuel costs - individual heating systems

	Fuel kWh/year		Fuel price (Table 12)		Fuel cost £/year	
Space heating - main system	(85)	×	<input type="text" value="1.87"/>	×0.01 =	<input type="text" value="17.87"/>	(88)
Space heating - secondary	(85a)	×	<input type="text" value="N/A"/>	× 0.01 =	<input type="text" value="0.00"/>	(89)
Water heating						
Water heating cost (electric, off-peak tariff)						
On-peak fraction (Table 13, or Appendix F for electric CPSUs)			<input type="text" value="0.00"/>	(90)		
Off-peak fraction		1.0 - (90) =	<input type="text" value="1.00"/>	(90a)		
On-peak cost	(86a) × (90)	×	<input type="text" value="N/A"/>	× 0.01 =	<input type="text" value="0.00"/>	(91)

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

Off-peak cost	(86a) × (90a) ×	N/A	× 0.01 =	0.00	(91a)
Water heating cost (other fuel)	(86a) ×	1.87	× 0.01 =	43.81	(91b)
Pump,fan,lights and appliances energy cost					
On-peak fraction				1.00	
Off-peak fraction				0.00	
Fuel price					
On-peak cost	2021.08 ×	1.00 ×	7.96 × 0.01 =	160.96	(NHER)
Off-peak cost	2021.08 ×	0.00 ×	-1.00 × 0.01 =	0.00	(NHER)
Cooking					
Cooking cost (Electricity)	302.30 ×	7.96 × 0.01 =	24.08	(NHER)	
Cooking cost (Other fuel)	531.08 ×	1.87 × 0.01 =	9.92	(NHER)	
Additional standing charges				76.24	(94)
Renewable and energy-saving technologies (Appendices M and N)					
PV					
Energy produced or saved, kWh/year	N/A	(95)			
Cost of energy produced or saved, £/year	(95) ×	N/A	× 0.01 =	N/A	(95a)
Wind					
Energy produced or saved, kWh/year	N/A	(95b1)			
Cost of energy produced or saved, £/year	(95b1) ×	N/A	× 0.01 =	N/A	(95b)
Micro CHP					
Energy produced or saved, kWh/year	N/A	(95c1)			
Cost of energy produced or saved, £/year	(95c1) ×	N/A	× 0.01 =	N/A	(95c)
Energy consumed by the technology, kWh/year	N/A	(96)			
Cost of energy consumed, £/year	(96) ×	N/A	× 0.01 =	N/A	(96a)
Special features (Appendix Q)					
Energy produced or saved, kWh/year	N/A	(s1)			
Cost of energy produced or saved, £/year	(s1) ×	N/A	× 0.01 =	N/A	(s1a)
Energy consumed by the technology, kWh/year	N/A	(s2)			
Cost of energy consumed, £/year	(s2) ×	N/A	× 0.01 =	N/A	(s2a)
Total energy cost	(88)+(89)+(91)+(91a)+(91b)+(92)+(93)+(94)-(95a)-(95b)-(95c)+(96a)-(s1a)+(s2a) =			332.87	(97)

11a. NHER rating - individual heating systems

NHER rating 11.10

12a. Total CO2 for individual heating systems (including micro-CHP) and community heating without CHP

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

Individual heating system:	Energy kWh/year	Emission factor kg CO ₂ /kWh	Emissions kgCO ₂ /year
Space heating main from box (85)	956.97	× 0.194	= 185.65 (101)
Space heating secondary from box (85a)	N/A	× N/A	= 0.00 (102)
Energy for water heating from box (86a)	2346.57	× 0.194	= 455.23 (103)
Energy for water heating (51) or [(87b*) × 100 ÷ (104)] =	N/A	× N/A	= 0.00 (106)
Space and water heating [(101) + (102) + (103)] or [(105) + (106)] =			640.89 (107)
Energy for water heating (Type 1 fraction) × (87*) × 100 ÷ (104a) =	N/A	× N/A	= 0.00 (106a)
Energy for water heating (Type 2 fraction) × (87*) × 100 ÷ (104b) =	N/A	× N/A	= 0.00 (106b)
Space and water heating [(105a) + (106a) + (105b) + (106b)] =			640.89 (107)
Electricity for pumps,fans,lights and appliances	2021.08	× 0.422	= 852.89 (NHER)
Cooking			
Energy for cooking (Electricity)	302.30	× 0.42	= 127.57 (NHER)
Energy for cooking (Other fuel)	531.08	× 0.19	= 103.03 (NHER)
Energy produced or saved in dwelling (Appendices M and N)			
PV energy produced or saved (95) or (95*)		× N/A	= N/A (110)
Wind energy produced or saved (95b1) or (95b1*)		× N/A	= N/A (110b)
Micro-CHP energy produced or saved (95c1) or (95c1*)		× N/A	= N/A (110c)
Micro-CHP energy consumed (96) or (96*)		× N/A	= 0.00 (111)
Energy produced or saved in dwelling (Appendix Q) (s1) or (s1*)		× N/A	= 0.00 (s1a)
Energy consumed by the technology (Appendix Q) (s2) or (s2*)		× N/A	= 0.00 (s2a)
Total CO ₂ kg/year (107) + (108) + (109) - (110) + (111) - (s1a) + (s2a)			= 1723.38 (112)
Total CO₂ (kg/m²/year) (112) ÷ (5)			= 40.80 (113)

13a. Primary energy, for individual heating systems (including micro-CHP) and community heating without CHP

Individual heating system:	Energy kWh/year	Primary energy factor	Primary energy (kWh/year)
Space heating main from box (85)	956.97	× 1.150	= 1100.52
Space heating secondary from box (85a)	N/A	× N/A	= 0.00
Energy for water heating from box (86a)	2346.57	× 1.150	= 2698.56
Energy for water heating (87b*) × 100 ÷ (104) =	N/A	× N/A	= 0.00
Space and water heating			3799.08
Energy for water heating (Type 1 fraction) × (87*) × 100 ÷ (104a) =	N/A	× N/A	= 0.00

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control

Energy for water heating	(Type 2 fraction) × (87*) × 100 ÷ (104b)	=	N/A	×	N/A	=	0.00
Space and water heating						=	3799.08
Primary energy for pumps,fans,lights and appliances			2021.08	×	2.80	=	5659.01 (NHER)
Cooking							
Primary energy for cooking (Electricity)			302.30	×	2.80	=	846.43 (NHER)
Primary energy for cooking (Other fuel)			531.08	×	1.15	=	610.74 (NHER)
Energy produced or saved in dwelling (Appendices M and N)							
PV energy produced or saved	(95) or (95*)	×	N/A	=			N/A
Wind energy produced or saved	(95b1) or (95b1*)	×	N/A	=			N/A
Micro-CHP energy produced or saved	(95c1) or (95c1*)	×	N/A	=			N/A
Micro-CHP energy consumed	(96) or (96*)	×	N/A	=			0.00
Energy produced or saved in dwelling (Appendix Q)	(s1) or (s1*)	×	N/A	=			0.00
Energy consumed by the above technology (Appendix Q)	(s2) or (s2*)	×	N/A	=			0.00
Primary energy kWh/year							10915.26
Primary energy kWh/m²/year							258.41

This draft NHER rating worksheet report is for internal purposes only and should not be accepted as evidence of compliance by Building Control