



- NOTES:
1. TO BE READ IN CONJUNCTION WITH MFLP SPECIFICATION FOR SPECIALIST MECHANICAL INSTALLATION, MFLP U10) SERIES DRAWINGS AND ALL OTHER DRAWINGS REFERENCED.
 2. ALL POOL DUCTWORK FOR POOL HALL VENTILATION TO BE PAINTED INTERNALLY AND EXTERNALLY WITH CHLORINATED RUBBER PAINT.
 3. INSTALLATION TO BE IN ACCORDANCE WITH HVCA SPECIFICATION FOR SHEET METAL DUCTWORK DW144 MEDIUM PRESSURE CLASS B UNLESS SPECIFIED OTHERWISE. SEE MFR SPECIFICATION FOR SPECIALIST MECHANICAL INSTALLATION.

NOTES ON HAZARDS/ ACCESS/ MAINTENANCE TEXT EDIT

CONSTRUCTION

B	01/13/08	CONSTRUCTION ISSUE
B	23/05/08	TENDER
A	06/05/08	PRE TENDER
+	06/04/08	FOR COORDINATION
rev	date	description

maxfordham
ENGINEERING DESIGN ENVIRONMENT

Max Fordham Consulting Engineers
42/43 Gloucester Crescent
London NW1 7PE
t. 020 7287 5161
f. 020 7482 0399
www.maxfordham.com

Max Fordham LLP is a limited liability partnership registered in England No OC300056
architect

LIMBRICK

job title

**KENTISH TOWN
SPORTS CENTRE**

drawn by date scale (at A1)
SAC APR'08 1:50

drawing title
**WILLES POOL EXTRACT
AIR DUCTWORK COORDINATION
DETAILS**

job no dwg no rev
3672 Z[--]-025 /B