

Arqiva Limited
Crawley Court
Crawley
Winchester
Hampshire
SO21 2QA

Application Ref: **2010/0875/P**
Please ask for: **Max Smith**
Telephone: 020 7974 **5114**

6 April 2010

Dear Sir/Madam

DECISION

Town and Country Planning Acts 1990 (as amended)
Town and Country Planning (General Development Procedure) Order 1995
Town and Country Planning (Applications) Regulations 1988

Full Planning Permission Refused

Address:
Unit 4
8 William Road
London
NW1 3EN

Proposal:
Installation of one ground based dry air cooler at front and 3 wall mounted air conditioning units on front elevation of existing commercial unit.

Drawing Nos: Searle Dry Air Coolers; Acoustic Report by Ian Sharland Limited dated 26th March 2010; 08801-00-004-ML001 rev1; 09-006-P002 rev P2; 09-006-P001 rev P2;

The Council has considered your application and decided to **refuse** planning permission for the following reason(s):

Reason(s) for Refusal

- 1 Insufficient information has been submitted to demonstrate that the proposed equipment would not harm the amenities of neighbours in terms of noise disturbance. As such, the proposal would be contrary to policies SD6 (Amenity for occupiers and neighbours), SD7 (Light, noise and vibration pollution) and SD8



(Disturbance) of the London Borough of Camden Replacement Unitary
Development Plan 2006.

Disclaimer

***This is an internet copy for information purposes. If you
require a copy of the signed original please contact the
Culture and Environment Department on (020) 7974 5613***