

Incomplete Reasons Schedule

Application Ref: 2010/0486/INVALID

Address Flat B, 5 Leigh Street, London, WC1H 9EW

Associated Ref:

Please review the items listed here as reasons for your application being incomplete.

It will assist with the checking of your new information if you can complete and return this sheet with your information, indicating what incomplete reasons have been addressed. Where you have not fully met the requirement or do not believe the information is necessary, please use the space provided to give reasons you believe should be taken into account.

Invalid Reason	Included Y/N	Comments or reason if not included
<p>Please provide information on any proposed service runs and extent of cutting of joists if any as well as any architraving of new openings.</p>	<p>YES</p>	<p>Please refer to drawing 1049.01.1D for services. I have indicated in red the proposed route for waste. Water supply to bathroom and kitchen will run in the same location from the current position on the rear wall. Our thinking for arranging the kitchen and bathroom as so is to allow minimal disruption to the space. Also our builder has suggested we can run in between joists only potentially cutting through beneath the shower tray. We have amended the design from a wet-room sump to a shower tray to help this further.</p> <p>I have not included any architrave details as I would very much like to discuss this on site with one of your planning officers who has the expertise in this area. There are currently no architraves anywhere in the apartment as all of the period features have unfortunately been removed by previous owners.</p>

RECEIVED
07 FEB 2011