Skelli - Yaoz, Tania

From:

Nabeela Ameen [NAmeen@oxford-architects.com]

Sent:

16 November 2009 11:34

To:

Skelli - Yaoz, Tania

Cc:

Brian Donnelly

Subject:

09043 Mornington Leisure Centre - Amended Louvre positions

Attachments: 021b.pdf

Dear Tania.

Thanks for taking my call this morning and having a chat about the Underhill Elevation louvres, following Brian's email of 12 November.

And the second of the second o

Please find attached revised drawing 021B showing the amended louvre positions to the 2nd and 3rd bay of Underhill Street.

Further to our conversation, I would like to clarify that the height of the grilles needs to be above the internal roof line, the apex being at Underhill Street. The internal ceiling line is 3m, which is above the rendered/white painted zone on Underhill Street. In addition there is the ceiling zone, the steel beam section along with roof makeup. We will aim to keep the louvres as low as practicably possible.

I hope all this helps and look forward to your reply in due course.

Many thanks Kind regards

Nabeela Ameen



Nabeela Ameen

Bagley Croft Hinksey Hill Tel: 01865 329100 Fax: 01865 326822

Oxford OX1 5BS www.oxford-architects.com

Private and Confidential: This e-mail transmission is strictly confidential and intended solely for the person or organisation to whom it is addressed. If you are not the intended recipient you must not use, copy or forward it, disclose its contents to any other person, or take any action in reliance on it. You should delete it from your system. While we take all reasonable precautions, neither Oxford Architects nor the sender accepts any liability or responsibility for any adverse effects on your systems or data caused by the onward transmission, opening or use of this message or attachments (if any). Please carry out virus and other such checks as you consider appropriate. Oxford Architects is the trading name of Oxford Architects LLP a Limited Liability Partnership. Any reference to a Partner means a member of the LLP.