

**CAM-G-RL-2
SAFER NEIGHBOURHOODS
179 WEST END LANE
LONDON NW6 2LH**

**PLANT NOISE
ASSESSMENT REPORT
3742/PNA**

1 October 2009
Revision Number: 0

Issued For: Mansell PLC
Roman House
263-269 City Road
EC1V 1JX

Prepared by:
Sam Laws

Approved by:
Russell Richardson

RBA Acoustics
104 The Foundry Annexe
65 Glasshill Street
London
SE1 0QR

Tel: 020 7953 7233
Facsimile: 020 7953 7236
Email: info@rba-acoustics.co.uk

**CAM-G-RL-2
SAFER NEIGHBOURHOODS
179 WEST END LANE
LONDON NW6 2LH**

**PLANT NOISE ASSESSMENT REPORT
3742/PNA**

Contents

1.0	Introduction	1
2.0	Noise Survey.....	1
3.0	Local Authority Requirements	2
4.0	Results	3
5.0	Atmospheric Noise Emission Criteria	3
6.0	Assessment.....	3
7.0	Conclusion	5

1.0 Introduction

It is proposed to install new building services plant to the rear of 179 West End Lane, London NW6. A planning application has been submitted for this and the London Borough of Camden's Environmental Health Department has requested an acoustic assessment be carried out in support of the application.

RBA Acoustics have been commissioned by TP Bennett to undertake measurements of the prevailing noise conditions at the rear of the site and to provide an assessment of the atmospheric noise emissions from the proposed air conditioning units to the nearest noise sensitive property for comparison with the London Borough of Camden's noise emission criterion.

2.0 Noise Survey

2.1 General

It is proposed that the plant will operate during the daytime period only (07:00 – 23:00 hours). Noise monitoring was therefore undertaken as follows:

Thursday 24 September 2009 20:00 – 23:00 hours

During the survey period the weather conditions were considered appropriate for the noise measurement exercise, it being dry with only a very light breeze.

Measurements were made of the L_{A90} noise levels over sample periods of 15 minutes.

2.2 Measurement Location

A microphone was mounted on a boom at a height of approximately 9m above ground level and approximately 8m from the proposed plant location. The measurement position is shown on the attached Site Plan 3742/SP1.

The nearest residential window to the proposed position of the plant was identified as being located directly above 179 West End Lane at second floor level. The measurement location was noted to be at an approximate distance of 2m from the nearest noise sensitive window. However, the noise climate at the measurement location was deemed to be representative of that at the location of the nearest noise-sensitive window, to which it was not possible to gain access.

The prevailing noise climate at the measurement position was noted to consist of noise produced by existing mechanical services to the rear of the adjacent property (Papa John's Pizza Restaurant) as well as noise produced by regular train movements along the adjacent railway lines to the North of the site and ambient road traffic movements within the local area.

2.3 Instrumentation

The following equipment was used for the measurements:

Table 3742/T1 – Equipment

Manufacturer	Model Type	Serial No.	Calibration	
			Certificate No.	Expiry Date
01dB A&V Type 1 Sound Level Meter	Blue Solo 01	60610	5589	11 August 2010
01dB A&V Pre Amplifier	PRE 21 S	13676		
Gras ½" Microphone	MCE 212	84948		
01dB-Stell Calibrator	Cal 21	50441910	U5569	6 August 2010

The equipment was calibrated prior to and on completion of the survey. No significant calibration drift occurred.

3.0 Local Authority Requirements

The requirements of Camden Council's Unitary Development Plan 2006 regarding noise levels from new plant and machinery are confirmed as follows.

Table 3742/T2 – Camden Council Noise Thresholds

Noise description and Location of measurement	Period	Time	Noise level
Noise at 1 metre external to a sensitive facade	Day, evening and night	0000-2400	5dB(A) <L _{A90}
Noise that has a distinguishable discrete continuous note (whine, hiss, screech, hum) at 1 metre external to a sensitive facade	Day, evening and night	0000-2400	10dB(A) <L _{A90}
Noise that has distinct impulses (bangs, clicks, clatters, thumps) at 1 metre external to a sensitive facade	Day, evening and night	0000-2400	10dB(A) <L _{A90}
Noise at 1 metre external to sensitive facade where LA90 >60dB	Day, evening and night	0000-2400	55dB L _{Aeq}

4.0 Results

The typical background noise spectrum at the measurement position is shown on the attached Graph 3742/G1.

The background (L_{A90}) noise levels measured are summarised below.

Table 3742/T3 – Measured Noise Levels

Measurement Period	L_{A90} Sound Pressure Level (dBA)
20:00 – 21:00	54.7
21:00 – 22:00	54.7
22:00 – 23:00	54.4

5.0 Atmospheric Noise Emission Criteria

Based on the measured existing background noise levels and the London Borough of Camden's criteria for plant noise emissions (as detailed in Section 3.0) we propose an atmospheric noise emission limit from all units at the nearest residential window of 49dBA (assuming the noise does not contain the undesirable characteristics described by Camden).

N.B. It should be noted that the prevailing noise climate was measured in intervals of 15 minutes duration, meaning that the measured L_{A90} sample is in fact an $L_{A90,15min}$ sample. However, as the noise climate was constant throughout the survey period it is considered to be representative of the existing background noise levels over each hourly period.

6.0 Assessment

In order to ensure a worst-case assessment the lowest measured background noise levels have been used in all analyses.

Our assessment has been based upon the following information:

6.1 Proposed Air Conditioning Units

2No. Mitsubishi SUZ-KA50VA

6.2 Noise Levels and Position of Units

Information regarding the noise levels of the proposed plant was provided by the manufacturers of the units.

The sound pressure level (SPL) of the SUZ-KA50VA unit is advised as being a worst case (heating mode) of 55dBA at 1m.

Octave band data was obtained for the specified units and is summarised below.

3742/T4 – Manufacturers Plant Noise Emission Data

	Sound Pressure Level (dB re 2×10^{-5} Pa) at Octave Band Centre Frequencies								Overall SPL
	63	125	250	500	1k	2k	4k	8k	dBA
SUZ- KA50VA	60	63	56	54	49	43	40	38	55

A review of the above noise data with reference to BS 7445 Pt. 2:1991 suggests that there would be no tonal characteristics associated with the proposed plant. As such, we assume no tonal correction to the noise emission criterion is required.

The proposed air-conditioning units are to be located to the rear of 179 West End Lane and are to be wall mounted at lower ground floor level. The proposed positions are indicated on the attached Site Plan 3742/SP1.

6.3 Operating Hours

We understand from TP Bennett Architects that the proposed plant is required to operate during the daytime period only, up to 22:00 hours.

6.4 Location of Nearest Residential Window

The worst-affected residential window in proximity to the proposed plant was identified as being located directly above 179 West End Lane, at second floor level. This is approximately 10m from the proposed plant location and is marginally screened by a balcony serving the second floor residence, which extends approximately 1.5m from the rear façade of the building.

The approximate location of these windows is also indicated on the attached Site Plan 3742/SP1.

6.5 Calculation of Noise Levels at Nearest Residential Window

Our calculation method for predicting noise levels from the proposed air conditioning units at the nearest residential window, based on the information stated above, is summarised below.

- Cumulative Source Term (combined condenser SPL)
- 20LogR Distance Attenuation
- Screening Effects
- Reflection Effects

The above method predicts a combined noise level due to the operation of the air conditioning units of 40dBA at the nearest noise-sensitive window. A copy of our calculation spreadsheet is attached as required by the London Borough of Camden.

6.6 Mitigation


The predicted worst-case noise level of 40dBA at the nearest residential window is in excess of 10dBA below the lowest measured background noise level and therefore within the proposed atmospheric noise emissions criterion. As such, no mitigation measures are required.


7.0 Conclusion

Measurements of the existing background noise levels at 179 West End Lane, London NW6 have been undertaken in accordance with the requirements of the London Borough of Camden. The results of the measurements have been used in order to assess atmospheric noise emissions from the proposed new plant.

The results of the assessment indicate atmospheric noise emissions from the proposed plant, when assessed at the nearest noise sensitive receptor location are likely to be significantly lower than the requirements of the London Borough of Camden's Environmental Health Department. As such, planning permission should not be refused on the basis of noise emissions.

CAM-G-RL-2, Safer Neighbourhoods
Typical Worst-Case Night-Time Background Noise (L_{90}) Values





Site Plan

Figure 3742/SP1

1 October 2009

CAM-G-RL-2, Safer Neighbourhoods,
179 West End Lane, London

Not to Scale

RBA 
richardsonbladonandersen
ACOUSTICS

104 The Foundry Annexe, 65 Glasshill St, London SE1 0QR
Telephone: 020 7953 7233 Facsimile: 020 7953 7236

CAM-G-RL-2 Safer Neighbourhoods

Outdoor Units

		63	125	250	500	1k	2k	4k	8k	dBA
SUZ-KA50VA										
SPL at 1m	Heating mode	60	63	56	54	49	43	40	38	55

To Rear Windows of Flat at Second Floor Level above Safer Neighbourhoods Office

Unit 1

SUZ-KA50VA	reflections from back + side wall	6	6	6	6	6	6	6	6	
Distance to Residential Window at 2nd Floor	9.9m									
Distance Correction		19.9	19.9	19.9	19.9	19.9	19.9	19.9	19.9	
Screening		5.2	5.5	5.9	6.7	8.0	10.0	12.5	15.4	0.04m path length difference assumed due to balcony of 2nd floor flat
SPL at Receiver		40.8	43.6	36.2	33.4	27.1	19.1	13.6	8.7	35 dBA

To Rear Windows of Flat at Second Floor Level above Safer Neighbourhoods Office

Unit 2

SUZ-KA50VA	reflection from back wall	5	5	5	5	5	5	5	5	
Distance to Residential Window at 2nd Floor	9.9m									
Distance Correction		19.9	19.9	19.9	19.9	19.9	19.9	19.9	19.9	
Screening		5.2	5.5	5.9	6.7	8.0	10.0	12.5	15.4	0.04m path length difference assumed due to balcony of 2nd floor flat
SPL at Receiver		39.8	42.6	35.2	32.4	26.1	18.1	12.6	7.7	34 dBA

Total	43.4	46.2	38.7	35.9	29.6	21.6	16.1	11.2	37	dBA
--------------	------	------	------	------	------	------	------	------	----	-----

Add 3dB for Façade Reflections	46.4	49.2	41.7	38.9	32.6	24.6	19.1	14.2	40	dBA
---------------------------------------	------	------	------	------	------	------	------	------	----	-----
