

Mark Kelly
QMP
Spratton Road
Brixworth
NORTHAMPTON
NN6 9DS

Application Ref: **2009/4198/P**
Please ask for: **Aysegul Olcar-Chamberlin**
Telephone: 020 7974 **6374**

24 November 2009

Dear Sir

DECISION

Town and Country Planning Acts 1990 (as amended)
Town and Country Planning (General Development Procedure) Order 1995
Town and Country Planning (Applications) Regulations 1988

Full Planning Permission Granted

Address:
**School of Oriental & African Studies
Thornhaugh Street
Russell Square
LONDON**

Proposal:
Installation of 2 x Daikin RXYQ24P condensing units to the rooftop of the building (Class D1).

Drawing Nos: M4858/A/004B; 4941/MP201 A; 090323-M03; Details of Daikin RXYQ24P condenser (manufacturer's specification); Environmental Noise Survey Report dated 6th July 2009 by Hann Tucker Associates (Acoustic Consultant); and the letter dated 26th October by Hann Tucker Associates.

The Council has considered your application and decided to grant permission subject to the following conditions:



Conditions and Reasons:

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies B1 and B7 of the London Borough of Camden Replacement Unitary Development Plan 2006.

- 3 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment are in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the [adjoining] premises [and the area generally] in accordance with the requirements of policies SD6, SD7B, SD8 and Appendix 1 of the London Borough of Camden Replacement Unitary Development Plan 2006.

Informatives:

- 1 Reasons for granting permission.

The proposed development is in general accordance with the policy requirements of the London Borough of Camden Replacement Unitary Development Plan 2006, with particular regard to policies SD1 (quality of life), SD6 (amenity of occupiers and neighbours), SD7B (noise/vibration pollution), SD8 (disturbance), B1 (general design principles), B3 (alterations and extensions), B6 (listed building), B7 (conservation areas), and Appendix 1 (noise and vibration thresholds). For a more detailed understanding of the reasons for the granting of this planning permission, please refer to the officers report.

- 2 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 2363).
- 3 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to

Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Planning and Public Protection Division (Compliance and Enforcement Team), Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 5613 or by email ppp@camden.gov.uk or on the website www.camden.gov.uk/pollution) or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

Disclaimer

This is an internet copy for information purposes. If you require a copy of the signed original please contact the Culture and Environment Department on (020) 7974 5613