



## NOTES

- This drawing shall be read in conjunction with all Mechanical and Electrical drawings, Schedules and Specification.
- Pipework routes through floor joists to be confirmed with structural engineer prior to any notching on site.
- All pipework penetrations through any structure to be sleeved with oversized tube of same material.
- Domestic Water Services shall be installed in accordance with Water Supply (Water Fittings) Regulations 1999
- All draw off's to be fitted with ballcock valve.
- All high points to be provided with air vents & all low points to be provided with drain cocks.
- All pipework to be thermally insulated in accordance with BS 5422 except for final connections to appliances where it shall be painted by others to Architect's detail.
- Contractor to site measure locations of plant prior to ordering.
- Contractor to allow for on site co-ordination with the structure and other services and the production of fully dimensioned working drawings prior to installation.
- For valving arrangements refer to schematic drawings.

## Legend

R.T.A: Rise To Above  
 D.T.L.L: Drop To Low Level  
 C.V: Ceiling Void  
 F&R: Flow & Return  
 T.A: To Above  
 F.B: From Below  
 L.L: Low Level

- Pipework at low level.
- Pipework in floor.
- Pipework at high level.
- Pipework in ceiling void.

P1	12.05.09	Preliminary Issue
rev	date	description

**m k p**  
 consultants ltd  
 Units 2&3, Burcot Farm  
 East Stratton, Winchester  
 Hants, SO21 3DZ  
 Tel: 01962 774665 Fax: 01962 774724 E-mail: info@mkpg.com  
 Building Services  
 Consultants

Client  
**Birkbeck College**  
 University of London  
 Department of Estates and Facilities  
 Malet Street  
 London WC1E 7HX  
 Tel: 0171 631 6015  
 Fax: 0171 631 6019

Project Title  
**39-47 GORDON SQUARE  
 BIRKBECK COLLEGE  
 LPHW HEATING SYSTEM**

Drawing Title  
**FIRST FLOOR  
 PROPOSED HEATING  
 LAYOUT**

Drawn SJL	Date OCT '08	Checked	Approved
--------------	-----------------	---------	----------

Scale 1:100	Size <input type="radio"/> A4 <input type="radio"/> A3 <input checked="" type="radio"/> A1 <input type="radio"/> A0	Issue <input checked="" type="radio"/> Preliminary <input type="radio"/> Tend <input type="radio"/> Construction
----------------	---	--

Org. No. **2188-M-027** Rev **P**