

Retrigeration & Assistantialoung Services

Tim Burford Design LSM The Bath House 58 Livingstone Road Hove BN3 3WL

13th August 2009

Dear Tim

Re: Mechanical Scheme for 170/171a Drury Lane

Retail/Café Area

Air Conditioning

It is proposed we install 2no ducted systems comprising of one outdoor condensing unit to be mounted at high level in the service yard, replacing the existing unit, which is currently in situ. The system is inverter driven and provides both cooling and heating and is compliant with Part L2B Building Regulations.

Fresh Air Supply

The current Fresh Air supply is taken from the louvre above the shop front. We propose to reuse the louvre and bring the air supply directly through the ducted air-handling units giving 12 litres per second, per person.

Restaurant

Air Conditioning

It is proposed we install 2no ducted systems comprising of one outdoor condensing unit to be mounted at high level in the service yard, replacing the existing unit, which is currently in situ. The system is inverter driven and provides both cooling and heating and is compliant with Part L2B Building Regulations.

> **FWP UK LTD** 4 Grantham Road, Radcliffe On Trent, Nottingham, NG12 2DR

Tel: 0115 933 3268 Fax: 0115 933 3268

E-mail: info@fwp-air-conditioning.co.uk Web: www.fwp-air-conditioning.co.uk

Registered Address: Venture House, Cross Street, Arnold, Nottingham, NG5 7PJ, Company Number: 4230912, VAT Registration Number: 803952433





Kitchen Extract Ducting

We propose to run the kitchen extract ducting from the kitchen area to the service yard. Following a thorough site survey, the only route to the service yard is through an area marked on the drawing as no access available to this area, however, there is an access panel in the wall to this area which we opened whilst on site and found if we could install a door, as marked on our drawings, we could access this area and run the kitchen extract ducting to a point of discharge.

We have included carbon filters and attenuators to reduce noise and odour in the kitchen extract ducting.

Toilet Extract

The toilet extract is sized to give 12 air changes per hour and will follow the kitchen extract to the point of discharge.

Kitchen Supply Air

We propose to reuse the existing fresh air supply and re-route to the kitchen area, installing a new motor filter section and attenuation.

Should you require any further clarification on specification, please do not hesitate to contact me

Regards Stuart Frudd FWP UK Ltd