

Quantech Environment Limited  
Quantech House  
Star Lane Industrial Estate  
Great Wakering  
Essex  
SS3 0PJ

Application Ref: **2009/0805/P**  
Please ask for: **Katrina Christoforou**  
Telephone: 020 7974 **5562**

2 July 2009

Dear Sir/Madam

## **DECISION**

Town and Country Planning Acts 1990 (as amended)  
Town and Country Planning (General Development Procedure) Order 1995  
Town and Country Planning (Applications) Regulations 1988

### **Full Planning Permission Granted**

Address:  
**95 Hatton Garden  
London  
EC1N 8NX**

Proposal:  
Installation of two condensing units in the rear courtyard at ground/basement level in association with the existing shop.

Drawing Nos: Site Location Plan Rev A; QE7518-01 B; 02B; Environmental Noise Level & Plant Noise Analysis Dated 03/02/09.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.



Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment are in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the neighbouring residential premises in accordance with the requirements of policies SD6, SD7B, SD8 and Appendix 1 of the London Borough of Camden Replacement Unitary Development Plan 2006.

- 3 The air-conditioning units hereby approved shall not be in operation outside of the hours of 08:00-19:00 on any given day in accordance with the 'Environmental Noise Level and Plant Assessment' hereby approved.

Reason: To protect the amenity of residential neighbours in accordance with policies SD6, SD7 & SD8 of the London Borough of Camden Replacement Unitary Development Plan 2006.

Informative(s):

- 1 Reasons for granting permission.

The proposed development is in general accordance with the policy requirements of the London Borough of Camden Replacement Unitary Development Plan 2006, with particular regard to policies SD1, SD6, SD7, SD8, B1, B3 & B7. For a more detailed understanding of the reasons for the granting of this planning permission, please refer to the officers report.

- 2 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 2363).
- 3 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Environmental Health Service, Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 2090 or by email [env.health@camden.gov.uk](mailto:env.health@camden.gov.uk) or on the website [www.camden.gov.uk/pollution](http://www.camden.gov.uk/pollution)) or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

**Disclaimer**

***This is an internet copy for information purposes. If you require a copy of the signed original please contact the Culture and Environment Department on (020) 7974 5613***