

APPLICATION REFERENCE 2004/1953/P

DATED 30TH SEPTEMBER 2004 FOR
264 - 267 TOTTENHAM COURT ROAD, LONDON. W1T 7RQ

INFORMATION INCLUDED TO DISCHARGE PLANNING CONDITIONS FOR RETAIL UNIT C, AT GROUND FLOOR AND BASEMENT, AT THE ABOVE DEVELOPMENT TO BE GARFUNKELS RESTAURANT.

- 1) The application form for discharge of conditions
- 2) The site location plan
- 3) Drawings C01-01 F (ground floor HVAC) and C01-2 E (basement HVAC), by Chapman Ventilation, showing the proposed mechanical services to the unit.
- 4) Details of the type of kitchen extract canopy to be installed within the basement kitchen, i.e. 'Halton KVF Capture Jet'
- 5) Data sheet for the type of grease filters to be incorporated within the kitchen extract canopy, i.e. 'Halton KSA Multi-Cyclone' filters.
- 6) Specification data for the air purification system to be incorporated into the kitchen extract. This will include UV treatment to eliminate odours and treatment of grease, with 2 passes over electrostatic precipitators to remove smoke.
- 7) Letter and quote from NSL confirming the specification of the silencers to be fitted to the supply and extract systems located within the basement. Please note that no mechanical services plant for this unit is located outside of the ground and basement demise.
- 8) Developers shell drawings C3480/M8 A and C3480/M9 A, showing the location of the roof top outlets. Please note that these outlets and the interconnecting ducts rising from the ground floor and basement have been supplied and fitted by the shell developer, and we therefore assume, previously submitted for planning consent.