

Mr C Wilson
University College London
Estate & Facilities Division
Gower Street
London
WC1E 6BT

Application Ref: **2008/5200/P**

Please ask for: **Aysegul Olcar-Chamberlin**

Telephone: 020 7974 **6374**

10 March 2009

Dear Sir/Madam

DECISION

Town and Country Planning Acts 1990 (as amended)

Town and Country Planning (General Development Procedure) Order 1995

Town and Country Planning (Applications) Regulations 1988

Full Planning Permission Granted

Address:

University College London

Roberts Building

Torrington Place

London

WC1E 7JE

Proposal:

Increase in height of fumes cupboard extract stacks at roof level and associated works.

Drawing Nos: 045-051-01; 02; 03; 04; 05; and 06.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and



Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies S1/ S2, B1 and B7 of the London Borough of Camden Replacement Unitary Development Plan 2006.

- 3 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment are in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the [adjoining] premises [and the area generally] in accordance with the requirements of policy[ies SD6 [, SD7B, SD8 and Appendix 1] of the London Borough of Camden Replacement Unitary Development Plan 2006.

Informative(s):

- 1 Reasons for granting permission.

The proposed development is in general accordance with the policy requirements of the London Borough of Camden Replacement Unitary Development Plan 2006, with particular regard to policies S1/S2, SD6, B1, B3, and B7. For a more detailed understanding of the reasons for the granting of this planning permission, please refer to the officers report.

- 2 This permission is only for increasing the height of the fume extractors shown in the approved drawings. Any further alterations or additions to the roof profile require submission of a new planning application.
- 3 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 2363).
- 4 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Environmental Health Service, Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 2090 or by email env.health@camden.gov.uk or on the website www.camden.gov.uk/pollution) or seek prior approval under Section 61 of the Act

if you anticipate any difficulty in carrying out construction other than within the hours stated above.

Disclaimer

This is an internet copy for information purposes. If you require a copy of the signed original please contact the Culture and Environment Department on (020) 7974 5613