



## ROOFING GENERALLY

Check all lead flashings to party wall, chimney stacks, dormers and eaves and take up and replace as necessary

All new leadwork to be in code 4, to be laid on new polythene vapour barrier tucked into all up-stands by minimum 150 mm

All flashings to brickwork to be dressed into masonry by minimum 50 mm and minimum 150 mm above roof finish. All gaps and joints to be sealed with bituminous mastic sealant

All dormers to be lined in 1000 gauge Polythene vapour barrier taped and sealed before re-clad in lead. All overlaps to be minimum 150 mm and joints to be folded seams

Rev. B: 19.12.08

New flat roof extension (bathroom below)

Rev. A: 20.10.08

Dolmer window on side elevation (change position)

**Martin Evans**  
Architects @

18 Charlotte Road  
London EC2A 3PB  
tel 020 7729 2474

## JOB

105 South Hill Park  
NW3 2SP, LONDON

**TITLE**  
PROPOSED PLAN  
ROOF FLOOR

DATE 19.12.08

SCALE 1:50 @ A3

DRAW BY R.M.

DRAWING NO. SH105-PL-GA-07-B