



ENVIRONMENT DEPARTMENT

London Borough of Camden
Camden Town Hall
Argyle Street
London WC1H 8EQ

Tel 0171 - 278 4444

Fax 0171 - 860 5556

Our Reference: PL/9501832/

Case File No: N12/8/A

Tel.Inqu:

John Davies

ext. 5885

Date: 14 Dec 05

none sent

Dear Sir(s)/Madam,

Town and Country Planning Act 1990

Town and Country Planning General Development Procedure Order 1995

Town and Country Planning (Applications) Regulations 1988

Re: British Telecom Tower, 60 Cleveland Street, W1.

Proposal: Alterations to the Maple Street elevation comprising the replacement of glazing in three windows with louvres at second floor level.

as shown on drawing numbers 6653/P/10 to /15.

Thank you for your observations submitted to the Council in respect of the above application. Your comments were reported to the Committee and considered when the application was decided.

I would advise you that the following decision was made:-

Grant permission

Condition(s):

- 01 Noise from the operation of the plant/structures associated with the works shall not exceed the existing ambient background noise level, in particular at night, and for that reason should be less than the background level by at least 5 dBA when measured at a point 1 metre external to the nearest residential accommodation.
- 02 Noise emanating due to the operation of Air treatment plant system shall be at least 5 dBA below the existing background noise level and 10 dBA below the existing background noise level in case of tonal noise.

Reason(s) for Condition(s):

- 01 In order to safeguard the amenities of the adjoining occupiers.
- 02 In order to safeguard the amenities of the adjoining occupiers.



ENVIRONMENT DEPARTMENT

London Borough of Camden
Camden Town Hall
Argyle Street
London WC1H 8EQ

Tel 0171 - 278 4444

Fax 0171 - 860 5556

(Cont.)

(Our Reference: PL/9501832/)
(Case File No: N12/8/A)

Yours faithfully,

Director,
Environment Department