

EPR Architects Limited  
Mr. S. Coates (Ref: SC/EW/8406)  
21 Douglas Street  
LONDON  
SW1P 4PE

Our Reference: PL/9500188/  
Case File No: N13/28/A  
Tel. Inqu:  
Kathy Blair ext. 2537

Date: 31 MAR 1995

Dear Sir(s)/Madam,

Town and Country Planning Act 1990  
Town and Country Planning General Development Order 1988 (as amended)  
Town and Country Planning (Applications) Regulations 1988

Permission for Development

The Council, in pursuance of its powers under the above-mentioned Act and Orders and Regulations made thereunder, hereby permits the development referred to in the undermentioned Schedule subject to the conditions set out therein and in accordance with the plans submitted, save insofar as may otherwise be required by the said conditions.

Your attention is drawn to the Appeal Rights and other information at the end of this letter.

SCHEDULE

Date of Original Application : 3rd February 1995

Address : 10-11 Percy Street, W1.

Proposal : Installation of five air conditioning condenser units on the roof.  
as shown on drawing numbers 610.244.01/A/01/T,  
8406/PA/19, /38B and /39A.

Standard Condition:

1. The development hereby permitted must be begun not later than the expiration of five years from the date of this permission.

Reason for Standard Condition:

1. In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990.

Additional Condition(s):

- 01 No process shall be carried on or machinery installed which is not such as could be carried on or installed in any residential area without detriment to the amenity of that area by reason of noise, vibration, smell, fumes, smoke, soot, ash, dust or grit.
- 02 Noise from the operation of the plant shall not exceed the existing ambient background noise level, in particular at night, and for that reason should be less than the background level by at least 5dB(A).


Reason(s) for Additional Condition(s):

(Cont.)

( Our Reference: PL/9500188/ )  
( Case File No: N13/28/A )

- 01 To safeguard the amenities of the adjoining premises and the area generally.
- 02 To safeguard the amenities of the adjoining premises and the area generally.

Yours faithfully,

  
Director,  
Environment Department

(Duly authorised by the Council to sign this document)

\*\*\*\*\*

STATEMENT OF APPLICANTS RIGHTS ARISING FROM REFUSAL OF PLANNING  
PERMISSION OR GRANT OF PERMISSION SUBJECT TO CONDITIONS.

Appeals to the Secretary of State.

If you are aggrieved by the decision of your local planning authority to refuse permission for the proposed development or to grant it subject to conditions, then you may appeal to the Secretary of State for the Environment under Section 78 of the Town and Country Planning Act 1990. If you want to appeal then you must do so within six months of the date of this notice, using a form which you can get from the Department of the Environment at Tollgate House, Houlton Street, Bristol BS2 9DJ. The Secretary of State can allow a longer period for giving notice of an appeal, but he will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.

The Secretary of State need not consider an appeal if it seems to him that the local planning authority could not have given planning permission for the proposed development or could not have granted it without the conditions it imposed, having regard to the statutory requirements, to the provisions of the development order and to any directions given under the order. In practice, the Secretary of State does not refuse to consider appeals solely because the local planning authority based its decision on a direction given by him.



ENVIRONMENT DEPARTMENT

London Borough of Camden  
Camden Town Hall  
Argyle Street  
London WC1H 8EQ

Tel 071 - 278 4444

Fax 071 - 860 5556

① CSA

Our Reference: PL/9500188/  
Case File No: N13/28/A  
Tel.Inqu:  
Kathy Blair ext. 2537

Date: 31 MAR 1995

Dear Sir(s)/Madam,

Town and Country Planning Act 1990  
Town and Country Planning General Development Order 1988 (as amended)  
Town and Country Planning (Applications) Regulations 1988

Re: 10-11 Percy Street, W1.

Proposal: Installation of five air conditioning condenser units on  
the roof.  
as shown on drawing numbers 610.244.01/A/£01/T,  
8406/PA/19, /38B and /39A.

Thank you for your observations submitted to the Council in respect  
of the above application. Your comments were reported to the Committee  
and considered when the application was decided.  
I would advise you that the following decision was made:-

Grant permission

Condition(s):

- 01 No process shall be carried on or machinery installed which is not such  
as could be carried on or installed in any residential area without  
detriment to the amenity of that area by reason of noise, vibration,  
smell, fumes, smoke, soot, ash, dust or grit.
- 02 Noise from the operation of the plant shall not exceed the existing  
ambient background noise level, in particular at night, and for that  
reason should be less than the background level by at least 5dB(A).

Reason(s) for Condition(s):

- 01 To safeguard the amenities of the adjoining premises and the area  
generally.
- 02 To safeguard the amenities of the adjoining premises and the area  
generally.

