

FILE



ENVIRONMENT

London Borough of Camden  
Town Hall  
Argyle Street  
London WC1H 8EQ

Tel 0171 278 4444  
Fax 0171 860 5713

M.Herman,  
4 Avondale Crescent,  
Redbridge,  
Ilford,

Application No: P9600916R1  
Case File:P14/17/A

26th July 1996

Dear Sir(s)/Madam

**DECISION**

Town and Country Planning Act 1990  
Town and Country Planning (General Development Procedure)  
Order 1995  
Town and Country Planning (Applications) Regulations 1988

PERMISSION FOR DEVELOPMENT - Subject to Conditions

Address :  
Commonwealth House, 1-3 New Oxford Street, WC1

Date of Application : 10/06/1996

Proposal :

**Installation of louvre grilles to ground floor on High  
Holborn elevation,  
as shown on drawing numbers 1B and 2B.**

The Council has considered your application and decided to grant permission subject to the following conditions:

Standard condition:

The development hereby permitted must be begun not later than the expiration of five years from the date of this permission.

Standard Reason:

In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990.

Additional conditions:

- 1 Noise from the operation of the plant shall not exceed the existing ambient background noise level, and for that reason should be less than the background level by at least 5 dB(A). Plant and equipment shall be designed or acoustically treated to ensure that levels of noise received at a point one metre from the facade of sensitive buildings

Director Mark Gilks BA(Hons),M.Soc.Sc.,MRTPI

London Borough of Camden  
Town Hall  
Argyle Street  
London WC1H 8EQ

Tel 0171 278 4444  
Fax 0171 860 5713

is at least 5 dB(A) below existing background levels LA(90) at the most sensitive period. If the plant or equipment has a tonal quality (concentrated level at certain frequencies) or is of an intermittent/impulsive quality the level shall be at least 10 dB(A) below existing background levels LA(90).

Reasons for additional conditions:

- 1 To safeguard the amenities of the adjoining premises and the area generally.

This application was dealt with by Kathy MacEwen on 0171 278 4444 EXT.2537.

Your attention is drawn to the notes attached to this notice which tell you about your Rights of Appeal and other information.

Yours faithfully



Environment Department  
(Duly authorised by the Council to sign this document)

DecfplanWC/TPFU