

Mr. J. Wallace,
Estates Services Department,
T6, G3, CAA House,
45-59 Kingsway,
London, WC2B 6TE.

Our Reference: PL/9501177/
Case File No: P15/5/A
Tel. Inqu:
Kathy Blair ext. 2537

Date: 25 AUG 1995

Dear Sir(s)/Madam,

Town and Country Planning Act 1990
Town and Country Planning General Development Procedure Order 1995
Town and Country Planning (Applications) Regulations 1988

Permission for Development

The Council, in pursuance of its powers under the above-mentioned Act and Orders and Regulations made thereunder, hereby permits the development referred to in the undermentioned Schedule subject to the conditions set out therein and in accordance with the plans submitted, save insofar as may otherwise be required by the said conditions.

Your attention is drawn to the Appeal Rights and other information at the end of this letter.

SCHEDULE

Date of Original Application : 28th June 1995

Address : CAA House, 45-59 Kingsway, WC2.

Proposal : Installation of attenuators to existing chiller units and erection of acoustic screening, as shown on drawing numbers 1397/SK1A, 2, 3, 1E/32101/8.A.

Standard Condition:

1. The development hereby permitted must be begun not later than the expiration of five years from the date of this permission.

Reason for Standard Condition:

1. In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990.

Additional Condition(s):

- 01 The noise emanating due to the operation of the chiller unit system shall be at least 5 dB(A) below the existing background noise level and 10dB(A) below the existing noise level in the case of tonal noise.

Reason(s) for Additional Condition(s):

- 01 To safeguard the amenities of the adjoining premises and the area generally.