




Support services team



For the attention of Charles Thuaire Esq
Development Control Planning Services
London Borough of Camden
Town Hall
Argyle Street
London
WC1H 8ND

Approval of details
(Condition 2)
2008/1252/P

Our Ref: 2602/178/NFR

3rd March 2008

Dear Sir

**RE: TOWN AND COUNTRY PLANNING ACT 1990 CONDITION 2 -
APPLICATION REF: 2005/3652/P - 8A MEDLEY ROAD, NW6 - SITE
PLAN TRIAL PITS**

Further to our conversation I confirm that the isolated contamination as highlighted within the ground report was removed from site to a registered waste tip for hydrocarbons.

The level of the concrete footings at 2.00 m deep in that area is below that of the contamination at 1.40 m and as such has been completely removed. Ground levels were reduced by 600 mm and more, and a retaining wall introduced. In any event the whole site is hard landscaped with no planting.

We have already discussed this with Colin Stapleton and I trust this letter is acceptable to allow the condition to be removed and Building Control sign off to be made.

Yours faithfully

A handwritten signature, likely of N Mistry, written in dark ink.

PR N Mistry
FOR AND ON BEHALF OF
LAD CONSTRUCTION LIMITED

Enc

LAD CONSTRUCTION LIMITED
VITHAL HOUSE, 16 GORST ROAD, PARK ROYAL, LONDON NW10 6LE
Tel: 020-8961 1342 FAX: 020-8961 1649