

Maverick Television
40 Churchway
London
NW1 1LW

Application Ref: **2007/4283/P**

Please ask for: **Hugh Miller**

Telephone: 020 7974 **2624**

05 February 2008

Dear Sir/Madam

DECISION

Town and Country Planning Acts 1990 (as amended)

Town and Country Planning (General Development Procedure) Order 1995

Town and Country Planning (Applications) Regulations 1988

Full Planning Permission Granted

Address:

40 Churchway

London

NW1 1LW

Proposal:

Installation of an additional 3 no. air conditioning units on the roof of the ground floor rear extension of existing office (B1 use).

Drawing Nos: Drawing No, T3163 02; MAV003; MAV004; MAV005; MAV006; MAV007; MAV008; MAV009; MAV010; T3163 01; Proposed Installation of New Air Conditioning Units File Ref: 14603;

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.



Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment are in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies SD6, SD7B, SD8 and Appendix 1 of the London Borough of Camden Replacement Unitary Development Plan 2006.

- 3 Automatic time clocks shall be fitted to the equipment/machinery hereby approved, prior to commencement of the use of the units, to ensure that the plant/equipment does not operate between 19:00 hrs and 07:00 hrs. The timer equipment shall be properly maintained and retained permanently thereafter.

Reason:- To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies SD6, SD7B, SD8, Appendix 1 of the London Borough of Camden Replacement Unitary Development Plan 2006.

Informative(s):

- 1 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Environmental Health Service, Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 2090 or by email env.health@camden.gov.uk or on the website www.camden.gov.uk/pollution) or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

- 2 Reasons for granting permission.

The proposed development is in general accordance with the policy requirements of the London Borough of Camden Replacement Unitary Development Plan 2006, with particular regard to policies B1, B3, SD6 and SD7. For a more detailed understanding of the reasons for the granting of this planning permission, please refer to the officers report.

Disclaimer

This is an internet copy for information purposes. If you require a copy of the signed original please contact the Culture and Environment Department on (020) 7974 5613