

Young-Harry Songo  
Tube Lines Ltd  
5th Floor, Desk 025  
15 Westferry Circus  
Canary Wharf  
LONDON  
E14 4HD

Application Ref: **2007/4947/L**  
Please ask for: **Joanna Ecclestone**  
Telephone: 020 7974 **2078**

01 February 2008

Dear Sir/Madam

## **DECISION**

Planning (Listed Building and Conservation Areas) Act 1990  
Planning (Listed Buildings and Conservation Areas) Regulations 1990

### **Approval of Details (Listed Building) Granted**

Address:  
**Mornington Crescent Underground Station**  
**Millbrook Place**  
**London**  
**NW1 2JA**

Proposal:  
Details of specifications and finishes pursuant to conditions 2 (a-c) of the listed building consent dated 07/08/06 (2006/2704/L) for internal and external refurbishment and alterations.

Drawing Nos: Faience and Terracotta Conservation & Repair Document ref TLL-L001-N418-ENG-MNL-00001; Generic Stone/Concrete/Quarry/Ceramic Tiling/Mosaic ref. NBS Specification M40; Tiling and Tactile Paving ref. M40F; Product Method Statement - Cleaning and Repair to external faience facade to front and side elevations off hydraulic platforms pages 1-14; NBS Specification C39 Generic Cleaning Specification

The Council has considered your application and decided to approve the submitted details.



Informative(s):

- 1 You are advised that any plastic or cold resin repairs to tiles are generally unacceptable in principal due to the visual impact. Whilst the works of making good to the existing plastic repairs have been carried out adequately, this is not considered to be an appropriate approach and we would normally require the full replacement of all damaged tiles with an agreed matching tile. We advise that in specifying methods for similar future works then advice should be sought from the Conservation Team at the London Borough of Camden at an early stage, and in any event prior to works being carried out.
- 2 You are advised that there are no outstanding conditions attached to listed building consent ref. no. 2006/2704/L that require submission of details to the Council for approval.

**Disclaimer**

***This is an internet copy for information purposes. If you require a copy of the signed original please contact the Culture and Environment Department on (020) 7974 5613***