

Add area for
heat rejection louvre

ADDITIONAL
SPACE
REQUIRED
FOR G.H. UNITS.

CHILD
8

CHILD
9

CHILD
10

BARLOW HOUSE
- MULTI CHILD ARRANGEMENT!
13 H² UNITS

- EACH UNIT 2500x1200
- ACCESS 1000 ALL AROUND.
- SPACING 1500 BETWEEN.

CHILLER
COMPONENT

ACCESS SPACE
REQUIRED
FOR UNIT.

CHILD
1

CHILD
2

CHILD
3

CHILD
4

CHILD
5

CHILD
6

CHILD
7

8.6M

Add area
for intake/
discharge
ventilation.

