

Paul Griffiths  
Griffiths Design Consulting Ltd  
2 Manor Drive  
New Haw  
Weybridge  
SURREY  
KT15 3RJ

Application Ref: **2007/3242/P**  
Please ask for: **Victoria Lewis**  
Telephone: 020 7974 **3500**

13 September 2007

Dear Sir/Madam

## **DECISION**

Town and Country Planning Acts 1990 (as amended)  
Town and Country Planning (General Development Procedure) Order 1995  
Town and Country Planning (Applications) Regulations 1988

### **Full Planning Permission Granted**

Address:

**203 Eversholt Street  
London  
NW1 1BU**

Proposal:

Installation of external air conditioning condenser units in existing rear lightwell at lower ground floor level.

Drawing Nos: Site Location Plan PL29A; PL28; PL30; Plant Noise Assessment Report 2744/PNA; Daikin Technical Data; Covering Letter

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).



- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies B1, B3 and B6 of the London Borough of Camden Replacement Unitary Development Plan 2006.

- 3 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment are in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies SD1, SD6, SD7, SD8 and Appendix 1 of the London Borough of Camden Replacement Unitary Development Plan 2006.

Informative(s):

- 1 Reasons for granting permission.

The proposed development is in general accordance with the policy requirements of the London Borough of Camden Replacement Unitary Development Plan 2006, with particular regard to policies B1, B3, B6, SD1, SD6, SD7 and SD8. For a more detailed understanding of the reasons for the granting of this planning permission, please refer to the officers report.

**Disclaimer**

***This is an internet copy for information purposes. If you require a copy of the signed original please contact the Culture and Environment Department on (020) 7974 5613***