

Frixos Kyriacou
136 Sylvan Avenue
LONDON
N22 5JB

Application Ref: **2007/2322/P**
Please ask for: **Matthew Durling**
Telephone: 020 7974 **2643**

20 July 2007

Dear Sir/Madam

DECISION

Town and Country Planning Acts 1990 (as amended)
Town and Country Planning (General Development Procedure) Order 1995
Town and Country Planning (Applications) Regulations 1988

Full Planning Permission Granted

Address: **220 West End Lane**
London
NW6 1UU

Proposal: Erection of dormer window to the rear roof slope to provide additional accommodation for existing flat.

Drawing Nos: Site Location Plan; APT/0704/02; 04/A; 05A; 06A; 07/A.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).



- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies S1/S2, B1 and B7 of the London Borough of Camden Replacement Unitary Development Plan 2006.

Informative(s):

- 1 Reasons for granting permission.

The proposed development is in general accordance with the policy requirements of the London Borough of Camden Replacement Unitary Development Plan 2006, with particular regard to policies SD6, B1, B3 and B7. For a more detailed understanding of the reasons for the granting of this planning permission, please refer to the officers report.

- 2 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 2363).
- 3 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Environmental Health Service, Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 2090 or by email env.health@camden.gov.uk or on the website www.camden.gov.uk/pollution) or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.
- 4 For the avoidance of doubt, and in the light of the annotations on the site location plan, you are advised that this permission does not confer approval for the replacement of any timber windows on either the front or rear elevation of the building with uPVC.

Your attention is drawn to the notes attached to this notice which tell you about your Rights of Appeal and other information.

Yours faithfully

A handwritten signature in black ink, appearing to read 'Robert Scarfield'.

Culture and Environment Directorate
(Duly authorised by the Council to sign this document)

It's easy to make, pay for, track and comment on planning applications on line. Just go to www.camden.gov.uk/planning.