

St Pancras Almshouses
Southampton Road
LONDON
NW5 4HU

Application Ref: **2007/1054/L**
Please ask for: **Conor McDonagh**
Telephone: 020 7974 **5562**

29 May 2007

Dear Sir/Madam

DECISION

Planning (Listed Building and Conservation Areas) Act 1990
Planning (Listed Buildings and Conservation Areas) Regulations 1990

Listed Building Consent Granted

Address:
**St Pancras Almshouses
Southampton Road
London
NW5 4HU**

Proposal:

Installation of secondary glazing to timber sash windows and installation of UPVC windows to rear extension, security gates and disabled access ramps to residential dwellings.

Drawing Nos: Site plan; Appendix 1; 2; 4A; 4B; 5; 5A; 7A; 7B; 8C1; 8C2; 8D1; 8D2; 9/1; 9/2; 10B; 11; windows specifications; letter from Crime Officer.

The Council has considered your application and decided to grant Listed Building Consent subject to the following condition(s):

Conditions And Reasons:

- 1 The works hereby permitted shall be begun not later than the end of three years from the date of this consent.

Reason: In order to comply with the provisions of Section 18 of the Planning (Listed Buildings and Conservation Areas) Act 1990.



- 2 All new work and work of making good shall be carried out to match the original work as closely as possible in materials and detailed execution.

Reason: In order to safeguard the special architectural and historic interest of the building in accordance with the requirements of policy B6 of the London Borough of Camden Replacement Unitary Development Plan 2006.

- 3 A sample panel of the brickwork for the new ramps shall be provided on site and approved by the Council before the relevant parts of the works are commenced and the development shall be carried out in accordance with the approval given. The sample panel shall be retained on site until the work has been completed.

Reason: In order to safeguard the special architectural and historic interest of the building in accordance with the requirements of policy B6 of the London Borough of Camden Replacement Unitary Development Plan 2006.

- 4 Notwithstanding the drawings hereby approved, the proposed replacement of steel windows on the rear extension with UPVC double glazed windows has not been granted permission.

Reason: In order to safeguard the special architectural and historic interest of the building and conservation area in accordance with the requirements of policy B6 of the London Borough of Camden Replacement Unitary Development Plan 2006.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Environmental Health Service, Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 2090 or by email env.health@camden.gov.uk or on the website www.camden.gov.uk/pollution) or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

Disclaimer

This is an internet copy for information purposes. If you require a copy of the signed original please contact the Culture and Environment Department on (020) 7974 5613