

Mae Teh
Laser House
1320140 Goswell Road
LONDON
EC1V 7DY

Application Ref: **2006/5075/P**
Please ask for: **Bethany Arbery**
Telephone: 020 7974 **2077**

30 March 2007

Dear Sir/Madam

DECISION

Town and Country Planning Acts 1990 (as amended)
Town and Country Planning (General Development Procedure) Order 1995
Town and Country Planning (Applications) Regulations 1988

Full Planning Permission Granted

Address:

199 - 201 Haverstock Hill

London

NW3 4QG

Proposal:

Installation of 9 air conditioning units in acoustic enclosure at roof level in connection with first floor offices.

Drawing Nos: Environmental Noise Assessment by Acoustic Plus Ltd dated January 2007; 564_1ST_GA_AC/Site Location; 564_1ST_GA_AC/Roof Top_Section Existing A/C UNITS_roof top plan; 564_1ST_GA_AC/Roof Top Existing A/C UNITS_roof top plan; 564_1ST_GA_AC Roof Top_Section Proposed A/C UNITS_roof top plan Rev A; 564_1ST_GA_AC Roof Top_Proposed A/C UNITS_roof top plan Rev B; and Mitsubishi Specifications.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three



years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment are in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies SD6, SD7B, SD8 and Appendix 1 of the London Borough of Camden Replacement Unitary Development Plan 2006.

- 3 Notwithstanding the details shown on the drawings hereby approved, the acoustic screening shall be 1.5m in height. The screening shall be installed prior to the first operation of the air conditioning units hereby approved, and shall be retained and maintained for as long as the air conditioning units are in use.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies SD6, SD7B, SD8 and Appendix 1 of the London Borough of Camden Replacement Unitary Development Plan 2006.

Informative(s):

- 1 Reasons for granting permission.

The proposed development is in general accordance with the policy requirements of the London Borough of Camden Replacement Unitary Development Plan 2006, with particular regard to policies S1, S2, SD6, SD7(B), SD8(A), B1, B3 and B7. For a more detailed understanding of the reasons for the granting of this planning permission, please refer to the officers report.

- 2 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 3 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public

Holidays. You are advised to consult the Council's Environmental Health Service, Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 2090 or by email env.health@camden.gov.uk or on the website www.camden.gov.uk/pollution) or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

Disclaimer

This is an internet copy for information purposes. If you require a copy of the signed original please contact the Culture and Environment Department on (020) 7974 5613