

Memo

Approval of Details
(Pursuant to Condition 9)

2007/1265/P



Environmental Health Team
London Borough of Camden
Town Hall
Argyle Street
London WC1H 8EQ

Phone: 020 7974 2638
Fax: 020 7974 6955/5517
E-mail: env.health@camden.gov.uk

Date: 28/02/07
To: Adele Castle
From: Darren Beesley
Re: 58/59 Highgate West Hill – 2005/3591/P

Adele

I have reviewed the site investigation report and human health risk assessment for this development. I understand that you have been forwarded a copy separately. I consider that the investigation has been carried out appropriately and I agree with the recommendations of the report.

On the basis that there will be no soft landscaped areas incorporated into the final scheme I agree that no remediation measures are necessary.

If soft landscaped areas are included then the applicant should use a 600mm cover layer of clean imported soil to protect future users.

In addition the applicant should consult Thames Water on requirements for protecting incoming water services as suggested in the report.

I am able to recommend discharge of the condition on this basis. Should you need clarification please contact me on extension 2638.

Yours sincerely

A handwritten signature in black ink, appearing to read "D. Beesley".

Darren Beesley
Environmental Health Team
Tel: 020 7974 2638

RECEIVED
- 1 MAR 2007

Director: Peter Bishop