

**Swanepoel, Marilet**

---

**From:** Tim Buckingham [tim@studioe.co.uk]  
**Sent:** 03 October 2006 11:23  
**To:** Swanepoel, Marilet  
**Subject:** 1151 October Gallery  
**Importance:** High

Dear Marilet,

Thankyou for the email earlier this morning.

*Single Glazing could be used to the new entrance door vision panels in lieu of double glazing as suggested by the Conservation Officer.*

Attached is a sketch of the molding panel profile of the proposed new door at scale 1:2 as requested and numbered PL 019

We note the comment to the profile and material to the new lintel above the door opening and look forward to confirmation of your receipt of this information and recommendation of the scheme for approval.

Kind Regards

**Tim Buckingham**

For and on behalf of  
Studio E Architects  
Palace Wharf  
Rainville Road  
London W6 9HN  
T 020 7385 7126  
F 020 7381 4995  
www.studioe.co.uk

**ELECTRONIC INFORMATION TRANSFER - DISCLAIMER**

This email and any files transmitted with it are sent for and on behalf of Studio E Architects Ltd and are intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error please notify the sender

All attached files are copyright and may only be used for the purpose stated in the drawing status box. In the event that the files are altered in anyway it is a condition of use that the Studio E name and logo be removed from the modified file, unless prior written agreement has been obtained. Studio E will assume no responsibility for the accuracy, adequacy, and integrity of the files and recommends that the files be thoroughly screened for viruses prior to installation.

Opinions, conclusions and other information expressed in this message are not given or endorsed by Studio E Architects unless otherwise indicated by an authorised representative independent of this message

-----Original Message-----

**From:** Swanepoel, Marilet [mailto:Marilet.Swanepoel@camden.gov.uk]  
**Sent:** 03 October 2006 10:07  
**To:** Tim Buckingham  
**Subject:** October Gallery

Hi Tim,

I had a discussion with Hannah (design officer) this morning and she requested that the new door should be single glazing as double glazing would appear to modern for this listed building. Would you be able to confirm this in writing.


Furthermore, details are required of the moulding panels of the new door. Would you please email me

03/10/2006

2006/ 37 6 1/ P

01

## DETAIL PART ELEVATION




02

## DETAIL SECTION

Clear laminated safety glass 8mm thick

Hardwood profiled timber beading

Glazed Hardwood exterior grade timber door 54mm thick with hardwood timber frame.



## NOTE

1. THIS DRAWING IS COPYRIGHT STUDIO E ARCHITECTS LTD.
2. THE CONTRACTOR MUST NOT SCALE FROM THE DRAWING ALL DIMENSIONS TO BE TAKEN FROM DIMENSION STRINGS.
3. WHERE ANY DISCREPANCIES ARE FOUND BETWEEN DIMENSIONS THESE MUST BE BROUGHT TO THE ATTENTION OF THE ARCHITECTS FOR RESOLUTION.
4. WHERE DISCREPANCIES EXIST BETWEEN REFERENCE OR ASSEMBLY DRAWINGS & DETAIL DRAWINGS, THE LATTER TAKE PREFERENCE.

## FOR PLANNING

## STUDIO E ARCHITECTS LTD

Palace Wharf, Barnville Road,  
Luton, Wiltshire,  
Tel: 020 7385 7126  
Fax: 020 7381 4995

## OCTOBER GALLERY

PROJECT

PROPOSED ACCESS  
DOOR MOULDING  
PROFILE  
DRAWING

1:2@A3

SCALE

OCT 06

DATE

1151 PL19

DWG. NO.

X

REVISION

XX

CHECKED

2006/ 3761/ P