

TASK Displays LTD

6 Uxbridge Road, Melton Road, Leicester LE4 7ST
Telephone 0116 2663233 Fax 0116 2663234

Development Control
Planning Services
London Borough of Camden
Town hall
Argyll Street
London WC1H 8ND

REF. 24 Neal Street install of 4 number air-conditioning units

DESIGN AND ACCESS STATEMENT

The air-conditioning system as been designed to fit into the narrow ceiling voids and meet the cooling requirement of the shop they have also been chosen for there low noise output.

The logical area for the condensers is in the light well to the back of the shop where the units will be accessible from the shop without need to go through anyone else's premises
The position also offers the maximum distance away from any residential flat/house.

A separate noise report as been done to ensure that the units do not create any noise disturbance.

As the units are positioned in an enclosed light well to the back of the premises no public access is effected access to this area is only required for servicing of the units

The Systems Fitted Will Be.

1No Daikin RXS25
Sound Pressure Level = 47dBa
Sound Power Level = 62dBA
External unit size 765x550x285
Colour cream

1No Daikin RXS35
Sound Pressure Level = 48dBa
Sound Power Level = 63dBA
External unit size 765x550x285
Colour cream

2No Daikin RXS60
Sound Pressure Level = 49dBa
Sound Power Level = 64dBA
External unit size Size 820x735x300
Colour cream

