

Arundel house Development
BREEAM Industrial Pre-Assessment Estimator

UNITE
3rd August 2006

Prepared by:



Eleanor Hayes
Graduate Engineer

.....

Approved by:



Kevin Couling
Principal Engineer

.....

Rev No	Comments	Date
1		

Bush House, Prince Street, Bristol, BS1 4QD

Telephone: 0117 901 7000 Fax: 0117 901 7099 Website: <http://www.fabermaunsell.com>

Job No

Reference

Date Created 3rd August 2006

This contains confidential and commercially sensitive information, which shall not be disclosed to third parties.

document2

Table of Contents

1	Introduction	4
	1.1 General	4
2	Predicted Performance	5
	2.1 Predicted Performance	5
3	Pre-Assessment Estimator	6

1

Introduction

1.1

General

BREEAM Industrial seeks to minimise the adverse effects of new buildings on the environment at global and local scales, whilst promoting healthy indoor conditions for the occupants. The environmental implications of a new building are assessed at the design stage, and compared with good practice by independent assessors. An overall rating of the building's performance is given using the terms Pass, Good, Very Good or Excellent. This is determined from the total number of BREEAM criteria met in the eight BREEAM categories and their respective environmental weightings.

It is possible to make a reasonable prediction of the likely performance of a particular scheme in a full assessment by using the pre-assessment estimator. The estimator process uses a series of questions based on the full assessment credits and awards scores according to the anticipated performance of the building.

It must be understood that the estimator is only a guide to the likely performance of the scheme and should not be taken as a guarantee of full assessment performance due to the significant number of assumptions which are made in completing the process.

This assessment has been based on plan and elevation drawings and information received from Unite.

2 Predicted Performance

2.1

Predicted Performance

The predicted performance of the building is summarised below. Whilst reviewing the output of the estimator, it should be borne in mind that developments which take place in a poor location in BREEAM terms (such as those in rural locations on greenfield sites) tend to fare worse than those in better locations (such as those within the limits of a major urban conurbation, on brownfield sites etc).

	Topic	Likely
1.0	MANAGEMENT	11.67
2.0	HEALTH & WELLBEING	12
3.0	ENERGY	3.84
4.0	TRANSPORT	4.81
5.0	WATER	3
6.0	MATERIALS	6
7.0	LAND USE	6
8.0	POLLUTION	10
	Total Score	57.32 = VERY GOOD

The required score for an VERY GOOD rating is 55.

Based on past experience, it is worth aiming for a score above 55 in order to allow flexibility during the design development phase which often results in a reduction in the overall score when undertaking the formal assessment.

3 Pre-Assessment Estimator

The following pages summarise the output of the pre-assessment estimator and any assumptions that have been made.



Credit Reference	MANAGEMENT			
		With Offices	Without Offices	Points Achieved
M01	Where evidence provided demonstrates that an appropriate project team member has been appointed to monitor commissioning on behalf of the client to ensure commissioning will be carried out in line with current Building Regulations and (where applicable), best practice and where there are complex systems then a specialist agent or manager is appointed.	1.67	1.67	1.67
	Where in addition to the above evidence provided demonstrates that seasonal commissioning will be carried out during the first year of occupation, post construction (or post fit out).	3.33		
	NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.			
M04	Where evidence provided demonstrates that there is a commitment to comply with best practice site management principles.	1.67	1.67	
	OR Where evidence provided demonstrates that there is a commitment to go significantly beyond best practice site management principles.	3.33	3.33	3.33
	NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.			
M05	Where evidence provided demonstrates that			
	• 2 or more of items a-g, listed below are achieved.	1.67	1.67	
	OR			
	• 4 or more of items a-g, listed below are achieved.	3.33	3.33	3.33
	OR			
	• 6 or more of items a-g, listed below are achieved.	5		
	a) Monitor and report CO ₂ or energy arising from site activities. b) Monitor and report on water consumption from site activities. c) Monitor and report transport to and from site to enable CO ₂ emissions arising from transport to be calculated. d) Monitor construction waste on site. e) Sort and recycle construction waste on site. f) Adopt best practice policies in respect to air (dust) pollution. g) Adopt best practice policies in respect to water (ground and surface) pollution.			
	NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.			
	Where temporary timber is used on site during construction, this is from a sustainably responsible source OR is re-used or recycled.	1.67	1.67	1.67
M12	Where evidence provided demonstrates the provision of a simple guide that covers information relevant to the tenant/occupants and non-technical building manager on the operation and environmental performance of the building.	1.67	1.67	1.67



BREEAM Industrial 2006
Pre-Assessment Estimator
Fitted Out Buildings

Total points achieved to carry forward **11.67**

HEALTH & WELLBEING		With Offices	Without Offices	Points Achieved
Credit Reference				
HW01	Where at least 80% of floor area is adequately daylit.	2.14	3	0
HW04	Where evidence provided demonstrates that high frequency ballasts are installed on all fluorescent and compact fluorescent lamps.	2.14	3	3
HW05	<p>Where evidence provided demonstrates that all internal and external lighting, where relevant, is specified in accordance with the appropriate maintained illuminance levels (in lux) recommended by CIBSE.</p> <p>External Lighting - Lux levels must be specified in accordance with CIBSE Lighting Guide 6, 'The outdoor environment'. External areas that must comply include (where applicable):</p> <ul style="list-style-type: none"> covered and open pavement areas external circulation areas and entrances surface car parks (i.e. uncovered car parks) access roads (following the recommendations in BS5489 Part 1) [4] direction signs & notice boards outdoor work and storage areas bicycle racks delivery, refuse and rubbish areas garage forecourts subways, stairways and foot bridges cash machines Roadways, general movement (following the recommendations in BS5489 Part 1) Walkways, perimeter zones, security: Recreational and club sports: Sports facilities <p>Internal Lighting - Lux levels must be specified in accordance with part two of the 2002 Code for Lighting⁽¹⁾ and its 2004 Addendum.</p>	2.14	3	3
HW11	<p>Where evidence provided demonstrates that each space within the development achieves recommended minimum fresh air rates.</p> <p>Mechanical Ventilation For office areas fresh air should be provided at a rate of 12 litres per second per person. For operational areas fresh air should be provided at a rate of at least 8 litres per second per person. In the case of fully fitted out schemes (where the number of occupants is known) this should be based on actual occupancy. In the case of speculative schemes occupancy of 1 person per 10m² should be assumed.</p> <p>OR</p> <p>Natural Ventilation Where office or operational areas have been designed to be naturally ventilated, all of the following criteria should be achieved: Background ventilation to be in accordance with the Building Regulations Part F. The plan depth of building is less than 15m.</p>	2.14	3	3
HW16	Where evidence provided demonstrates that the risk of waterborne and airborne legionella contamination has been minimised.	2.14	3	3



BREEAM Industrial 2006
Pre-Assessment Estimator
Fitted Out Buildings

HW18	Where information provided demonstrates that office space within the development achieves best practice in terms of occupant comfort and control.		
	Three of the following measures must be achieved for at least 80% of the development's office space.	2.14	
	OR Five of the following measures must be achieved for at least 80% of the development's office space.	4.30	
	<p>NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.</p> <ul style="list-style-type: none"> • View Out - All work stations are situated a maximum of 7m away from a window or permanent opening providing a view. • Daylight glare control - Where an occupant controlled system of glare control, (e.g. internal or external blinds) is fitted on all windows. • Lighting zones - Separate zoned lighting controls provided. • Potential for natural ventilation - The openable window area in each room/floor plate should be equivalent to 5% of the gross internal floor area of that room/floor plate, and for accommodation over 7m deep openable windows are on opposite sides. • Internal air pollution - Air-conditioned and mixed-mode buildings: - Where locations of air intakes/outlets are over 10m apart to minimise recirculation AND intakes are over 20m from sources of external pollution or for naturally-ventilated buildings: Where location of openable windows/ventilators are over 10m from sources of external pollution. • Thermal zoning - where the heating / cooling system is designed to allow separate occupant control to be made of each perimeter area (i.e. within 7m of each external wall) and the central zone (i.e. over 7m from the external walls). • Thermal comfort - Thermal comfort levels must meet the requirements set out in CIBSE Guide A and feasibility studies aimed at optimising thermal comfort completed. • Acoustic performance - Indoor ambient noise level in unoccupied offices must be achieved. 		
Total points achieved to carry forward			12



ENERGY				
Credit Reference		With Offices	Without Offices	Points Achieved
E01	Where the building demonstrates a percentage improvement above the requirement for CO ₂ emissions as set out in the 2006 Building Regulations. • +1% • +2% • +4% • +6% • +8% • +10% • +12% • +14% • +18% • +22% • +30% • +40% • +50% • +60% • ≥70% Where fitted out units with unheated operational space are being assessed then the notional model must assume that the operational space has no heating source. NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.	0.96	0.96	1.92
		1.92	1.92	
		2.88	2.88	
		3.85	3.85	
		4.81	4.81	
		5.77	5.77	
		6.73	6.73	
		7.69	7.69	
		8.65	8.65	
		9.62	9.62	
		10.58	10.58	
		11.54	11.54	
		12.50	12.50	
		13.46	13.46	
		14.43	14.43	
		E03	Where evidence provided demonstrates sub-metering of energy use by areas is installed within each unit. This should cover the following areas as a minimum: • Office areas • Operational area • Ancillary areas (such as canteen etc)	
E04	Where 80% of external luminaires have an efficacy of at least 100 luminaire-lumens/circuit-Watts and all external light fittings are controlled through a time switch or daylight sensor to allow for daylight control.	0.96	0.96	0.96
E05	Where evidence is provided to demonstrate that the building has been designed and detailed to ensure optimum building fabric performance and to minimise unnecessary air infiltration.	0.96	0.96	0
Total points achieved to carry forward				3.84



TRANSPORT		With Offices	Without Offices	Points Achieved
Credit Reference				
T01	<p>The number of credits awarded is based on the proximity of the development to a public transport node with a good service frequency.</p> <ul style="list-style-type: none"> Where the transport node is within 800m with a frequent service of 30min intervals OR Where the transport node is within 500m with a frequent service of 30min intervals OR Where the transport node is within 800m with a frequent service of 15min intervals OR Where the transport node is within 500m with a frequent service of 15min intervals <p>NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.</p>	0.96	0.96	3.85
		1.92	1.92	
		2.88	2.88	
		3.85	3.85	
T05	<p>Where evidence is provided to demonstrate that there is adequate provision of covered, secure and well lit cycle racks and showers. Compliant cycle storage facilities must be provided for a percentage of building occupants in accordance with the following figures:</p> <ul style="list-style-type: none"> 10% of building occupants up to 500 PLUS 7% for building occupants in the range of 501 – 1000 PLUS 5% for building occupants over 1000 <p>Where in addition to the above, information is provided to demonstrate that there is adequate provision of changing facilities and lockers for clothes or a dedicated drying space for wet clothes.</p> <p>NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.</p>	0.96	0.96	0.96
		1.92	1.92	
T08	<p>Where evidence is provided to demonstrate that a travel plan has been developed and tailored to the specific needs of the users of the assessed development. The plan must include policies that address constraints, opportunities, targets and actions for the following:</p> <ul style="list-style-type: none"> walking; cycling; public transport; use of the private car for travel to work; mopeds/motorcycles; reducing the need to travel; visitors/customers; deliveries. 	0.96	0.96	0.96
T12	<p>Where evidence is provided to demonstrate that vehicle access areas have been designed to ensure adequate space for manoeuvring delivery vehicles, and provide space for storage of refuse skips and pallets.</p>	0.96	0.96	0
Total points achieved to carry forward				4.81



BREEAM Industrial 2006
Pre-Assessment Estimator
Fitted Out Buildings

WATER		With Offices	Without Offices	Points Achieved
Credit Reference				
W01	<p>Credits are awarded based on the improvement over standard specification of water fittings. A standard specification would include 6 litre flush toilets, urinals with no controls, a shower that uses 12-15 litres per minute, standard taps with no flow restrictors. In a formal BREEAM assessment the predicted water consumption will be calculated using the BREEAM water calculator, as a guide the following can be used as a rough estimate of likely number of credits achieved:</p> <ul style="list-style-type: none"> • where some of the fittings use less water than a standard fitting <p>OR</p> <ul style="list-style-type: none"> • where all of the fittings are low water OR, where only some of the fittings are low water, rainwater or grey water systems are specified. <p>OR</p> <ul style="list-style-type: none"> • where the water fittings are all low water AND rainwater or greywater fittings have been specified. <p>NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.</p>	1	1	2
		2	2	
		3	3	
W02	Where evidence is provided to demonstrate that a water meter with a pulsed output will be installed on the mains supply to each unit.	1	1	1
W03	Where evidence is provided to demonstrate that a leak detection system is specified or installed to each unit.	1	1	0
Total points achieved to carry forward				3



MATERIALS		With Offices	Without Offices	Points Achieved
Credit Reference				
MW01	<p>Where evidence provided demonstrates that the major building elements specified have an 'A rating', as defined in the <i>Green Guide to Specification</i>. In a formal BREEAM assessment the number of credits will be calculated using the BREEAM materials calculator, but as a guide the following can be used as a rough estimate of the likely number of credits achieved. The following elements are considered;</p> <ul style="list-style-type: none"> External Walls Roof <p>Credits are awarded for the external walls and roof building elements based on the percentages below</p> <ul style="list-style-type: none"> Where at least 50% of the external walls and the roof achieve an A rating in the Green Guide to Specification. <p>OR</p> <ul style="list-style-type: none"> Where at least 80% of the external walls and the roof achieve an A rating in the Green Guide to Specification. <p>NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.</p>	1	1	
		2	2	2
MW02	Where at least 80% of the combined area of external hard landscaping and boundary protection specifications achieve an A rating, as defined by the Green Guide to Specification.	1	1	1
MW06	<p>For new build: Where evidence provided demonstrates that a design reuses at least 80% of an existing primary structure and</p> <p>OR</p> <p>For part refurbishment and part new build: Where evidence provided demonstrates that the volume of the reused structure comprises at least 50% of the final structure's volume.</p>	1	1	1
MW07	Where significant use of crushed aggregate, crushed masonry or alternative aggregates (manufactured from recycled materials) is specified for 'high grade' aggregate uses (such as the building structure, ground slabs, roads, etc.).	1	1	
MW08	Where materials used in structural and non-structural elements are responsibly sourced.			
	For timber products this requires third party certification to show that the timber has come from a sustainably managed source and for non-timber products that the materials have EMS certification at either the process stage or the process and extraction phases.	2	2	



BREEAM Industrial 2006
Pre-Assessment Estimator
Fitted Out Buildings

MW10	<p>Where protection is given to vulnerable parts of the building such as areas exposed to high pedestrian traffic, vehicular and trolley movements.</p> <p>Suitable durability measures are listed below:</p> <ul style="list-style-type: none"> • Bollards/high kerbs to vehicle drop-off areas • Corridor walls specified to Severe duty (SD) as per BS 5234-2 • Rails to walls of corridors where trolleys will be used (i.e. Science accommodation) • Kick plates/impact protection on doors • Hard wearing and easily washable floor finishes in heavily used circulation areas (i.e. main entrance, corridors etc). 	1	1	1
MW12	<p>Where a central, dedicated storage space is provided for materials that can be recycled. This can be either within the building itself, or on site using skips, (provided there is good access for collections and it is within easy reach of the building).</p> <p>For fully fitted out units: The space provided should allow an external hardstanding area that is adequate to enable the occupier to recycle materials from the operational area(s) effectively PLUS at least 2m² per 1000m² of net office floor area (up to a maximum of 10m²).</p>	1	1	1
MW16	<p>Where evidence provided demonstrates that either a compactor or baler is provided for compacting/baling waste generated on site and</p> <ul style="list-style-type: none"> • A water outlet is provided for cleaning • The development achieves the BREEAM credit for recycling storage facilities (MW12) 	1	1	0
Total points achieved to carry forward				6



LAND USE & ECOLOGY				
Credit Reference		With Offices	Without Offices	Points Achieved
LE01	Where the footprint of the proposed development largely falls within the boundary of land previously developed.	1.5	1.5	1.5
LE02	Where land used for the new development has, prior to development, been defined as contaminated, and where adequate remedial steps have been taken to decontaminate the site prior to construction.	1.5	1.5	0
LE03	Where evidence is provided to demonstrate that the construction zone is defined as land of low ecological value and all existing features of ecological value will be fully protected from damage during site preparation and construction works.	1.5	1.5	1.5
LE04	<p>Credits are awarded based upon the degree of negative impact the new development has on the site's existing ecology. In a formal BREEAM assessment the ecological impact of the development is calculated based on the area of habitat and number of floral species displaced, using BREEAM's ecological value calculator. As a guide, the following can be used to estimate the likely number of credits:</p> <p>No credits can be awarded where the new development will displace a significant majority of the existing site's ecological habitat types and areas.</p> <p>Where a majority of the existing site's ecological habitat types and areas are not displaced as a result of the new development.</p> <p>Where either the development displaces none of the existing site's ecological habitat types and areas. Or, where there is no, or very limited existing site ecology; for example the new development is a refurbishment, or it is on contaminated land or Brownfield land that has been derelict/unoccupied for less than one year.</p> <p>NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.</p>			
		1.5	1.5	
		3	3	3
LE05	<p>Where evidence is provided to demonstrate that the design team (or client) has</p> <p>i) appointed a professional to advise and report on enhancing and protecting the ecological value of the site; AND</p> <p>ii) Implemented the professional's recommendations for general enhancement and protection for site ecology.</p> <p>OR</p> <p>Where, in addition to the above, evidence is provided to demonstrate a positive increase in the ecological value of the site of up to (but not including) 6 species.</p> <p>OR</p> <p>Where, in addition to the above, evidence is provided to demonstrate a positive increase in the ecological value of the site of 6 species or greater.</p> <p>NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.</p>	1.5	1.5	0
		3	3	
		4.5	4.5	

LE06	Where evidence is provided to demonstrate that the client has committed to achieving the mandatory requirements listed below and:			
	At least two of the additional requirements.	1.5	1.5	
	OR			
	At least four of the additional requirements.	3	3	0
	NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.			
	Mandatory Requirements			
	A suitably qualified ecologist must confirm in writing that:			
	<ul style="list-style-type: none">• All relevant UK and EU legislation relating to protection and enhancement of ecology has been, or will be, complied with during the design and construction process.• An appropriate management plan is produced covering at least the first 5 years after project completion. This should include details of the scope of the management plan.• Key responsibilities, and with whom these responsibilities lie, e.g. owner, landlord, occupier, FM, other.			
	Additional Requirements			
	<ul style="list-style-type: none">• A 'Biodiversity Champion' has been nominated• The relevant site work-force has been trained on how to protect site ecology during the project.• Record and monitor actions taken to protect biodiversity throughout key stages of construction• The client requires that a new ecologically valuable habitat, appropriate to the local area, be created.• The client requires the contractor to programme site works to minimise disturbance to wildlife.• The client requires actions to be taken to protect/enhance biodiversity• A Biodiversity Champion must have sufficient authority and time on site to influence activities and ensure that they have minimal detrimental impact on biodiversity• Local biodiversity expertise should be sought at, or before, the design stage• Where a site is deemed to have no ecological value			
	The refurbishment of a listed building may be exempt from the credit requirements if they conflict with the need to maintain the building's listed features			
Total points achieved to carry forward		6		



POLLUTION				
Credit Reference		With Offices	Without Offices	Points Achieved
P01	<p>Where evidence provided demonstrates the use of refrigerants with a global warming potential (GWP) of less than 5 OR where there are no refrigerants specified for use in building services.</p> <p>For fitted out buildings with integral cold storage areas, the following must also be achieved: Where evidence provided demonstrates that all refrigerant types used in cold storage systems have a global warming potential (GWP) of below 5.</p>	1.15	1.25	1.25
P02	Where evidence provided demonstrates that refrigerant leaks can be detected AND that the provision of automatic refrigerant pump down is made to a heat exchanger (or dedicated storage tanks) with isolation valves OR where there are no refrigerants specified for the development.	1.15	1.25	1.25
P04	Where evidence provided demonstrates that the specification of insulating materials avoids the use of substances with a global warming potential (GWP) of 5 or more in either manufacture or composition	1.15	1.25	1.25
P06	<p>Office and associated areas: Where evidence provided demonstrates that the maximum dry NO_x emissions from delivered space heating energy are:</p> <ul style="list-style-type: none"> ≤70 mg/kWh delivered heating energy or less (at 0% excess O₂). <p>In addition for Fully Fitted Buildings - Operational areas: Where evidence provided demonstrates that the maximum dry NO_x emissions from delivered space heating energy are:</p> <ul style="list-style-type: none"> ≤70 mg/kWh delivered heating energy or less (at 0% excess O₂). <p>NOTE: These point scores <u>ARE</u> cumulative.</p>	1.15	1.25	0
		2.32		
P07	<p>Where evidence provided demonstrates that the assessed development is located in a zone defined as having a low annual probability of flooding.</p> <p>OR</p> <p>Where evidence provided demonstrates that the assessed development is located in a zone defined as having a medium annual probability of flooding and the ground level of the building, car parking and access is above the design flood level for the site's location.</p> <p>NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.</p>	2.32	2.5	2.5
		1.15	1.25	
	Where evidence provided demonstrates that Sustainable Urban Drainage techniques are specified to minimise the risk of localised flooding, resulting from a loss of flood storage on site through development.	1.15	1.25	0



BREEAM Industrial 2006
Pre-Assessment Estimator
Fitted Out Buildings

P08	Where evidence provided demonstrates that on site treatment such as oil separators/interceptors or filtration have been specified for areas at risk from pollution, i.e. vehicle manoeuvring areas, car parks, waste disposal facilities, delivery facilities or plant areas.	1.15	1.25	1.25
P11	Where evidence provided demonstrates that : A feasibility study considering renewable and low emission energy has been carried out and the results implemented. OR In addition to the above , 10% of total energy demand for the building/development is supplied from local renewable or low emission energy, sources. OR In addition to the above and 15% of total energy demand for the building/development is supplied from local renewable or low emission energy, sources. NOTE: These point scores are not cumulative, simply award the appropriate points score corresponding to the predicted level of achievement.	1.15	1.25	2.5
		2.32	2.5	
		3.46	3.75	
P13	Where evidence provided demonstrates that sources of noise from the development do not give rise to the likelihood of complaints from existing noise sensitive premises and amenity or wildlife areas that are within the locality of the site.	1.15	1.25	0
Total points achieved to carry forward				10



BREEAM Industrial 2006
Pre-Assessment Estimator
Fitted Out Buildings

SCORING	
TOTAL OF POINTS ACHIEVED	57.32

Rating	Minimum Score Required
	Design stage & Post Construction Review
PASS	25
GOOD	40
VERY GOOD	55
EXCELLENT	70