

LONDON BOROUGH OF CAMDEN

PLANNING AND COMMUNICATIONS DEPARTMENT

Report from the District Surveyor *Hampstead*

To the Director of Planning and Communications  
Camden Town Hall  
Argyle Street Entrance  
Euston Road  
London WC1H 8EQ

*My Ref: M4- 16/6/81*

Town and Country Planning Acts.

REPORT OF COMPLETION

Case No. C.T.P. *|E4|9X/A|30886*

Premises *312-314, Finchley Road, N.W.6.*

Council's permission dated *4/9/80*

Plan(s) No. *30886*

A survey was made on *15th June 1981*  
and it was found that the works had been completed in  
accordance with the terms and conditions of the planning  
permission and the plan(s) attached thereto with the  
exception of:

*1) The external vertical enclosures have  
been covered with asbestos cement slates*

*and not with cedar wood as  
shown on drawings.*

*cedar wood as*

*A. Bailey*  
*District Surveyor*

PLANNING AND COMMUNICATIONS  
DEPARTMENT  
CAMDEN  
23 JUN 1981