

Clive Attwood
Attwood Design
53 Tentercroft Avenue
SYSTON
LEICESTERSHIRE
LE7 2EZ

Application Ref: **2013/8103/P**
Please ask for: **David Peres Da Costa**
Telephone: 020 7974 **5262**

16 July 2014

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:
69 Tottenham Court Road
London
W1T 2HA

Proposal:
Change of use from amusement arcade (Class Sui Generis) to restaurant/cafe (Class A3) at basement level, alterations to shopfront and repositioning of extended extract flue to rear elevation of main building.

Drawing Nos: 2003 - 00 EP Rev B; 2003 - 02 PP Rev C; 2003 - 01 EP; 2003 - 03 PP Rev A; 2003 - 06 EPF Rev B (with site location plan); 2003 - 03 PS Rev C; 2003 - 04 ES Rev B; 2003 - 07 RE.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and



Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy CS14 of the London Borough of Camden Local Development Framework Core Strategy and policy DP24 and DP25 of the London Borough of Camden Local Development Framework Development Policies.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans:

2003 - 00 EP Rev B; 2003 - 02 PP Rev C; 2003 - 01 EP; 2003 - 03 PP Rev A; 2003 - 06 EPF Rev B (with site location plan); 2003 - 03 PS Rev C; 2003 - 04 ES Rev B; 2003 - 07 RE.

Reason:

For the avoidance of doubt and in the interest of proper planning.

- 4 Before the development commences, full details of a scheme for ventilation, including manufacturers specifications, noise levels and attenuation including an acoustic report to demonstrate compliance with condition 7, shall be submitted to and approved by the Local Planning Authority in writing. The use shall not proceed other than in complete accordance with such scheme as has been approved. All such measures shall be retained and maintained in accordance with the manufacturers' recommendations.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies CS5 and CS7 of the London Borough of Camden Local Development Framework Core Strategy and policies DP12, DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies.

- 5 The use hereby permitted shall not be carried out outside the following times 08:00 to 23:30 Mondays to Thursdays, 08:00 to 00:00 on Fridays and Saturdays and 09:00 to 22:30 on Sundays and public Holidays.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies CS5 and CS7 of the London Borough of Camden Local Development Framework Core Strategy and policy DP26, DP28 and DP12 of the London Borough of Camden Local Development Framework Development Policies.

- 6 Before the development commences, details of the location, design and method of waste storage and removal including recycled materials, shall be submitted to and approved by the local planning authority in writing. The facility as approved shall be

provided prior to the first occupation of any of the new units and permanently retained thereafter.

Reason: To ensure that sufficient provision for the storage and collection of waste has been made in accordance with the requirements of policy CS18 of the London Borough of Camden Local Development Framework Core Strategy and policies DP26 and DP12 of the London Borough of Camden Local Development Framework Development Policies.

- 7 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policy CS5 of the London Borough of Camden Local Development Framework Core Strategy and policies DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website <http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.
- 3 You are reminded of the need to provide adequate space for storage for waste and recyclables. For further information contact Council's Environment Services (Waste) on 020 7974 6914/5 or see the website <http://www.camden.gov.uk/ccm/content/environment/waste-and-recycling/twocolumn/new-recycling-rubbish-and-reuse-guide.en>.


- 4 This permission is granted without prejudice to the necessity of obtaining consent under the Town and Country Planning (Control of Advertisements) (England) Regulations 2007. Application forms may be obtained from the Council's website, www.camden.gov.uk/planning or the Camden Contact Centre on Tel: 020 7974 4444 or email env.devcon@camden.gov.uk).
- 5 Your attention is drawn to the need for compliance with the requirements of the Environmental Health regulations, Compliance and Enforcement team, [Regulatory Services] Camden Town Hall, Argyle Street, WC1H 8EQ, (tel: 020 7974 4444) particularly in respect of arrangements for ventilation and the extraction of cooking fumes and smells.
- 6 You are advised that condition 5 means that no customers shall be on the premises and no noise generating activities associated with the use, including preparation and clearing up, shall be carried out otherwise than within the permitted time.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink, appearing to read 'Rachel Stopard', with a horizontal line underneath.

Rachel Stopard
Director of Culture & Environment