



Notes

- This drawing to be read in conjunction with all relevant Architectural, Structural, Mechanical, Electrical and Public Health drawings and specifications.
- All penetrations through fire compartments to be provided with fire damper c/w actuator linked to fire alarm.

01	23/08/12	LD	LD	PL
Issued For Tender				
00	30/07/12	MVL	LD	PL
Issued for Tender				
Issue	Date	By	Chkd	Appd

ARUP

Client
Institute of Sports, Exercise
and Health

Job Title
Macdonald Buchanan House
Sports Institute

Mechanical Services
Schematic
Ventilation

Scale at A1 NTS

Discipline Mechanical Services

Job No 218598-01 Drawing Status Tender

Drawing No M-SC-00-11 Issue 01