

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## MANHOLE SURVEY

CLIENT. ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD	LO- 101 CAMLEY STREET LONDON NW1
DAT 28/04/14	JOB. CV.0578

MANHOLE NO.13  
COVER 720X570mm  
CHAMBER 1400X1400mm  
WL 1220mm  
B 1570mm

C100 VC DEPTH 400 mm

C100 VC DEPTH 400mm

C100 VC DEPTH 600mm

MANHOLE NO.14  
COVER 720X570mm  
UTR

MANHOLE NO.14A  
UTL

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## MANHOLE SURVEY

CLIENT. ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD	LO- 101 CAMLEY STREET LONDON NW1
DAT 28/04/14	JOB. CV.0570

MANHOLE NO.15  
COVER 720X570mm

C150 VC DEPTH 630mm

C100 VC DEPTH 520mm

C150 VC DEPTH 620mm

C150 VC DEPTH 520mm

MANHOLE NO.16  
COVER 720X570mm

C100 VC DEPTH 390mm

C150 VC DEPTH 510mm

C150 VC DEPTH 500mm

MANHOLE NO.17  
COVER 720X570mm  
UTR

MANHOLE NO.18  
COVER 720X570mm  
UTR

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## PHOTOS

CLIENT. ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD	LO- 101 CAMLEY STREET LONDON NW1
DATE 28/04/14	JOB. CV.0578



MANHOLE NO.14



MANHOLE NO.07

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT. ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD	LOCATION. 101 CAMLEY STREET LONDON NW1
--	--

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	01	28/04/14	COMBINED	750mm	UPSTREAM	150mm	V/CLAY	DRY	YES	GO	1

START FINISH  
 ST. MANHOLE No. 01 CONNECTION-2 FH. MANHOLE NO.03



CHAINAGE	CODE	OBSERVATION
000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
002.8	MC	MATERIAL OF DRAIN CHANGES TO CAST IRON AT THIS POINT
003.4	MC	MATERIAL OF DRAIN CHANGES TO V/CLAY AT THIS POINT
003.7	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
003.7	FH	FINISH OF SURVEY ( MH-03 )

**END OF RUN NO.01**

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	02	28/04/14	COMBINED	880mm	DOWNSTREAM	225mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 01 CONNECTION- X FH. MANHOLE NO.05

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
001.4	FC	FRACTURE, CIRCUMFERENTIAL FROM 12 TO 02 O'CLOCK
009.7	FC	FRACTURE, CIRCUMFERENTIAL FROM 10 TO 02 O'CLOCK
041.6	CC	CRACK, CIRCUMFERENTIAL FROM 12 TO 03 O'CLOCK
047.8	JN	JUNCTION AT 03 O'CLOCK, DIAMETER 100mm
054.0	MH	MANHOLE NO.05
054.0	FH	FINISH OF SURVEY

**END OF RUN NO.02**



# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	03	28/04/14	COMBINED	1140mm	UPSTREAM	225mm	CAST IRON	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 05 CONNECTION- 2 FH. MANHOLE NO.06

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
000.6	LR	LINE OF DRAIN DEVIATES RIGHT ( SLIGHT )
004.6	MC	MATERIAL OF DRAIN CHANGES TO V/CLAY AT THIS POINT
004.6	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP ) TRAP
004.6	MH	MANHOLE NO.06
004.6	FH	FINISH OF SURVEY

**END OF RUN NO.03**



# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	04	28/04/14	COMBINED	1180mm	DOWNSTREAM	450mm	BRICK	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 05 CONNECTION- X FH. MANHOLE NO.07

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
001.4	LL	LINE OF DRAIN DEVIATES LEFT ( SLIGHT )
016.1	MC	MATERIAL OF DRAIN CHANGES TO V/CLAY AT THIS POINT
017.1	MH	MANHOLE NO.07
017.1	FH	FINISH OF SURVEY

END OF RUN NO.04

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	05	28/04/14	SURFACE	860mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 08 CONNECTION- 1 FH. GULLY

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
002.8	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
002.8	FH	FINISH OF SURVEY ( GULLY )

END OF RUN NO.05



# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	06	28/04/14	SURFACE	600mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 08 CONNECTION- 2 FH. UPSTREAM

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
003.0	FM	FRACTURES,MULTIPLE FROM 07 TO 05 O'CLOCK
003.0	B	BROKEN PIPE AT 01 O'CLOCK
003.0	FL	FRACTURE, LONGITUDINAL AT 11 O'CLOCK
003.0	FL	FRACTURE, LONGITUDINAL AT 02 O'CLOCK
003.0	FM	FRACTURES,MULTIPLE FROM 12 TO 12 O'CLOCK
003.5	B	BROKEN PIPE AT 02 O'CLOCK
006.9	FM	FRACTURES,MULTIPLE FROM 12 TO 12 O'CLOCK
006.9	B	BROKEN PIPE AT 02 O'CLOCK
008.6	FH	FINISH OF SURVEY ( EXTENT OF SURVEY )

**END OF RUN NO.06**

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	07	28/04/14	SURFACE	600mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 08 CONNECTION- 3 FH. GULLY

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
007.7	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
007.7	FH	FINISH OF SURVEY ( GULLY )

**END OF RUN NO.07**

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	08	28/04/14	COMBINED	1160mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 03 CONNECTION- 1 FH. GULLY

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
005.5	DES	SETTLED DEPOSITS FINE 05%
009.8	DES	SETTLED DEPOSITS FINE 20%
009.8	SA	SURVEY ABANDONED DUE TO ABOVE



END OF RUN NO.08

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	09	28/04/14	COMBINED	1210mm	UPSTREAM	150mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 03 CONNECTION- 3 FH. MANHOLE NO.04

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
007.7	LR	LINE OF DRAIN DEVIATES RIGHT ( SLIGHT )
007.7	FL	FRACTURE, LONGITUDINAL AT 09 O'CLOCK
008.4	MH	MANHOLE NO.04
008.4	FH	FINISH OF SURVEY



END OF RUN NO.09

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	10	28/04/14	COMBINED	610mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 04 CONNECTION- 2 FH. GULLY

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
000.4	LL	LINE OF DRAIN DEVIATES LEFT ( SLIGHT )
002.5	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
002.5	FH	FINISH OF SURVEY ( GULLY )



END OF RUN NO.10

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	11	28/04/14	COMBINED	480mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 04 CONNECTION- 1 FH. GULLY

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
008.4	CC	CRACK,CIRCUMFERENTIAL FROM 07 TO 05 O'CLOCK
011.0	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
011.0	FH	FINISH OF SURVEY ( GULLY )



END OF RUN NO.11

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	12	28/04/14	COMBINED	1280mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 03 CONNECTION- 2 FH. GULLY

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
000.3	LL	LINE OF DRAIN DEVIATES LEFT ( SLIGHT )
004.2	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
004.2	FH	FINISH OF SURVEY ( GULLY )

END OF RUN NO.12



# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	13	28/04/14	COMBINED	1160mm	UPSTREAM	150mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 06 CONNECTION- 3 FH. UPSTREAM

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
000.4	JN	JUNCTION AT 06 O'CLOCK,DIAMETER 150mm BACKDROP
001.9	JN	JUNCTION AT 03 O'CLOCK,DIAMETER 150mm
011.9	LR	LINE OF DRAIN DEVIATES RIGHT ( SLIGHT )
014.4	MH	MANHOLE NO.14
014.7	LR	LINE OF DRAIN DEVIATES RIGHT ( SLIGHT )
014.7	REM	GENERAL REMARK ( END OF CHAMBER )
016.8	LL	LINE OF DRAIN DEVIATES LEFT ( SLIGHT )
017.0	LL	LINE OF DRAIN DEVIATES LEFT ( SLIGHT )
018.4	MH	MANHOLE NO.14A
018.4	FH	FINISH OF SURVEY

END OF RUN NO.13





# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	14	28/04/14	COMBINED	1220mm	UPSTREAM	150mm	V/CLAY	DRY	YES	GO	1

START ST. MANHOLE No. 06 CONNECTION- 1 FINISH FH. MANHOLE NO.11

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
000.4	JN	JUNCTION AT 06 O'CLOCK, DIAMETER 150mm BACKDROP
000.4	LL	LINE OF DRAIN DEVIATES LEFT ( SLIGHT )
001.7	LL	LINE OF DRAIN DEVIATES LEFT ( SLIGHT )
002.8	MH	MANHOLE NO.10
003.6	REM	GENERAL REMARK ( END OF CHAMBER )
012.2	MH	MANHOLE NO.11
012.2	FH	FINISH OF SURVEY

**END OF RUN NO.14**



# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	15	28/04/14	COMBINED	980mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START ST. MANHOLE No. 06 CONNECTION- 2A FINISH FH. UPSTREAM

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
001.6	LR	LINE OF DRAIN DEVIATES RIGHT ( SLIGHT )
002.0	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
002.0	FH	FINISH OF SURVEY

**END OF RUN NO.15**



# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	16	28/04/14	COMBINED	297mm	UPSTREAM	150mm	CAST IRON	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 06 CONNECTION- 2 FH. MANHOLE 13 TANK

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
000.4	LU	LINE OF DRAIN DEVIATES UP ( SHARP )
000.4	FH	FINISH OF SURVEY

END OF RUN NO.16

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	18	28/04/14	COMBINED	680mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 11 CONNECTION- 1 FH. GULLY

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
002.4	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
002.4	FH	FINISH OF SURVEY ( GULLY )

END OF RUN NO.18

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	19	28/04/14	COMBINED	680mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 11 CONNECTION- 2 FH. GULLY

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
001.4	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
001.4	FH	FINISH OF SURVEY ( GULLY )

END OF RUN NO.19

GULLY

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	20	28/04/14	COMBINED	800mm	UPSTREAM	150mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 11 CONNECTION- 3 FH. UPSTREAM

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
000.4	LL	LINE OF DRAIN DEVIATES LEFT ( SLIGHT )
002.7	LR	LINE OF DRAIN DEVIATES RIGHT ( SLIGHT )
003.9	MH	MANHOLE NO.11A
005.0	REM	GENERAL REMARK ( END OF CHAMBER )
005.4	LL	LINE OF DRAIN DEVIATES LEFT ( SLIGHT )
008.1	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
008.1	FH	FINISH OF SURVEY ( GULLY )

END OF RUN NO.20

U/ST

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	21	28/04/14	COMBINED	710mm	UPSTREAM	150mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 11 CONNECTION- 4 FH. MANHOLE NO.17

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
000.4	LL	LINE OF DRAIN DEVIATES LEFT ( SLIGHT )
010.4	LR	LINE OF DRAIN DEVIATES RIGHT ( SLIGHT )
010.6	MH	MANHOLE NO.17
010.6	FH	FINISH OF SURVEY

END OF RUN NO.21



# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	22	28/04/14	COMBINED	510mm	DOWNSTREAM	150mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No.09 CONNECTION- X FH. MANHOLE NO.10

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
010.6	MH	MANHOLE NO.18
011.3	REM	GENERAL REMARK ( END OF CHAMBER )
011.3	DES	SETTLED DEPOSITS FINE 05%
017.6	MH	MANHOLE NO.10
017.6	FH	FINISH OF SURVEY

END OF RUN NO.22



# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	23	28/04/14	COMBINED	500mm	UPSTREAM	150mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 09 CONNECTION- 1 FH. UPSTREAM

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
001.3	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
001.3	FH	FINISH OF SURVEY

END OF RUN NO.23



# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	24	28/04/14	COMBINED	390mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 09 CONNECTION- 2 FH. GULLY

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
000.3	LL	LINE OF DRAIN DEVIATES LEFT ( SLIGHT )
006.3	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
006.3	FH	FINISH OF SURVEY ( GULLY )

END OF RUN NO.24



# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	24A	28/04/14	COMBINED	510mm	DOWNSTREAM	150mm	V/CLAY	DRY	YES	GO	1

START: ST. MANHOLE No.16 CONNECTION- X FINISH: FH. MANHOLE NO.14

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
008.7	FC	FRACTURE, CIRCUMFERENTIAL FROM 12 TO 12 O'CLOCK
009.2	MH	MANHOLE NO.15
010.2	REM	GENERAL REMARK ( END OF CHAMBER )
011.7	DES	SETTLED DEPOSITS FINE 05%
016.6	LR	LINE OF DRAIN DEVIATES RIGHT ( SLIGHT )
017.6	MH	MANHOLE NO.14

END OF RUN NO.24A



# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	25	28/04/14	COMBINED	500mm	UPSTREAM	150mm	V/CLAY	DRY	YES	GO	1

START: ST. MANHOLE No. 16 CONNECTION- 1 FINISH: FH. UPSTREAM

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
002.7	LL	LINE OF DRAIN DEVIATES LEFT ( SLIGHT )
002.7	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
002.7	FH	FINISH OF SURVEY

END OF RUN NO.25





# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	27	28/04/14	COMBINED	390mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No. 16 CONNECTION- 2 FH. GULLY

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
005.6	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
005.6	DES	SETTLED DEPOSITS FINE 10%
005.6	FH	FINISH OF SURVEY ( GULLY )

END OF RUN NO.27

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	27A	28/04/14	COMBINED	520mm	UPSTREAM	150mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No.15 CONNECTION- 2 FH. UPSTREAM

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
001.2	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
001.2	FH	FINISH OF SURVEY

END OF RUN NO.27A

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## INSPECTION REPORT

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

JOB NO.	RUN NUMBER	DATE	SEWER USE	DEPTH	DIRECTION	PIPE SIZE	MATERIAL	WEATHER	CLEANED	OPERATOR	PAGE
CV.0578	28	28/04/14	COMBINED	520mm	UPSTREAM	100mm	V/CLAY	DRY	YES	GO	1

START FINISH  
ST. MANHOLE No.15 CONNECTION- 3 FH. GULLY

CHAINAGE CODE OBSERVATION



000.0	ST	START OF SURVEY
000.0	WL	WATER LEVEL 05%
007.3	LD	LINE OF DRAIN DEVIATES DOWN ( SHARP )
007.3	FH	FINISH OF SURVEY ( GULLY )

END OF RUN NO.28



# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## SUMMARY AND RECOMMENDATIONS

CLIENT: ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD LOCATION: 101 CAMLEY STREET LONDON NW1

DATE: 28/04/14 JOB: CV.0578

- RUN NO.01 NO WORK NEEDED
- RUN NO.02 FRACTURES
- RUN NO.03 NO WORK NEEDED
- RUN NO.04 NO WORK NEEDED
- RUN NO.05 NO WORK NEEDED
- RUN NO.06 BROKEN AND FRACTURES
- RUN NO.07 NO WORK NEEDED
- RUN NO.08 NO WORK NEEDED
- RUN NO.09 FRACTURE
- RUN NO.10 NO WORK NEEDED
- RUN NO.11 NO WORK NEEDED
- RUN NO.12 NO WORK NEEDED
- RUN NO.13 NO WORK NEEDED
- RUN NO.14 NO WORK NEEDED
- RUN NO.15 NO WORK NEEDED
- RUN NO.16 NO WORK NEEDED
- RUN NO.18 NO WORK NEEDED
- RUN NO.19 NO WORK NEEDED
- RUN NO.20 NO WORK NEEDED

# G.O. DRAINAGE SERVICES LTD

53 PREMIER AVENUE GRAYS RM16 2SJ TEL:01375 373302 MOB:07792 815977 E-MAIL: godrainage@aol.com

## SUMMARY AND RECOMMENDATIONS

CLIENT. ELLIOTTWOOD 241 THE BROADWAY LONDON SW19 1SD	LOCATION. 101 CAMLEY STREET LONDON NW1
DATE 28/04/14	JOB. CV.0578

RUN NO.21 NO WORK NEEDED

RUN NO.22 NO WORK NEEDED

RUN NO.23 NO WORK NEEDED

RUN NO.24 NO WORK NEEDED

RUN NO.24A FRACTURE

RUN NO.25 NO WORK NEEDED

RUN NO.27 NO WORK NEEDED

RUN NO.27A NO WORK NEEDED

RUN NO.28 NO WORK NEEDED

## DRAIN & PIPEWORK CCTV SURVEYS

-

**DRAINS**

**PIPEWORK**

**DUCTS**

**CHUTES**

**CHIMNEY FLUES**

**TANKS**

**HIGH PRESSURE  
WATER JETTING**

-

**SEWER & DRAIN BLOCKAGES**

**DESCALING**

**SILT REMOVAL**

**ROOT CUTTING**


**GREASE REMOVAL**

**REMEDIAL WORKS**

-

**POLYESTER RESIN LINING**

**DRAINAGE EXCAVATIONS & REPAIRS**



**G.O. DRAINAGE SERVICES LTD**

**Wimbledon**

241 The Broadway  
London  
SW19 1SD

tel. (020) 8544 0033  
fax. (020) 8544 0066

**Central London**

4 John Prince's Street  
London  
W1G 0JL

tel. (020) 7499 5888  
fax. (020) 7499 5444

**Nottingham**

Halifax House  
Halifax Place  
Nottingham  
NG1 1QN

tel. 0870 460 0061  
fax. 0870 460 0062

email: [info@elliottwood.co.uk](mailto:info@elliottwood.co.uk)  
[www.elliottwood.co.uk](http://www.elliottwood.co.uk)

elliott wood partnership llp  
structural and civil engineers



INVESTOR IN PEOPLE