

REQUEST FOR COMMENTS/OBSERVATIONS FROM:

Please send in your comments by email to planning@camden.gov.uk, submit comments directly when viewing the application on the web ("view related documents - my submissions") or alternatively, fax your comments to us on 0207 974 1930. Please make it clear which CAAC you are representing.

Regeneration and Planning
Development Management
London Borough of Camden
Town Hall
Judd Street
London
WC1H 8ND

Tel 020 7974 4444
Fax 020 7974 1930
Textlink 020 7974 6866

planning@camden.gov.uk
www.camden.gov.uk/planning

Hampstead CAAC

104 Heath Street
London
NW3 1DR

Application ref: 2014/2482/P

Associated ref(s):

Date of consultation: 09 May 2014

Proposal: Add studio at roof level, form new pitched roof and balcony enlarge two windows to rear and add cantilevered extension to rear

Comments: OBJECT NO COMMENT

OBJECTION

(Please tick as appropriate)

No location plan in package. Submitted? Valid?
Roof plan and front elevation are not consistent - the
front elevation suggests a gable but if a slope is deeper
than shown on plan.
Re-submit to clarify.

Name (block capitals only
- no signatures please)



Date: 04 June 2014

If you would like to discuss the above application in more detail, please telephone Neil Collins of East Area Team on 020 7974 .

All comments and returned plans, should be sent within 21 days to:

