

Application No:	Consultees Name:	Consultees Addr:	Received:	Comment:	Response:
2014/5262/P	Meredith Whitten	Covent Garden Community Association 42 Earlham Street WC2H 9LA	15/09/2014 00:01:48	COMMNT	The CGCA has no objection provided the following concerns are addressed via condition: <ul style="list-style-type: none"> <li>The extract duct should not be placed adjacent to any openable windows, particularly residential windows. The noise report does not mention where the nearest noise-sensitive window is. From the drawings, it appears that the duct is near a residential window.</li> <li>Vibration levels are below the levels outlined in DP28.</li> <li>The extract duct should not be in use between the hours of 23:00 and 07:00 (DP28).</li> </ul>
2014/5262/P	John Dunlop	2 Neal's Yard London WC2H 9DP	25/09/2014 15:44:49	INT	Concerned that the fumes from the duct will be blown into the opening skylight of No2.  Consider moving the duct well away from the skylights of No2.  Move chimney duct well away from these skylights or raise the height of the chimney.