

17-21 EMERALD STREET, LONDON

NOISE IMPACT ASSESSMENT

Report **9563-NIA-01**

Prepared on 29 September 2014

Issued For:

Agap Ltd
24 Undine Road
London
E4 9UW

Contents

1.0	INTRODUCTION	1
2.0	ENVIRONMENTAL NOISE SURVEY	1
2.1	Procedure	1
2.2	Equipment	1
3.0	RESULTS	2
4.0	NOISE CRITERIA	2
5.0	DISCUSSION	3
5.1	Noise Impact Assessment	3
6.0	CONCLUSION	4

List of Attachments

9563-SP1	Indicative Site Plan
9563-TH1	Environmental Noise Time History
Appendix A	Glossary of Acoustic Terminology
Appendix B	Acoustic Calculations

1.0 INTRODUCTION

Clement Acoustics has been commissioned by Agap Ltd, 24 Undine Road, London E4 9UW to measure existing background noise levels at 17-21 Emerald Street, London WC1N 3QN. The measured noise levels will be used to determine noise emission criteria for the proposed plant unit installation in agreement with the planning requirements of the London Borough of Camden.

This report presents the results of the environmental survey followed by noise impact calculations and outlines any necessary mitigation measures.

2.0 ENVIRONMENTAL NOISE SURVEY

2.1 Procedure

Measurements were undertaken at the position shown in indicative site plan 9563-SP1. The choice of this position was based both on accessibility and on collecting representative noise data in relation to the nearest noise sensitive receivers.

Continuous automated monitoring was undertaken for the duration of the survey between 14:10 on 23 September 2014 and 14:30 on 24 September 2014. Weather conditions were generally dry with light winds, therefore suitable for the measurement of environmental noise.

Background noise levels at the monitoring positions consisted mainly of traffic noise from surrounding roads and existing plant servicing nearby commercial premises.

The measurement procedure generally complied with BS7445:1991. *Description and measurement of environmental noise, Part 2- Acquisition of data pertinent to land use.*

2.2 Equipment

The equipment calibration was verified before and after use and no abnormalities were observed.

The equipment used was as follows.

- 1 No. Svantek Type 957 Class 1 Sound Level Meter
- Norsonic Type 1251 Class 1 Calibrator

3.0 RESULTS

The $L_{Aeq: 5min}$, $L_{Amax: 5min}$, $L_{A10: 5min}$ and $L_{A90: 5min}$ acoustic parameters were measured at the location shown in site plan 9563-SP1. The measured noise levels are shown as a time history in Figure 9563-TH1.

Minimum background noise levels are shown in Table 3.1.

	Minimum background noise level $L_{A90: 5min}$ dB(A)
Daytime (07:00 - 23:00)	49
Night-time (23:00 - 07:00)	47

Table 3.1: Minimum background noise levels

4.0 NOISE CRITERIA

The London Borough of Camden's general criterion for noise emissions of new plant installations is as follows:

"Design measures should be taken to ensure that specific plant noise levels at a point 1 metre external to sensitive façades are at least 5dB(A) less than the existing background measurement (L_{A90}) when the equipment is in operation. Where it is anticipated that equipment will have a noise that has distinguishable, discrete continuous note[...], special attention should be given to reducing the noise at any sensitive façade by at least 10dB(A) below the L_{A90} level."

We therefore propose to set the noise criteria as shown in Table 4.1 in order to comply with the above requirements.

	Noise Emissions Criteria at Receiver [10dB Below Minimum L_{A90}]
Daytime (07:00 - 23:00)	39 dB(A)
Night-time (23:00 - 07:00)	37 dB(A)

Table 4.1: Proposed Noise Emissions Criteria

The proposed plant unit is for commercial use and will only be operational during daytime. This assessment will therefore be based on the daytime criterion of 39 dB(A).

5.0 DISCUSSION

The plant installation is comprised of the following unit:

- 1 No. Toshiba Air Conditioning Unit: MAP1204HT8

The selected unit and the associated spectral noise emissions levels, as provided by the manufacturer, are shown in Table 5.1. Loudest modes of operation have been used in order to present a robust assessment.

Unit	Sound Pressure Level (dB) in each Frequency Band at 1m							
	63Hz	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	8kHz
Toshiba Condenser Unit type: MAP1204HT8	56	60	62	61	55	49	43	45

Table 5.1 Manufacturer's Sound Pressure Levels at 1m

The proposed plant unit will be installed on the flat roof area alongside the existing plant units against the stairwell wall of 17-21 Emerald Street, as shown in indicative site plan 9563-SP1.

The closest noise sensitive window likely to be affected by noise emissions from the proposed plant unit is the rear of the residential properties on Lamb's Conduit Street, approximately 20 metres away.

5.1 Noise Impact Assessment

Taking all necessary acoustic corrections into consideration, including distance corrections and reflections, noise levels expected at the closest residential window would be as shown in Table 5.2. Detailed calculations are shown in Appendix B. Note that this is a 'worst-case' level and does not account for any screening that is offered by the building envelope.

Receiver	Daytime Criterion	Noise Level at Receiver (due to proposed plant unit)
Nearest Noise Sensitive Receiver	39 dB(A)	38 dB(A)

Table 5.2: Noise levels and criteria at nearest noise sensitive receiver

As shown in Appendix B and Table 5.2, transmission of noise to the nearest sensitive window due to the effects of the proposed plant installation would be expected to meet the noise emissions

criteria set by the London Borough of Camden, without the need for any particular mitigation measures.

6.0 CONCLUSION


An environmental noise survey has been undertaken at 17-21 Emerald Street, London WC1N 3QN. The results of the survey have enabled criteria to be set for noise emissions from the proposed plant installation in accordance with the requirements of the London Borough of Camden.

A noise impact assessment has then been undertaken using manufacturer noise data to predict noise levels due to the current proposal at nearby noise sensitive receivers.

Calculations show that noise emissions from the proposed plant unit would meet the requirements of the London Borough of Camden, without the need for any particular mitigation measures.


Report by
Andrew Thomas

Checked by
Florian Clement MIOA



17-21 EMERALD STREET, LONDON

Environmental Noise Time History
23 September to 24 September 2014



GLOSSARY OF ACOUSTIC TERMINOLOGY

dB(A)

The human ear is less sensitive to low (below 125Hz) and high (above 16kHz) frequency sounds. A sound level meter duplicates the ear's variable sensitivity to sound of different frequencies. This is achieved by building a filter into the instrument with a similar frequency response to that of the ear. This is called an A-weighting filter. Measurements of sound made with this filter are called A-weighted sound level measurements and the unit is dB(A).

L_{eq}

The sound from noise sources often fluctuates widely during a given period of time. An average value can be measured, the equivalent sound pressure level L_{eq} . The L_{eq} is the equivalent sound level which would deliver the same sound energy as the actual fluctuating sound measured in the same time period.

L_{10}

This is the level exceeded for not more than 10% of the time. This parameter is often used as a “not to exceed” criterion for noise

L_{90}

This is the level exceeded for not more than 90% of the time. This parameter is often used as a descriptor of “background noise” for environmental impact studies.

L_{max}

This is the maximum sound pressure level that has been measured over a period.

Octave Bands

In order to completely determine the composition of a sound it is necessary to determine the sound level at each frequency individually. Usually, values are stated in octave bands. The audible frequency region is divided into 10 such octave bands whose centre frequencies are defined in accordance with international standards.

Addition of noise from several sources

Noise from different sound sources combines to produce a sound level higher than that from any individual source. Two equally intense sound sources operating together produce a sound level which is 3dB higher than one alone and 10 sources produce a 10dB higher sound level.

Attenuation by distance

Sound which propagates from a point source in free air attenuates by 6dB for each doubling of distance from the noise source. Sound energy from line sources (e.g. stream of cars) drops off by 3dB for each doubling of distance.

Subjective impression of noise

Sound intensity is not perceived directly at the ear; rather it is transferred by the complex hearing mechanism to the brain where acoustic sensations can be interpreted as loudness. This makes hearing perception highly individualised. Sensitivity to noise also depends on frequency content, time of occurrence, duration of sound and psychological factors such as emotion and expectations. The following table is a reasonable guide to help explain increases or decreases in sound levels for many acoustic scenarios.

Change in sound level (dB)	Change in perceived loudness
1	Imperceptible
3	Just barely perceptible
6	Clearly noticeable
10	About twice as loud
20	About 4 times as loud

Barriers

Outdoor barriers can be used to reduce environmental noises, such as traffic noise. The effectiveness of barriers is dependent on factors such as its distance from the noise source and the receiver, its height and its construction.

Reverberation control

When sound falls on the surfaces of a room, part of its energy is absorbed and part is reflected back into the room. The amount of reflected sound defines the reverberation of a room, a characteristic that is critical for spaces of different uses as it can affect the quality of audio signals such as speech or music. Excess reverberation in a room can be controlled by the effective use of sound-absorbing treatment on the surfaces, such as fibrous ceiling boards, curtains and carpets.

APPENDIX B

9563

17-21 EMERALD STREET, LONDON

EXTERNAL PLANT NOISE EMISSIONS CALCULATION

Receiver: Nearest Residential Receiver

Source: Proposed plant installation

	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
Manufacturer provided sound pressure level at 1 metre									
Toshiba Air Conditioning Unit: MAP1204HT8	56	60	62	61	55	49	43	35	61
Correction for reflections, dB	3	3	3	3	3	3	3	3	
Distance correction to receiver, dB (20m)	-26	-26	-26	-26	-26	-26	-26	-26	
Sound pressure level at receiver	33	37	39	38	32	26	20	12	38

Design Criterion

39