

## Acoustic report checklist for planning applications

Please fill in the checklist and attach to the acoustic report with your planning application.

Please place a tick against one box for every item in each category, to indicate whether the relevant information has been included in the report, excluded, or does not apply.

Category ITEM	Yes	No	Not applicable- state why?
1. Introduction & Description of Development		✓	see main application
2. Authors name and qualifications	✓		A. Bithell Cool Environment.
3. Maps/Plans included		✓	see Main application
4. Photo of site and surroundings		✓	see main application
5. Guidance/Standards Quoted?	✓		see letter.
6. Calibration and Sound Level Meter details			8928 Digital Sound Meter 'A'
7. Is Development considered Noise Sensitive?		✓	Rear, Basement level.
8. Is Development Potentially Noisy (see LAQs)?	✓	✓	
9. Existing Noise Environment assessed?	✓		sampled between 7am - 9pm.
10. Impact of Noise Sources?		✓	Existing Restaurant terrace during day
11. Proposed Working Hours and Methods?	✓		see Main Application
12. Distance (nearest Noise sensitive receptor)?			2nd floor Bedroom
13. Boundary Noise Limits?			N/A

Category ITEM	Yes	No	Not applicable – state why?
14. Building Orientation/Construction?		✓	see main appl w/rai
15. Noise Barriers/ attenuation proposed?		✓	Not Regl.
16. Equipment Specification?	✓		Attached
17. Noise Management Plan?	No Night Work		Not Regl
18. Background Noise measurement (General)?	checked the		hourly Max/Min during working day
19. Background Noise (Worse Case)?			N/A.
20. LB Camden's Noise Conditions considered under DP28/DP29?	✓		
21. Evaluation/Analysis of measured levels?	✓		see Attached
22. Frequency Analysis done?		✓	Not Regl.
23. Vibration analysis done?		✓	Not Regl.
Other Considerations/comments (please specify) PLEASE FIND ATTACHED EQUIPMENT DATA SHEET			

Signed  ..... Print name ABITHELL .....


Company details COOL ENVIRONMENT S. .....

Date 06-07-2014 .....

If you have any queries on filling in this form please see further guidance on the planning website, email [helen.masterson@camden.gov.uk](mailto:helen.masterson@camden.gov.uk) or ring our Noise duty officer on 0207 974 2163.



DAIKIN



**VRV**

Fully integrated solutions for medium to large commercial environments

INDOOR UNIT				FXDQ20M9		FXDQ25M9	
Cooling capacity	Nom.		kW	2.2		2.8	
Heating capacity	Nom.		kW	2.5		3.2	
Power input - 50Hz	Cooling	Nom.	kW		0.050		
	Heating	Nom.	kW		0.050		
Casing Colour				Unpainted			
Dimensions	Unit	HeightxWidthxDepth	mm	230x502x652			
Required ceiling void >				250			
Weight	Unit			17			
Fan-Air flow rate - 50Hz	Cooling	High/Low	m <sup>3</sup> /min	6.7/5.2		7.4/5.8	
	Heating	High/Low	m <sup>3</sup> /min	6.7/5.2		7.4/5.8	
Sound power level	Cooling	Nom.	dBA		50		
	Heating	Nom.	dBA		37/32		
Sound pressure level	Cooling	High/Low	dBA		37/32		
	Heating	High/Low	dBA		37/32		
Refrigerant	Type			R-410A			
Piping connections	Liquid/OD/Gas/OD/Drain			6.35/12.7/I.D. 21.6, O.D. 27.2			
Power supply	Phase/Frequency/Voltage			1~/50/230			
Current - 50Hz	Maximum fuse amps (MFA)			16			



FXDQ-M9

## Heating & Cooling **SkyAir** Perfect for light commercial applications

INDOOR UNIT				FDBQ25B			
Cooling capacity	Nom.		kW				
Heating capacity	Nom.		kW				
Casing	Material			Zinc coated low carbon steel			
Dimensions	Unit	HeightxWidthxDepth	mm	230x652x502			
Weight	Unit			17.0			
Fan - Air flow rate	Cooling	High/Low	m <sup>3</sup> /min	6.50/5.20			
	Heating	High/Low	m <sup>3</sup> /min	6.95/5.20			
Sound power level	Cooling	High/Low	dBA	55.0/49.0			
	Heating	High/Low	dBA	55.0/49.0			
Sound pressure level	Cooling	High/Low	dBA	35.0/28.0			
	Heating	High/Low	dBA	35.0/29.0			
Piping connections	Liquid	OD	mm	6.35			
	Gas	OD	mm	9.52			
Power supply	Drain			27.2			
	Phase / Frequency / Voltage			1~/50/230			



FDBQ25B




BRC1E52A/B

(1) Sound values are measured in a semi-anechoic room. (2) Sound pressure level is a relative value, depending on the distance and acoustic environment. For more details, please refer to the sound level drawings. (3) The sound power level is an absolute value indicating the power which a sound source generates.

OUTDOOR UNIT				3MXS40K	3MXS52E	3MXS68G	4MXS88F	4MXS80E	5MXS90E	
Dimensions	Unit	HeightxWidthxDepth	mm	735x936x300				770x900x320		
Weight	Unit			49				58		
Sound power level	Cooling	Nom.	dBA	59				61		
	Heating	Nom.	dBA	46				48		
Sound pressure level	Cooling	Nom.	dBA	47				49		
	Heating	Nom.	dBA					52		
Compressor	Type			Hermetically sealed swing compressor						
Operation range	Cooling	Ambient	Min.~Max. °CDB	-10~-46						
	Heating	Ambient	Min.~Max. °CWB	-15~-18						
Refrigerant	Type			R-410A						
Piping connections	GWP			1,975						
	Liquid	OD	mm	6.35						
	Gas	OD	mm	9.5		9.52				
	Drain	OD	mm	16 (inner diameter of connecting hose)						
	Gas 2	OD	mm			12.7				
	Gas 3	OD	mm			15.9		15.9		
Piping length	OU - IU	Max.	m	25						
	IU - OU	Max.	m	15						
	IU - IU	Max.	m	7.5		7.5				
Total piping length	System	Actual	m	50		60		70		
Power supply	Phase / Frequency / Voltage			1~/50/230						


Daikin Units



OUTDOOR UNIT				RXYSQ4P8V1	RXYSQ5P8V1	RXYSQ6P8V1
Capacity range				4	5	6
Cooling capacity	Nom.			12.6	14.0	15.5
Heating capacity	Nom.			14.2	16.0	18.0
Power input - 50Hz	Cooling	Nom.	kW	3.24	3.51	4.53
	Heating	Nom.	kW	3.12	3.86	4.57
EER				3.89	3.99	3.42
COP				4.55	4.15	3.94
Maximum number of connectable indoor units				8	9	9
Indoor index connection	Min.			50	62.5	70
Indoor index connection	Max.			130	162.5	182
Dimensions	Unit	HeightxWidthxDepth	mm	1,345x900x320		
Weight	Unit			120		
Sound power level	Cooling	Nom.	dBA	66	67	69
	Heating	Nom.	dBA	50	51	53
Sound pressure level	Cooling	Nom.	dBA	52	53	55
	Heating	Nom.	dBA			
Operation range	Cooling	Min.~Max.	°CDB	-5~-46		
	Heating	Min.~Max.	°CWB	-20~-15.5		
Refrigerant	Type			R-410A		
Piping connections	Liquid	OD	mm	9.52		
	Gas	OD	mm	19.1		
	Total piping length	System	Actual	m	115	135
Level difference	OU - IU			40 (Outdoor unit in highest position) / 30 (Indoor unit in highest position)		
Power supply	Phase/Frequency/Voltage			1N~/50/220-240		
Current - 50Hz	Maximum fuse amps (MFA)			32.0		

(1) EER/COP according to Eurovent 2012

revisions:



*Proposed A/C units x2  
placed on top of each other*



Mark Zudini  
Unit 2, No9 Chatsworth rd  
London E5 0LH

status:  
PLANNING

project:  
128 Regent's Park Rd NW1

drawing:  
BASEMENT FLOOR PLAN AS  
PROPOSED

date: scale: job no: dwg no:  
APRIL 2014 1:50@A3 070 P0.02