



GRAYS INN ROAD, LONDON
18-Aug-14
JOB 13 - AMENITY RESULTS - NEW WALL HEIGHT

Room/Floor	Room Use	Window			No Sky	%Sun		
			%VSC	%ADF	% of Room	Summer	Winter	Total
277 GRAYS INN ROAD								
LOWER GROUND FLOOR								
R9/499	BEDROOM	W27/499	0.70	1.02	5.84%	0.00	0.00	0.00
R10/499	BEDROOM	W26/499	0.87	1.23	8.08%	0.00	0.00	0.00
R11/499	BEDROOM	W25/499	1.84	2.02	8.07%	1.00	0.00	1.00
R12/499	BEDROOM	W24/499	2.16	2.27	7.93%	5.00	0.00	5.00
R13/499	BEDROOM	W23/499	2.19	2.28	8.06%	5.00	1.00	6.00
R14/499	BEDROOM	W29/499	1.94	2.16	8.06%	6.00	1.00	7.00
R15/499	BEDROOM	W28/499	0.88	1.41	7.28%	6.00	2.00	8.00
R16/499	BEDROOM	W30/499	0.30	1.09	12.89%	0.00	0.00	0.00
R17/499	LKD	W31/499	6.41	3.36	51.38%	6.00	0.00	6.00
		W33/499	16.14			#N/A	#N/A	#N/A
R18/499	BEDROOM	W32/499	4.92	1.29	46.92%	5.00	0.00	5.00
GROUND FLOOR								
R15/500	LKD	W22/500	4.04	2.12	92.41%	5.00	0.00	5.00
		W41/500	10.45			#N/A	#N/A	#N/A
R16/500	LKD	W23/500	4.07	3.42	88.92%	0.00	0.00	0.00
		W40/500	24.04			#N/A	#N/A	#N/A
R17/500	LKD	W24/500	9.09	3.82	98.33%	4.00	1.00	5.00
		W39/500	20.33			#N/A	#N/A	#N/A
R18/500	LKD	W25/500	9.66	3.34	99.58%	10.00	1.00	11.00
		W38/500	12.18			#N/A	#N/A	#N/A
R19/500	LKD	W26/500	9.98	3.43	98.96%	16.00	1.00	17.00
		W37/500	13.44			#N/A	#N/A	#N/A
R20/500	LKD	W27/500	9.66	4.09	96.80%	19.00	2.00	21.00
		W36/500	23.59			#N/A	#N/A	#N/A
R21/500	LKD	W28/500	2.32	2.98	84.72%	10.00	3.00	13.00
		W35/500	22.52			#N/A	#N/A	#N/A
R22/500	LKD	W29/500	0.09	1.87	79.07%	0.00	0.00	0.00
		W34/500	24.71			#N/A	#N/A	#N/A
R23/500	LKD	W30/500	16.49	4.86	97.67%	21.00	2.00	23.00
		W33/500	20.55			#N/A	#N/A	#N/A
R24/500	BEDROOM	W31/500	8.39	1.63	53.94%	21.00	1.00	22.00